



REPLACE ANNUNCIATOR

PROVIDE FILLER PLATE AND
NEW MASTER CONTROLLER
HMI TOUCH SCREEN DISPLAY

PROVIDE FILLER PLATE AND
NEW MASTER CONTROLLER
HMI TOUCH SCREEN DISPLAY

REMOVE RECORDERS AND
PROVIDE FILLER PLATES

REPLACE INCANDESCENT
INDICATORS WITH LOW
VOLTAGE LED INDICATORS

REMOVE 4 CONTROLLERS.
PROVIDE NEW FILLER PLATE.
REMOUNT EXISTING
SELECTOR SWITCHES.

VA MEDICAL CENTER
WEST PALM BEACH, FL
BOILER PLANT CONTROL ROOM
MAIN BOILER CONTROL PANEL.