

Exhibit C SECURITY STANDARDS

The Lessor agrees to the requirements of Security Level II attached to this Lease.

1.01.1 GENERAL REQUIREMENTS (NOV 2005)

A. Overview of Lease Security Standards:

1. The Government will determine security standards for facilities and agency space requirements. Security standards will be assessed based upon tenant agency mix, size of space requirement, number of employees, use of the space, location of the facility, configuration of the site and lot, and public access into and around the facility. The Government will designate a security level from Level I to Level IV for each space requirement. The Contracting Officer (or the Contracting Officer's designated representative) will provide the security level designation as part of the space requirement. A copy of the Government's security standards is available at www.oca.gsa.gov.
2. The Contracting Officer (or the Contracting Officer's designated representative) will identify all required security standards.
3. Within 120 days of lease award, or at the time of submission of working/construction drawings, whichever is earlier, the Lessor shall provide the Government with itemized costs of the security items in this section. Additionally, the Lessor shall provide the cost per square foot of those items designated "shell" in this section as submitted in the final offer.
4. A security level designation may be determined by the individual space requirement or by the assessed, cumulative tenant agency mix within a given facility. If an Offeror is offering space in a facility currently housing a federal agency, the security level designation of the facility may be increased and the Offeror may be required to adhere to a higher security standard than other Offerors competing for the same space requirement. If two or more federal space requirements are being competed at the same time, an Offeror submitting on both or more space requirements may be subject to a higher security standard if the Offeror is determined to be the successful Offeror on more than one space requirement. It is incumbent upon the Offeror to prepare the Offeror's proposal accordingly.
5. Level I requirements have been incorporated into the paragraphs entitled, Lighting: Interior and Parking, and Doors: Hardware as part of this SFO. If this SFO is used for a Level I space requirement, the Level II lease security standards, as determined by the Government, shall become the minimum lease security standards for this requirement.

1.01.2 DETERRENCE TO UNAUTHORIZED ENTRY (NOV 2005)

The Lessor shall provide a level of security that reasonably prevents unauthorized entry to the space during non-duty hours and deters loitering or disruptive acts in and around the space leased. The Lessor shall ensure that security cameras and lighting are not obstructed.

1.01.3 ACCESS TO UTILITY AREAS (NOV 2005)

Utility areas shall be secure, and only authorized personnel shall have access.

1.01.4 EMERGENCY POWER TO CRITICAL SYSTEMS (SEP 2009)

Emergency power backup is required for all alarm systems, CCTV monitoring devices, fire detection systems, entry control devices, lighting, etc., and special equipment, as identified elsewhere in the SFO.

A. Building Shell:

Emergency power to building systems is building shell.

B. Tenant Improvement:

Emergency power to agency special equipment is tenant improvement.

1.01.5 MECHANICAL AREAS AND BUILDING ROOFS (NOV 2005)

- A. Keyed locks, keycards, or similar security measures shall strictly control access to mechanical areas. Additional controls for access to keys, keycards, and key codes shall be strictly maintained. The Lessor shall develop and maintain accurate HVAC diagrams and HVAC system labeling within mechanical areas.
- B. Roofs with HVAC systems shall also be secured. Fencing or other barriers may be required to restrict access from adjacent roofs based on a Government Building Security Assessment. Roof access shall be strictly controlled through keyed locks, keycards, or similar measures. Fire and life safety egress shall be carefully reviewed when restricting roof access.

1.01.6 ACCESS TO BUILDING INFORMATION (NOV 2005)

Building Information—including mechanical, electrical, vertical transport, fire and life safety, security system plans and schematics, computer automation systems, and emergency operations procedures—shall be strictly controlled. Such information shall be released to authorized personnel only, approved by the Government, preferably by the development of an access list and controlled copy numbering. The Contracting Officer may direct that the names and locations of Government tenants not be disclosed in any publicly accessed document or record. If that is the case, the Government may request that such information not be posted in the building directory.

1.01.7 POSTING OF GOVERNMENT RULES AND REGULATIONS (TENANT IMPROVEMENT) (NOV 2005)

The Government will post applicable Government rules and regulations at the entrance to any Government-occupied space for such things as, but not limited to, barring the unauthorized possession of firearms and dangerous weapons. The Government will coordinate with the Lessor to ensure signage is consistent with the Lessor's standards.

1.01.8 DEVELOPMENT, IMPLEMENTATION, AND PERIODIC REVIEW OF OCCUPANT EMERGENCY PLANS (NOV 2005)

The Lessor shall cooperate and participate in the development of an Occupant Emergency Plan (OEP) and if necessary, a supplemental Sheltering-in Place (SIP) Plan. Periodically, the Government may request that the Lessor assist in reviewing and revising the OEP and SIP plan(s).

1.01.9 BUILDING SECURITY PLAN (NOV 2005)

The Offeror shall provide a Pre-Lease Building Security Plan with the offer that addresses its compliance with the lease security standards, as described in this SFO and its attachments.

1.01.10 ADDITIONAL SECURITY MEASURES AS DETERMINED BY THE GOVERNMENT (NOV 2005)

The Government reserves the right, prior to the submission of final revised proposals, to require additional security measures to meet specific tenant occupancy requirements, as may be determined by the Government's building security assessment or any type of Government risk assessment evaluation of the proposed building, location, and tenant mix.

1.01.11 VERIFICATION OF PERSONNEL (MAY 2007)

A. The Government reserves the right to verify identities of personnel with routine access to Government space. The Lessor shall comply with the agency personal identity verification procedures below that implement Homeland Security Presidential Directive-12 (HSPD-12), Office of Management and Budget (OMB) guidance M-05-24, and Federal Information Processing Standards Publication (FIPS PUB) Number 201, as amended.

B. The Lessor shall insert this paragraph in all subcontracts when the subcontractor is required to have physical access to a federally controlled facility or access to a federal information system.

C. Lessor compliance with subparagraphs 1 through 4 below will suffice to meet the Lessor's requirements under HSPD-12, OMB M-05-24, and FIPS PUB Number 201.

1. The Government reserves the right to conduct background checks on Lessor personnel and contractors with routine access to Government leased space.

2. Upon request, the Lessor shall submit completed fingerprint charts and background investigation forms for each employee of the Lessor, as well as employees of the Lessor's contractors or subcontractors, who will provide building operating services requiring routine access to the Government's leased space for a period greater than 6 months. The Government may also require this information for the Lessor's employees, contractors, or subcontractors who will be engaged to perform alterations or emergency repairs in the Government's space.

3. The Lessor must provide Form FD-258, Fingerprint Chart (available from the Government Printing Office at <http://bookstore.gpo.gov>), and Standard Form 85P, Questionnaire for Public Trust Positions, completed by each person and returned to the contracting officer (or the contracting officer's designated representative) within 30 days from receipt of the forms. Based on the information furnished, the Government will conduct background investigations of the employees. The contracting officer will advise the Lessor in writing if an employee fails the investigation, and, effective immediately, the employee will no longer be allowed to work or be assigned to work in the Government's space.

4. Throughout the life of the lease, the Lessor shall provide the same data for any new employees, contractors, or subcontractors who will be assigned to the Government's space. In the event the Lessor's contractor or subcontractor is subsequently replaced, the new contractor or subcontractor is not required to submit another set of these forms for employees who were cleared through this process while employed by the former contractor or subcontractor. The Lessor shall resubmit Form FD-258 and Standard Form 85P for every employee covered by this paragraph on a 5-year basis.

1.01.12 ENTRY SECURITY: PUBLIC LOBBIES/ENTRANCES/EXITS (NOV 2005)

The Lessor shall permit Government security control over all public areas and building entry points, including adjacent surface parking, underground parking, and structures under the building owner's control. The Government will have the

right to inspect at point of entry and in the public space. This right also includes the right to deny access and to remove persons and vehicles from the premises.

1.01.14 ENTRY SECURITY: TRUCK SHIPMENTS (NOV 2005)

When the Government will occupy the building in its entirety, or nearly so (approx. 90 percent or greater), the Government will have the right to divert truck shipments to a secondary location for screening purposes.

1.01.15 ENTRY SECURITY: INTRUSION DETECTION SYSTEM WITH CENTRAL MONITORING CAPABILITY (NOV 2005)

The Lessor shall permit installation of a perimeter Intrusion Detection System (IDS) to be operated and maintained by the Government or contracted vendor.

1.01.18 OCCUPANT/VISITOR SCREENING: VISITOR CONTROL/SCREENING SYSTEM (NOV 2005)

- A. All visitors to the building shall be required to sign in with a receptionist or guard, display a formal identification/badge, and/or require an escort. The Lessor shall permit a staffed station or stations. Public entrances and lobby space shall be made available for visitor control and screening equipment.
- B. Visitor control and screening is required throughout the facility as determined by the Government's building security assessment. Underground garages and parking area entrances are also subject to visitor controls and screening.

1.01.19 SECURE HVAC: OUTDOOR AIR INTAKES (BUILDING SHELL) (NOV 2005)

- A. The outdoor air intakes shall be located on a secure roof or high sidewall and not within 30 feet of the loading dock; otherwise the Lessor shall relocate, extend, or secure intakes as described below:
 - 1. Outdoor air intakes shall be relocated. The lowest edge of the outdoor air intakes shall be placed 40 feet, 0 inches above grade and not less than 30 feet, 0 inches from the loading dock. Access shall be locked and secured, if feasible. For increased visibility of suspicious items, moat areas and other ground level areas surrounding outside air intakes shall be completely free of trash, debris or any other matter.
 - 2. Outdoor air intakes shall be extended. If relocation is not feasible, as approved by the Government, intake extensions shall be constructed without creating adverse effects on HVAC performance. The higher the extensions, the better, as long as other design constraints (excessive pressure loss, dynamic and static loads on structure) are considered. An extension height of 40 feet, 0 inches is required unless adverse effects on HVAC performance can be demonstrated. The entrance to the intake shall be covered with a sloped metal mesh to reduce the threat of objects being tossed in the intake. A minimum slope of 45 degrees may be required. Extension height shall be increased where existing platforms or building features (e.g., loading docks, retaining walls) might provide access to the outdoor air intakes.
 - 3. A security zone around outdoor air intakes shall be established. When outdoor air intakes are publicly accessible and relocation or physical extensions are not viable options or are cost prohibitive, perimeter barriers that prevent public access to outdoor air intake areas shall be required based on the Government's building security assessment. Iron fencing or similar see-through barriers may be required. The restricted area shall also include an open buffer zone between the public areas and the intake louvers. The Government will have the right to monitor the buffer zone by physical security and/or closed circuit television (CCTV). Security lighting or intrusion detection sensors are required and shall be provided and installed by the Lessor.

1.01.20 SECURE HVAC: DEDICATED HVAC FOR LOBBIES, MAILROOMS, AND LOADING DOCKS (BUILDING SHELL) (NOV 2005)

To prevent widespread dispersion of a contaminant released within lobbies, mailrooms, and loading docks, the associated HVAC systems shall be isolated and the areas maintained by a dedicated exhaust system at a negative pressure relative to the rest of the building, but at a positive pressure relative to the outdoors. Physical isolation of these areas (well-sealed floor to roof-deck walls, sealed wall penetrations) is critical to maintaining the pressure differential and requires special attention to ensure airtight boundaries between these areas and adjacent spaces. A qualified HVAC professional can assist in determining if the recommended isolation is feasible for a given building. A modification to an existing system will likely require a re-evaluation of the existing HVAC system as well as potentially involving architectural and/or structural changes to the building. Any re-engineering of HVAC systems shall be estimated and costs identified to the Contracting Officer before beginning any proposed alterations. In addition, lobbies, mailrooms, and loading docks shall not share a return-air system. The Lessor shall provide lobby, mailroom, and loading dock ventilation systems' outside air intakes and exhausts with low leakage, fast acting, isolation dampers that can be closed to isolate their systems. Dedicated HVAC will be required for mailrooms only when the Government specifically requires a centrally-operated mailroom. Non-Government building tenants may share the mailroom. Where possible, the mailroom shall be adjacent to the loading dock to prevent the possible contamination of additional areas within the building. Any mailroom or area where mail is received and sorted, shall have posted the telephone numbers of the Lessor/Owner's building manager/engineer and local emergency personnel for emergency notification. Mailrooms shall also have posted a copy of the general precautions for mail handling.

1.01.21 SECURE HVAC: AIRBORNE HAZARDS (NOV 2005)

Air-handling units shall be able to be shut down in response to a threat. Procedures shall be in place for notification of the Lessor's building engineer or manager, building security guard desk, local emergency personnel, VHA personnel, and Contracting Officer for possible shut-down of the air handling units serving the mailroom and/or any other possibly affected areas of the building to minimize contamination, as deemed appropriate to the hazard.

1.01.22 SECURE HVAC: SECURE RETURN-AIR GRILLES (BUILDING SHELL) (NOV 2005)

The Lessor shall secure return-air grilles in public lobbies. Protection measures shall not adversely affect performance of the building's HVAC system. Return air-grille protective measures include 1) relocating return-air grilles to inaccessible, yet observable locations, 2) increasing security presence (human or CCTV) near vulnerable return-air grilles, 3) directing public access away from return-air grilles, and 4) removing furniture and visual obstructions from areas near air grilles.

1.01.23 PARKING SECURITY REQUIREMENTS (NOV 2005)

- A. Control of Parking Areas:
The Lessor shall permit Government security control over all parking areas, surface or structured. Security control will include the right to inspect at points of entry, the right to deny access, and the right to remove vehicles from the premises. The Lessor shall provide a vehicle pass/ID system for contract/monthly parkers, acceptable to the Government.
- B. Arrange for Employee Parking after Normal Working Hours:
The Lessor will allow employee parking in/near the building after normal working hours.
- C. No vehicle shall be parked or be permitted to travel closer than 25 feet [7.62 m] to any life- safety protected VA Facility.
- D. Parking and access for patients, visitors, and the persons transporting them to and from the VA facility shall be as convenient as possible to the main entrance, subject to the requirements above. Where vehicles are unscreened, make site provisions to accommodate a shuttle service for persons needing assistance. Parking and facility access shall comply with accessibility requirements.
- E. Emergency entrance shall be provided with a small parking area for emergency patients and space for ambulances. Ambulances shall be permitted to approach the building directly and not be subjected to the distance requirements
- F. Vendors shall use the delivery vehicle entrance and service yard at the loading dock. Parking shall be provided for vendors in the service yard.

1.01.26 SHATTER-RESISTANT WINDOW PROTECTION REQUIREMENTS (NOV 2005) (BUILDING SHELL)

- A. The Lessor shall provide and install wet-glazed or mechanically attached, shatter-resistant material not less than 0.18 millimeters (7 mil) thick on all exterior windows in Government-occupied space. The Offeror shall provide a description of the shatter-resistant window system in the attached "Pre-Lease Building Security Plan" for evaluation by the Government. Alternatively,
- B. The Lessor shall provide certification from a licensed professional engineer that the window system conforms to a minimum glazing performance condition of "3B" for a high protection level and a low hazard level. Window systems shall be certified as prescribed by WINGARD 4.1 or later or WINLAC 4.3 software to have satisfied the specified performance condition using the test methods provided in the US General Services Administration Standard Test Method for Glazing and Window Systems Subject to Dynamic Overpressure Loadings or ASTM F1642-04 Standard Test Method for Glazing and Glazing Systems Subject to Airblast Loadings.

1.01.27 TEMPORARY SECURITY UPGRADE DUE TO IMMEDIATE THREAT (NOV 2005)

The Government reserves the right, at its own expense and with its own personnel, to temporarily heighten security in the building under lease during heightened security conditions due to emergency situations such as terrorist attacks, natural disaster, and civil unrest.

1.01.28 SECURITY DESIGN CRITERIA (NOV 2005)

- A. Security Design Criteria:
The Lessor shall ensure that the building design conforms to the standards detailed in the latest version of the Interagency Security Committee's (ISC) Security Design Criteria. A copy of the criteria is available at www.oca.gsa.gov.

1.01.29 SECURITY DESIGN CRITERIA: SETBACK (BUILDING SHELL) (NOV 2005)

The Lessor shall provide a setback distance of 20ft as specified from the face of the building's exterior to the protected/defended perimeter (i.e., any potential point of explosion). This means the distance from the building to the curb or other boundary protected by bollards, planters or other street furniture. Such potential points of explosion may be,

but are not limited to, such areas that could be accessible by any motorized vehicle (i.e., street, alley, sidewalk, driveway, parking lot).

1.01.30 SECURITY DESIGN CRITERIA: FACADE PROTECTION (BUILDING SHELL) (NOV 2005)

- A. Façade Fenestration:
All façade fenestration shall be designed to crack but fragments shall enter the occupied space and land on the floor no further than 10 feet (3 m) from the façade in response to the calculated peak pressures and impulses resulting from the design level vehicle threat (W2) located at the stand-off distance, but no greater than GP2.
- B. Glass: Fenestration shall be constructed using debris mitigating materials such as laminated glass.
- C. Glazing: The glass shall be restrained within the mullions with a sufficient bite or structural silicone adhesive to allow it to develop its post-damage capacity.
- D. Mullions: The mullions shall be designed to accept the design level pressures while sustaining deformations no greater than L/30.
- E. Curtainwall: Curtainwall framing members shall span from slab to slab and shall not be attached directly to gravity load bearing elements (such as columns and shear walls) unless an advanced analysis of the load bearing element demonstrates it can accept the maximum forces of the members framing into it without compromising its load bearing capacity.
- F. Façade fenestration shall be upgraded to meet the requirements of this section. A mechanically anchored or wet glazed anti-shatter film may be used to satisfy the requirements of this section. The choice of film and the performance of the upgraded system shall be demonstrated using U.S. Government developed glass fragment hazard software. The means of attachment shall be based on the site specific features of the glass façade.

1.01.31 SECURITY DESIGN CRITERIA: SHATTER-RESISTANT WINDOWS (BUILDING SHELL) (NOV 2005)

In Government-occupied space, window systems shall be certified by a licensed professional engineer as conforming to a minimum glazing performance condition of "3B" for a high protection level and a low hazard level. Window systems shall be certified as prescribed by WINGARD 4.1 or later or WINLAC 4.3 software to have satisfied the specified performance condition using the test methods provided in the *US General Services Administration Standard Test Method for Glazing and Window Systems Subject to Dynamic Overpressure Loadings* or F1642-04 *Standard Test Method for Glazing and Glazing Systems Subject to Airblast Loadings*.

1.01.32 SECURITY DESIGN CRITERIA: HVAC (BUILDING SHELL) (NOV 2005)

Lobbies, mailrooms, and loading docks shall not share a return-air system with the remaining areas of the building. The Lessor shall provide lobby, mailroom, and loading dock ventilation systems' outside air intakes and exhausts with low leakage, fast acting, isolation dampers that can be closed to isolate their systems. Dedicated HVAC shall be required for mailrooms only when the Government specifically requires a centrally operated mailroom. On buildings of more than four stories, air intakes shall be located on the fourth floor or higher. On buildings of three stories or less, air intakes shall be located on the roof or as high as practical. Locating intakes high on a wall is preferred over a roof location.

1.01.33 SECURITY DESIGN CRITERIA: DESIGN AND ENGINEERING DOCUMENTS (NOV 2005)

The Government will review all design and engineering documents, including structural engineering calculations during design development and will be able to provide input prior to completing design.