

ANSWERS TO RFIs PROJECT #540-18-003S

RFI #1 Will room LAB 3321B be completed during the shutdown of OR-4 3321? **Yes, along with Room 3321A and 3329B.**

RFI #2 Will rooms SUB-STERILE 3319B and ENDO 3319A be completed during the shutdown of OR-3 3319? **No, only 3319A will be closed along with OR-3_3319.**

RFI #3 Will room LAB 3316B be completed during the shutdown of OR-1 3316? **No, 3316B will be closed along with OR-2_3317**

RFI #4 The drawing references installing SS Base and Wall Cabinets. Please provide an elevation or some information indicating configuration of the new cabinets. Should they include doors, drawers, shelves, etc.? **Base cabinets should have doors and no shelves. Wall cabinet should have doors with safety glass and two shelves.**

RFI #5 Can vinyl flooring be quoted in place of resinous flooring? **No, vinyl flooring cannot be quoted in lieu of Resinous Flooring in the Operating Rooms and attached ante rooms.**