



## Addendum #01

ISSUE DATE: 2.15.18

PROJECT: Modernize SPS Elevators SE-3 & SE-4  
Proj. #541-17-507  
Department of Veterans Affairs Medical Center – Wade Park  
Cleveland, Ohio

TO: Mr. Adam Miller

The following February 15, 2018 **Addendum #01** is made to supplement the original bid specifications and drawings prepared by Kaczmar architects incorporated dated 05.19.17, for the **Modernize SPS Elevators SE-3 & SE-4 Project**.

The intent of the issuance of **Addendum #01** is to more clearly identify, amend, clarify and/or provide additional information. The sections and/or paragraphs listed below supersede the original publication and any previously issued addenda in their entirety:

### Specifications

1. **Section 14 25 00 – Hydraulic Elevator Modernization**
  - a. Subsection 2.01(B) – Contract Speed modified to indicate “Retain Existing.” Speed will not be increased to 125 fpm.

END OF ADDENDUM 01

Issued By:

**KACZMAR ARCHITECTS INCORPORATED**

David A. Kaplan

File: K:\VA CLEVELAND\ELEVATOR MODERNIZATION PROJECT\DOCUMENTS\18-0215 Modernize SPS Elevators SE3 SE4 - Addendum 01.docx