

# Overton Brooks VAMC

## Infection Prevention & Control Construction Risk Assessment (ICRA)

**Project:** BE1 667-18-116 **Preliminary Assessment\* by:** Vickie L. Moore **Date:** 1/26/2018

**FINAL ICRA** Determined and Processed by: \_\_\_\_\_ **Final Date:** \_\_\_\_\_

**STEP ONE:** CIRCLE the Type of Construction Project based on scope and expected activity (Type A-D)

<b>TYPE A</b>	<b>Inspection and Non-Invasive Activities.</b> Includes, but is not limited to: <ul style="list-style-type: none"> <li>removal of ceiling tiles for visual inspection only, e.g., limited to 1 tile per 50 square feet</li> <li>painting (but not sanding)</li> <li>wallcovering, electrical trim work, minor plumbing, activities which do not generate dust or require cutting of walls or access to ceilings other than for visual inspection.</li> </ul>
<b>TYPE B</b>	<b>Small scale, short duration activities which create minimal dust</b> Includes, but is not limited to: <ul style="list-style-type: none"> <li>installation of telephone and computer cabling</li> <li>access to chase spaces</li> <li>cutting of walls or ceiling where dust migration can be controlled.</li> </ul>
<b>TYPE C</b>	<b>Work generates a moderate/high level of dust or requires demolition/removal of any fixed building components or assemblies</b> Includes, but is not limited to: <ul style="list-style-type: none"> <li>sanding of walls for painting or wall covering</li> <li>removal of floorcoverings, ceiling tiles and casework</li> <li>new wall construction</li> <li>minor duct work or electrical work above ceilings</li> <li>major cabling activities</li> <li>any activity which cannot be completed within a single work shift.</li> </ul>
<b>TYPE D</b>	<b>Major demolition and construction projects</b> Includes, but is not limited to: <ul style="list-style-type: none"> <li>activities which require consecutive work shifts</li> <li>requires heavy demolition, removal of a complete cabling system, or excavation</li> <li>new construction.</li> </ul>

**STEP TWO:** CIRCLE the affected Patient Risk Groups. If more than one risk group will be affected, select the higher risk group.

Low Risk	Medium Risk	High Risk	Highest Risk
<ul style="list-style-type: none"> <li>Office areas</li> <li>Kitchen storage area</li> <li>Public access, hallways, elevator Lobby</li> <li>Non-clinical vacated engineering space</li> </ul>	<ul style="list-style-type: none"> <li>Cardiology</li> <li>Echocardiography</li> <li>Endoscopy</li> <li>Nuclear Medicine</li> <li>Physical Therapy</li> <li>Radiology/MRI</li> <li>Respiratory Therapy</li> <li>Kitchen – food preparation area</li> </ul>	<ul style="list-style-type: none"> <li>Step Down Unit</li> <li>Emergency Room</li> <li>Laboratories (specimen)</li> <li>Medical Units</li> <li>Outpatient Surgery</li> <li>Pharmacy</li> <li>Post Anesthesia Care Unit</li> <li>Surgical Units</li> <li>Minor Procedure Rooms</li> <li>Sterile Supply storage/distribution</li> </ul>	<ul style="list-style-type: none"> <li>Immunocompromised patient care areas</li> <li>Cardiac Cath Lab</li> <li>Sterile Processing Service <ul style="list-style-type: none"> <li>Preparation Area</li> <li>Decontamination Area</li> </ul> </li> <li>Intensive Care Unit</li> <li>Negative pressure isolation rooms</li> <li>Oncology</li> <li>Operating rooms</li> </ul>

**STEP THREE:** Using the IC Matrix CIRCLE the Class of Precautions as determined by Construction Type and Patient Risk

		Construction Project Type			
Patient Risk Group		TYPE A	TYPE B	TYPE C	TYPE D
IC Matrix	LOW Risk Group	I	II	II	III/IV
	MEDIUM Risk Group	I	II	III	IV
	HIGH Risk Group	I	II	III/IV	IV
	HIGHEST Risk Group	II	III/IV	III/IV	IV

Preliminary ICRA Approved

Final ICRA Approved

1/26/2018

**X** Vickie L. Moore

Vickie L. Moore MA, CIC, VHA-CM  
Infection Prevention Program Manager  
Signed by: VICKIE L. MOORE 193380

**X**

Vickie L. Moore MA, CIC, VHA-CM  
Infection Prevention Program Manager

\*A preliminary ICRA is required for contracting purposes only; do not post during construction. The FINAL ICRA must be posted at the construction site.