

three inches = one foot  
one and one-half inch = one foot  
one inch = one foot  
three-quarters inch = one foot  
one-half inch = one foot  
three-eighths inch = one foot  
one-quarter inch = one foot  
one-eighth inch = one foot

GENERAL NOTES

- A. WORK IN THE CONTAINED ROOM SHALL BE AT A GREATER DURATION THAN OVERNIGHT WORK.
- B. WORK IN THE OPEN WAITING AREA WILL BE PERFORMED IN AFTER HOURS.

INFECTION AND DUST CONTROL PLAN LEGEND

- EXISTING PARTITION TO REMAIN  
EXISTING PARTITION TO BE REMOVED  
EXISTING DOOR & FRAME TO REMAIN  
EXISTING DOOR, FRAME & PARTITION TO BE REMOVED  
EXISTING DOOR & FRAME TO BE REMOVED
- LIMITS OF DISTURBANCE AND CONSTRUCTION  
PROVIDE TEMPORARY INFECTION CONTROL / DUST CONTROL BARRIERS AT THIS LOCATION. REMOVE AFTER CONSTRUCTION IS COMPLETED.
- DUST MAT (2'-0" X 3'-0")  
AREA NOT IN CONTRACT

GENERAL INFECTION CONTROL PLAN NOTES


- FOR THE PURPOSE OF THE RENOVATION, THE CONSTRUCTION WORK IS CONSIDERED LOW RISK. THE DUST CONTROL PLAN SHALL BE DISTRIBUTED AND REVIEWED BY ALL CONTRACTORS PERFORMING WORK ON THIS CONSTRUCTION PROJECT.
- A. EXTERNAL DEMOLITION AND CONSTRUCTION ACTIVITIES
1. DETERMINE IF THE IMPACTED AREAS OF THE FACILITY CAN OPERATE TEMPORARILY ON RECIRCULATED AIR; IF FEASIBLE SEAL OFF ADJACENT AIR INTAKES.
  2. IF THIS IS NOT POSSIBLE OR PRACTICAL, CHECK THE LOW-EFFICIENCY FILTER BANKS FREQUENTLY AND REPLACE AS NEEDED TO AVOID BUILDUP OF PARTICULATE.
  3. SEAL WINDOWS AND REDUCE WHEREVER POSSIBLE OTHER SOURCES OF OUTSIDE AIR INTRUSION (OPEN DOORS IN STAIRWELLS AND CORRIDORS) ESPECIALLY IN PROTECTIVE ENVIRONMENT (PE) AREAS.
- B. INTERNAL DEMOLITION AND CONSTRUCTION ACTIVITIES DUST AND DEBRIS CONTROL
1. **BARRIER SYSTEMS:** THE AREA SHOULD BE ISOLATED, AS THE PROJECT REQUIRES. SMALL, SHORT DURATION PROJECTS GENERATING MINIMAL DUST MAY USE FIRE-RATED PLASTIC SHEETING, BUT SHOULD BE SEALED AT FULL CEILING HEIGHT WITH AT LEAST 2'-FOOT OVERLAPPING FLAPS FOR ACCESS TO ENTRY. PROJECTS THAT PRODUCE MODERATE TO HIGH LEVELS OF DUST REQUIRE RIGID, DUST-PROOF, AND FIRE-RATED BARRIER WALLS (E.G. DRYWALL) WITH CAULKED SEAMS FOR A TIGHT SEAL EXTENDING FLOOR TO CEILING. SEAL OFF AND BLOCK RETURN AIR VENTS IF RIGID BARRIERS ARE USED FOR CONTAINMENT. LARGE DUSTY PROJECTS NEED AN ENTRY VESTIBULE FOR CLOTHING CHANGES AND TOOL STORAGE AND TIGHT SEALS SHOULD BE MAINTAINED AT THE FULL PERIMETER OF WALLS AND WALL PENETRATIONS. AN INTERIM PLASTIC DUST BARRIER (MINIMUM 4-MIL) MAY BE REQUIRED TO PROTECT THE AREA WHILE THE RIGID IMPERVIOUS BARRIER IS BEING CONSTRUCTED. ANY DUST SHALL BE IMMEDIATELY CLEANED IF TRACKED OUTSIDE OF THE CONSTRUCTION BARRIER. UPON COMPLETION OF THE CONSTRUCTION PROJECT DUST BARRIERS SHALL BE REMOVED CAREFULLY TO MINIMIZE SPREADING OF DUST AND THE CONTRACTOR SHALL HAVE TEMPORARY DUST PROTECTION IN PLACE BEFORE REMOVAL OF A PERMANENT BARRIER. CONTRACTOR PERSONNEL SHALL MONITOR AND PERFORM BARRIER MAINTENANCE AND BE EDUCATED TO NOTICE SIMPLE CLUES SUCH AS ACCUMULATIONS OF VISIBLE DUST EVIDENCED BY FOOTPRINTS, OPENED DOORS/WINDOWS EVIDENCED BY PRESENCE OF INSECTS AND FLIES, WET CEILING TILES, ETC.
  2. **TRAFFIC CONTROL:** DESIGNATED ENTRY AND EXIT PROCEDURES SHALL BE DEFINED. EGRESS PATHS SHOULD BE FREE OF DEBRIS; DESIGNATED ELEVATORS SHOULD BE USED DURING SCHEDULED TIMES; AND ONLY AUTHORIZED PERSONNEL SHOULD BE ALLOWED TO ENTER THE CONSTRUCTION ZONE. SIGNAGE SHOULD DIRECT PEDESTRIAN TRAFFIC AWAY FROM THE CONSTRUCTION AREA AND MATERIALS.
  3. **DEMOLITION DEBRIS:** DEBRIS SHOULD BE REMOVED IN CARTS WITH TIGHTLY FITTED COVERS, USING DESIGNATED TRAFFIC ROUTES. EFFORTS SHOULD BE MADE TO MINIMIZE USE OF ELEVATORS WITH AN EMPHASIS ON TRANSPORT DURING THE LOWEST PERIOD OF ACTIVITY. DEBRIS SHOULD BE REMOVED DAILY AND AT TIMES SPECIFIED BY THE VAMC. IF CHUTES ARE USED TO DIRECT DEBRIS OUTSIDE, HIGH EFFICIENCY PARTICULATE AIR (HEPA) FILTERED NEGATIVE AIR MACHINES SHOULD BE USED, AND THE CHUTE OPENING SHOULD BE SEALED WHEN NOT IN USE. FILTERS SHOULD BE BAGGED AND SEALED BEFORE BEING TRANSPORTED OUT OF THE CONSTRUCTION AREA. THE CONTRACTOR SHALL NOT HAUL DEBRIS THROUGH PATIENT-CARE AREAS WITHOUT PRIOR APPROVAL OF THE VAMC.
  4. **EXTERIOR WINDOWS:** WINDOWS SHOULD BE SEALED TO MINIMIZE INFILTRATION FROM ANY ADJACENT EXCAVATION DEBRIS.
- C. VENTILATION AND ENVIRONMENTAL CONTROLS
1. **AIR SYSTEM FLOW:** DETERMINE WHETHER THE CONSTRUCTION AREA USES FRESH/OUTSIDE OR RECIRCULATED AIR; FILTERS SHOULD BE ADDED OR RETURN VENTS COVERED AS NEEDED WITH FILTER MATERIAL OR PLASTIC. AIR MUST FLOW FROM CLEAN TO DIRTY AREAS.
  2. **NEGATIVE AIR PRESSURE:** THE AIR WITHIN THE CONSTRUCTION AREA MUST BE NEGATIVE WITH RESPECT TO SURROUNDING AREAS AND WITH NO DISRUPTION OF AIR SYSTEMS OF ADJACENT AREAS. USE OF THE NEGATIVE AIR PRESSURE SYSTEM WITHIN THE ENCLOSURE TO REMOVE DUST SHOULD PASS AIR THROUGH AN INDUSTRIAL GRADE, PORTABLE HEPA FILTER CAPABLE OF FILTRATION RATES OF 300-800 CUBIC FEET PER MINUTE (FT3/MIN), OR EXHAUST AIR DIRECTLY TO THE OUTSIDE IF APPROVED BY VAMC.
  3. **ADJACENT AREAS:** THE STATUS OF SEALED PENETRATIONS AND INTACT CEILING SHOULD BE VERIFIED DAILY.
  4. **AIR EXCHANGE RATES AND PRESSURE RELATIONSHIPS:** VAMC AND CONTRACTOR WILL VERIFY AND MAINTAIN PROPER RATES IN CRITICAL AREAS NEAR CONSTRUCTION ACTIVITY AND ENSURE AIR IS NOT BEING RE-CIRCULATED WITHOUT FILTRATION FROM THE CONSTRUCTION AREA ELSEWHERE. VAMC WILL MAKE DETERMINATION ON PROVIDING FOR THE ACCOUNTABILITY AND FREQUENCY OF TESTING AIR PRESSURE THROUGHOUT THE PROJECT.
- D. CONTAMINATION OF PATIENT ROOMS, SUPPLIES, EQUIPMENT AND RELATED AREAS
1. **WORKSITE CLOTHING:** CONTRACTOR PERSONNEL CLOTHING SHOULD BE FREE OF LOOSE SOIL AND DEBRIS BEFORE LEAVING THE CONSTRUCTION AREA. IF PROTECTIVE APPAREL IS NOT WORN (E.G., COVERS, FOOTWEAR AND HEADGEAR) A HEPA-FILTERED VACUUM SHOULD BE USED TO REMOVE DUST FROM CLOTHING BEFORE LEAVING THE BARRICADE. IF PROTECTIVE APPAREL IS UTILIZED THE CONTRACTOR SHALL CONSTRUCT A SPACE OR ANTEROOM FOR CHANGING CLOTHING AND STORING EQUIPMENT (DESIGNATED AREA). ALL EQUIPMENT, TOOLS, TOOL CARTS, MATERIALS, ETC. TRANSPORTED THROUGH OCCUPIED AREAS SHALL BE MADE FREE FROM DUST AND MOISTURE BY VACUUMING AND WET WIPING BEFORE THEIR REMOVAL FROM THE CONSTRUCTION ZONE OR WORK AREA.
  2. **CONTRACTOR CLEANING:** THE CONSTRUCTION ZONE SHOULD BE MAINTAINED IN A CLEAN MANNER BY CONTRACTORS AND SWEEP OR HEPA-VACUUMED DAILY OR MORE FREQUENTLY AS NEEDED TO MINIMIZE DUST. ADJACENT AREAS THAT MAY BE IMPACTED BY THE CONSTRUCTION SHOULD BE DAMP MOPPED DAILY OR MORE FREQUENTLY AS NEEDED. WALK-OFF MATS WITH TACKY OR ADHESIVE SURFACES SHOULD BE UTILIZED TO MINIMIZE TRACKING OF HEAVY DIRT AND DUST FROM CONSTRUCTION AREAS.

F1 FIRST FLOOR INFECTION AND DUST CONTROL PLAN  
1/8" = 1'-0"

VA WESTERN NEW YORK HEALTHCARE SYSTEM  
3495 BAILEY AVENUE  
BUFFALO, NEW YORK 14215

**paradigm**  
Architecture | Engineering | Design-Build  
200 Envoy Circle, Suite 201 Louisville, KY 40299  
www.paradigmusa.com

Architect



stamp

CARDIOLOGY MANAGER

DATE

ENGINEERING MANAGER

DATE

INFECTION CONTROL

DATE

CARELINE MANAGER

DATE

SAFETY OFFICER

DATE

CHIEF OF STAFF

DATE

Drawing Title

FIRST FLOOR INFECTION AND  
DUST CONTROL PLAN

MEDICAL CENTER DIRECTOR

DATE

ASSOCIATE MEDICAL CENTER DIRECTOR

DATE

Project Title

BUFFALO GU AHU

Building Number

1

Checked

Drawn

Location

V.A.M.C. BUFFALO, NEW YORK

Date

09-07-2017

Station No.

528

17-S06-GH01

FULLY SPRINKLERED  
BID DOCUMENTS (PART B)

