




three inches = one foot
 one and one-half inch = one foot
 one inch = one foot
 three-quarters inch = one foot
 one-half inch = one foot
 three-eighths inch = one foot
 one-quarter inch = one foot
 one-eighth inch = one foot

KEY NOTES

1. REFER TO MH402 FOR ENLARGED PLAN OF THIS AREA.
2. INSTALL NEW STEAM REHEAT DUCT COIL AND APPROPRIATE DUCT/TRANSITIONS TO COMPLETE INSTALLATION.
3. CONNECT NEW SUPPLY DUCTWORK TO EXISTING AT THIS LOCATION.
4. INSTALL NEW RUNOUT TO NEW AIR DEVICE AT THIS LOCATION.
5. NEW SPACE HUMIDITY SENSOR; REFER TO MH502 FOR SEQUENCE.
6. INSTALL NEW 2" INSULATED COVER OVER EXISTING LOUVER.
7. LOCATION OF NEW DDC CONTROL PANEL.
8. LOCATION OF NEW DDC TEMPERATURE SENSOR. COORDINATE WITH COR; REFER TO MH502 FOR SEQUENCE.

NOTES

- A. REFER TO DWG. M-001 FOR MECHANICAL ABBREVIATIONS, SYMBOLS, AND GENERAL NOTES RELATED TO THIS SHEET.
- B. ALL EXISTING PIPING, DUCTWORK, SPRINKLERS, CONDUIT, LIGHTING OR OTHER CONSTRUCTION SHALL BE RELOCATED AS REQUIRED FOR ALL DEMOLITION AND INSTALLATION WORK.
- C. REFER TO SHEET MD102 FOR MECHANICAL HVAC AND PIPING PLAN, EXISTING CONDITIONS AND DEMOLITION.
- D. REFER TO SHEET MP102 FOR MECHANICAL PIPING PLAN, NEW WORK.




KEY PLAN - SECOND FLOOR
 NTS

FULLY SPRINKLERED
 BID DOCUMENTS
 FOR CONSTRUCTION

F1 FLOOR PLAN SCALE 1/4" = 1'-0"	
ISSUED FOR BID	9-7-2017
Revisions	Date

VA WESTERN NEW YORK HEALTHCARE SYSTEM
 3495 BAILEY AVENUE
 BUFFALO, NEW YORK 14215



MANAGER	DATE	ENGINEERING MANAGER	DATE
INFECTION CONTROL	DATE	MANAGER	DATE
SAFETY OFFICER	DATE	CHIEF OF STAFF	DATE

Drawing Title MECHANICAL HVAC PLAN NEW WORK SECOND FLOOR	
Project Title BUFFALO GU AHU	
MEDICAL CENTER DIRECTOR	DATE
ASSOCIATE MEDICAL CENTER DIRECTOR	DATE

Building Number	1	Checked	KLP	Drawn	JDM
Location	V.A.M.C. BUFFALO, NEW YORK				

09-07-2017
 Station No.
 528
17-s06-MH102

