



1. REFER TO SHEET E-0 FOR LEGEND, ABBREVIATIONS, GENERAL NOTES AND PANELBOARD LOCATIONS.
2. CONNECT UN-SWITCHED PHASE CONDUCTOR TO BATTERY CHARGING CIRCUIT OF ALL EMERGENCY FIXTURES.

- ① CRAWL SPACE FIXTURES SHALL BE MOUNTED 3'-0" AFF.
- ② ELECTRICAL/MECHANICAL ROOM FIXTURES SHALL BE MOUNTED 6'-10" AFF.
- ③ MOUNT SWITCH ON WALL IN SPACE MADE CLEAR BY REMOVAL OF ABANDONED MOTOR STARTER.

1 BASEMENT FLOOR PLAN - LIGHTING - NEW WORK
SCALE: 1/4" = 1'-0"

FINAL DOCUMENTS SUBMISSION
PDG 110105.07

[illegible]