



- GENERAL NOTES:**
1. REFER TO M-0 FOR MECHANICAL LEGEND, ABBREVIATIONS AND GENERAL NOTES.
- DRAWING NOTES:**
- 1 REMOVE EXISTING STEAM PIPING UP.
 - 2 REMOVE EXISTING AIR COOLED CHILLER AND ALL ASSOCIATED APPURTENANCES. EXISTING CONCRETE PAD TO REMAIN.
 - 3 REMOVE EXISTING 1/2" CH AND CHR UP.
 - 4 REMOVE EXISTING BASE MOUNTED PUMP, PIPING AND ALL ASSOCIATED APPURTENANCES.
 - 5 REMOVE EXISTING EXPANSION TANK AND ALL ASSOCIATED APPURTENANCES.
 - 6 EXISTING WATER HEATER TO REMAIN.
 - 7 REMOVE EXISTING 1 1/2" RELIEF VENT UP THROUGH ROOF.
 - 8 REMOVE EXISTING CONDENSATE PUMP VENT UP THROUGH ROOF.
 - 9 REMOVE EXISTING STEAM PIPING DOWN.
 - 10 REMOVE EXISTING FAN COIL UNIT, ALL ASSOCIATED PIPING AND APPURTENANCES.
 - 11 TO EXISTING CONDENSATE RISER.

ASBESTOS ABATEMENT NOTES:

- 1. ESTABLISH A TENT ENCLOSURE WITH TWO LAYERS OF 6-MIL POLYETHYLENE, HEPA EXHAUST AND ONE STAGE DECONTAMINATION FACILITY. CAREFULLY DEMOLISH PLASTER AND BLOCK WALL TO EXPOSE PIPE RISER. REMOVE PIPE INSULATION AND DEBRIS.
- 2. LOCATION OF A 1-STAGE DECONTAMINATION FACILITY.
- 3. LOCATION OF A 3-STAGE DECONTAMINATION FACILITY AND SHOWER.
- 4. HEPA EXHAUST POINT
- 5. SOURCE OF WATER FOR SHOWER AND ABATEMENT ACTIVITIES
- 6. ESTABLISH A TENT ENCLOSURE WITH TWO LAYERS OF 6 MIL POLYETHYLENE. REMOVE ACM PIPE INSULATION AND DEBRIS FROM END OF TUNNEL.

LOCATIONS AND QUANTITIES OF ASBESTOS MATERIALS

ROOM OR AREA	QUANTITY (Linear Feet)
ROOM 101	10
ROOM 102	10
ROOM 103	10
ROOM 104	10
ROOM 105	40
CORRIDOR BY BACK EXIT	10
ROOM 107 & ROOM 109	20
ROOM 108	20
CORRIDOR BY FRONT EXIT	10
BASEMENT AT STEAM TUNNEL	5

Additions:	Date:
Revisions:	

Consultants

BURDETTE KOEHLER MURPHY & ASSOCIATES, INC.

MECHANICAL / ELECTRICAL CONSULTING ENGINEERING
1423 CLARKVIEW ROAD, SUITE 500
BALTIMORE, MARYLAND 21209
410.323.0600 - FAX 410.377.2543

BUILDING COST CONSULTANTS

COST ESTIMATING
12917 - 30TH AVENUE
PLATTSMOUTH, NEBRASKA 68048
402.298.8260 - FAX 402.298.8290

1 SOURCE SAFETY AND AND HEALTH, INC.

ASBESTOS ABATEMENT
1401 SOUTH VILLAGE AVE., SUITE 130
EXTON, PENNSYLVANIA 19341
610.524.5525 - FAX 610.524.0565

Seal:

ARCHITECTURE PLANNING ENGINEERING

POLT DESIGN GROUP

1301 ENTERPRISE COURT, SUITE 103-C Bel Air, Maryland 21014
410.803.2141 fax 410.838.1603

WEB SITE: <http://www.polt-design.com>

Drawing Scale:	Drawing Title:
	BASEMENT & FIRST FLOOR PLAN ASBESTOS ABATEMENT
Drawing Start Date:	Approved: Associate Director for Operations:
Drawing Finish Date:	Approved: Chief, Facilities Engineer:
Drawing Approved:	Approved: Director, Medical Center:

Project Title:			Date:
REPLACE BUILDING 6 HVAC			07-09-2012
Building No:			Project No:
6	Checked:	Drawn:	460-12-204
	SMM	DMB	DRAWING NO:
Location: VAMHCS MEDICAL CENTER WILMINGTON, DELAWARE			G-2
			Dwg. 3 Of 21

DEPARTMENT OF VETERANS AFFAIRS