



NOTE: CONTRACTOR SHALL PROVIDE AND INSTALL ACCESSORIES REQUIRED FOR A COMPLETE AND OPERATIONAL SYSTEM PROVIDE BLANK COVERS AS REQUIRED

* CONTRACTOR SHALL CUSTOM ORDER BOXES OR FIELD PUNCH BOXES AS REQUIRED FOR CONDUIT SIZES AS INDICATED

DATA WIRING CONNECTION

NOT TO SCALE

ELECTRICAL ABBREVIATIONS SCHEDULE					
A	AMPERE	ED	EQUAL	MFR	MANUFACTURER
AC	ABOVE COUNTER	EWC	ELECTRICAL WATER COOLER	MH	METAL HALIDE
AE	ARCHITECT/ENGINEER	EWI	ELECTRICAL WATER HEATER	MIN	MINIMUM
AF	ABOVE FINISHED FLOOR	EXIST	EXISTING	MIS	MISCELLANEOUS
AFG	ABOVE FINISHED GRADE	EXT	EXTENSION	MO	MASONRY OPENING
AHU	AIR HANDLING UNIT	FA	FIRE ALARM	#	NUMBER
ALT	ALTERNATE	FAA	FIRE ALARM ANNUNCIATOR	N/C	NORMALLY CLOSED
AMP	AMPERE	FACP	FIRE ALARM CONTROL PANEL	NC	NORMALLY OPEN
APPROX	APPROXIMATELY	FC	FAN COIL	N/A	N/A
AWG	AMERICAN WIRE GAUGE	FDN	FOUNDATION	NO	NOMINAL
BLDG	BUILDING	FL	FINISH	NOT TO SCALE	WITHOUT
BLKG	BLOCKING	FL	FLUORESCENT	WP	WATERPROOF
BOT	BOTTOM	FT	FOOT	XFRMR	TRANSFORMER
C	CONDUIT	FT-C	FOOT FOOTCANDLE	YD	YARD
CB	CIRCUIT BREAKER	G OR EGC	GROUND	YR	YEAR
CL	CENTERLINE	GA	GAUGE		
CFM	CUBIC FEET PER MINUTE	GFCI OR GFI	GROUND FAULT CIRCUIT INTERRUPTER		
CUH	CABINET UNIT HEATER	GRC	GALVANIZED RIGID CONDUIT		
CLG	CEILING	HT	HEIGHT		
CMU	CONCRETE MASONRY UNIT	HORIZ	HORIZONTAL		
COL	COLUMN	HPS	HIGH PRESSURE SODIUM		
CONC	CONCRETE	HR	HOUR		
CONC BLK	CONCRETE BLOCK	ID	INSIDE DIAMETER		
CONSTR	CONSTRUCTION	IS	ISOLATED GROUND		
CONTR	CONTRACTOR	IMC	INTERMEDIATE METAL CONDUIT		
Cu	COPPER	INSUL	INSULATION		
CONTR	DIRECT CURRENT	INT	INTERIOR		
DC	DIAMETER	INFO	INFORMATION		
DEG	DEGREE	KCMIL	THOUSAND CIRCULAR MILLS		
DET	DETAIL	KVA	KILOVOLT-AMPERE		
DIM	DIMENSION	KWH	KILOWATT-HOUR		
DWG	DRAWING	KW	KILOWATT		
EC	ELECTRICAL CONTRACTOR	LX	LIGHT POLE		
EF	EXHAUST FAN	MAX	MAXIMUM		
ELEV	ELEVATION	MC	MECHANICAL CONTRACTOR		
EM	EMERGENCY	MCM	MOTOR CONTROL CENTER		
EMT	ELECTRICAL METALLIC TUBING	MCC	THOUSAND CIRCULAR MILLS		

GENERAL ELECTRICAL DEMOLITION NOTES	
REMOVE ALL EXPOSED RACEWAY AND WIRE THAT ARE NO LONGER TO BE USED.	
BLANK OFF OR REMOVE ALL ABANDONED JUNCTION AND OUTLET BOXES IN WALLS, FLOORS, AND CEILINGS THAT ARE TO REMAIN.	
REMOVE ALL ELECTRICAL OUTLETS, DEVICES, AND RACEWAYS FROM WALL THAT ARE TO BE REMOVED.	
ALL EXISTING EQUIPMENT THAT IS TO REMAIN IS INTENDED TO BE OPERATIONAL AT THE COMPLETION OF THE PROJECT. RE-CIRCUIT WHERE NECESSARY TO INSURE THIS CONTINUED OPERATION.	
OWNER SHALL HAVE FIRST RIGHT OF REFUSAL ON ALL EQUIPMENT THAT IS TO BE REMOVED.	
ALL EXISTING RECEPTACLES AND LIGHT SWITCHES THAT ARE TO REMAIN WITHIN A REMODELED AREA SHALL BE REPLACED WITH NEW DEVICES AND COVER PLATES.	
THE EXISTING EQUIPMENT SHOWN ON THE DRAWINGS IS BELIEVED TO BE A REASONABLE INDICATION OF THE EXISTING LAYOUT. EXACT QUANTITY AND LOCATION SHALL BE FIELD VERIFIED BY CONTRACTOR.	

MOUNTING HEIGHT SCHEDULE	
SWITCHES - 44" OR AS SPECIFIED ON DRAWINGS.	
RECEPTACLES OR CONVENIENCE OUTLETS - 16" OR AS SPECIFIED ON DRAWINGS.	
RECEPTACLES OR CONVENIENCE OUTLETS - 44" FOR MECHANICAL, ELECTRICAL, JANITOR, SHOP AREAS, GARAGE AREAS STORAGE ROOMS AND ELEVATOR EQUIPMENT OR AS SPECIFIED ON DRAWINGS.	
EXTERIOR WEATHER PROOF RECEPTACLES OR CONVENIENCE OUTLETS - 24" ABOVE GRADE OR AS SPECIFIED ON DRAWINGS.	
SAFETY SWITCHES - 54" OR AS SPECIFIED ON DRAWINGS.	
MOTOR CONTROLLERS, VSD, VFD - 54" O.R. AS SPECIFIED ON DRAWINGS.	

MOTOR STARTER SCHEDULE										
TAG	EQUIPMENT SERVED	LOCATION	EQUIPMENT DATA			STARTER DATA			REMARKS	
			HP	FLA	VOLTAGE	PH	TYPE	NEMA SIZE		ENCL.
MS-1	AHL-1	AUTOPSY 60	1.00	4.8	208	3	FVNR	0	4X SS	1, 2, 3, 4
MS-2	AHL-2	RM 55	1.00	2.1	480	3	FVNR	0	1	
			#N/A						#N/A	
REMARKS:										
1. HAND/OFF/AUTO SELECTOR SWITCH.										
2. RED RUN LIGHT.										
3. SOLID STATE OVERLOADS.										
4. PROVIDE INTERLOCKS.										

GENERAL ELECTRICAL NOTES

REFER TO ARCHITECTURAL PLANS FOR DIMENSIONS.

DIMENSIONS SHOWN ON OUTLET BOXES AND DEVICES SHALL BE TO THE BOTTOM OF THE BOX.

CONDUIT SHOWN TO LIGHT FIXTURES IS SHOWN TO INDICATE SWITCHING AND DOES NOT REPRESENT THE QUANTITY OR EXACT LOCATION OF WIRING AND/OR CONDUIT.

COORDINATE LOCATION OF LIGHT FIXTURES IN AREAS OF MECHANICAL DUCTWORK AND PIPING WITH MECHANICAL CONTRACTOR. RELOCATE LIGHT FIXTURES, WIRING, AND CONDUIT IF NECESSARY AND AS DIRECTED BY THE ARCHITECT/ENGINEER.

VERIFY LOCATION OF ALL BACKBOXES IN LABORATORY EQUIPMENT AND BUILT-IN FURNITURE WITH EQUIPMENT SUPPLIER AND INSTALLER PRIOR TO ROUGH-IN.

PROVIDE AND INSTALL PLASTER RINGS FOR LIGHT FIXTURES WHERE REQUIRED BY CEILING CONSTRUCTION.

VERIFY HEIGHT AND LOCATION OF RECEPTACLES BEHIND ELECTRIC WATER COOLERS WITH THE MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.

THE ELECTRICAL LAYOUT DRAWINGS ARE DIAGRAMMATIC IN NATURE. REFER TO ENTIRE CONSTRUCTION DRAWING SET AND SPECIFICATIONS FOR GUIDANCE ON DIMENSIONS, CEILING HEIGHTS, DOOR SWINGS, ROOM FINISHES, STRUCTURAL DETAILS, LOCATIONS OF PIPING, DUCTWORK, STRUCTURAL MEMBERS, AND OTHER OBSTRUCTIONS. INSTALL THE ELECTRICAL SYSTEMS SO AS NOT TO INTERFERE WITH THE INSTALLATION OR FUNCTION OF ANY WORK BY ANOTHER DISCIPLINE.

ALL DIMENSIONS OF EXISTING DEVICES AND EQUIPMENT ARE APPROXIMATE. CONTRACTOR SHALL MAKE ALL NECESSARY FIELD MEASUREMENTS OF EXISTING STRUCTURES AND EQUIPMENT TO VERIFY DIMENSIONS SHOWN ON THE PLANS. ALL ADDED COSTS TO MODIFY NEW CONSTRUCTION DUE TO A LACK OF COORDINATION AND FIELD MEASUREMENTS SHALL BE BORNE BY THE CONTRACTOR.

PROVIDE ADDITIONAL SUPPORT FOR SWITCHES, STARTERS, RACEWAY, GROUNDING SYSTEMS, AND OTHER ELECTRICAL EQUIPMENT WHEREVER THE BUILDING CONSTRUCTION IS NOT SUITABLE FOR DIRECT MOUNTING.

ALL PENETRATIONS THROUGH FIRE RATED WALLS, FLOORS, AND CEILINGS SHALL BE SEALED WITH FIRE STOPPING MATERIAL EQUAL TO THOMAS AND BETTS LUL LISTED FLAME-SAFE FIRE STOP SYSTEM.

COORDINATE ALL EQUIPMENT WIRING WITH MFR'S REQUIREMENTS. CHANGES REQUIRED FROM THE USE OF PRODUCTS THAT ARE OTHER THAN THE BASIS OF DESIGN SHALL BE BORNE BY THE CONTRACTOR.

SIZING OF BRANCH CIRCUITS AND FEEDERS FOR EQUIPMENT IS BASED ON DESIGN LOADS. PRIOR TO INSTALLATION, CONFIRM EXACT LOADS WITH RELEASED SHOP DRAWINGS. BRING ANY DISCREPANCIES TO THE ATTENTION OF THE ENGINEER PRIOR TO ROUGH-IN.

BRANCH CIRCUITS SHALL BE WIRED WITH 3/4", 2#12, 1#12G, UNLESS NOTED OTHERWISE.

WHERE CONDUIT AND WIRING HAS NOT BEEN SHOWN ON THE DRAWINGS, THE ARRANGEMENT AND ROUTING OF LIGHTING AND RECEPTACLE BRANCH CIRCUITS SHALL BE AT THE DISCRETION OF CONTRACTOR IN ACCORDANCE WITH GENERALLY ACCEPTED GOOD PRACTICE, N.E.C. REQUIREMENTS, AND THE FOLLOWING LIMITATIONS:

EXCEPT WHERE NOTED OTHERWISE, SIZE BRANCH CIRCUIT CONDUCTORS WITHIN THE FOLLOWING MAXIMUM LENGTH LIMITS: (MEASURE TO THE CENTER OF THE LOAD FOR LIGHTING AND MOST REMOTE OUTLET FOR RECEPTACLE CIRCUITS)

CIRCUIT BREAKER	CIRCUIT LENGTH	CONDUCTOR SIZE
120V, 20 A	110 FEET	#12
	165 FEET	#10
	270 FEET	#8

PROVIDE #12 AWG MINIMUM FOR BRANCH CIRCUITS. PROVIDE ADDITIONAL DERATING PER N.E.C. TABLES 310.16 THROUGH 310.21 FOR ALL HOME RUNS WITH MORE THAN THREE CURRENT CARRYING CONDUCTORS IN A RACEWAY.

FOR EQUIPMENT THAT IS TO BE FURNISHED BY OTHERS AND WIRED BY THIS CONTRACTOR, REVIEW ALL SPECIFICATION SECTIONS, EQUIPMENT SCHEDULES, AND/OR DRAWING DETAILS THAT PERTAIN TO THIS EQUIPMENT AND INCLUDE ALL WIRING AND DEVICES REFERENCED. CONTRACTOR SHALL COORDINATE EXACT LOCATION OF THIS EQUIPMENT WITH EQUIPMENT INSTALLER PRIOR TO ROUGH-IN/INSTALLATION.

ALL CONDUIT, BOXES, AND WIRING DEVICES IN ALL AREAS SHALL BE INSTALLED IN CONCEALED SPACES OR RECESSED IN WALLS UNLESS IN MECHANICAL/ELECTRICAL EQUIPMENT ROOMS OR AS DIRECTED BY THE ARCHITECT/ENGINEER.

ALL HVAC CONTROL WIRING SHALL BE THE RESPONSIBILITY OF THE HVAC CONTRACTOR UNLESS NOTED OTHERWISE.

ELECTRICAL SYMBOLS SCHEDULE			
	RECESSED PANELBOARD		RELAY
	SURFACE MOUNTED PANELBOARD		HORIZONTALLY MOUNTED SURFACE RACEWAY
	MOTOR CONTROL CENTER: X - DENOTES EQUIPMENT TAG.		VERTICALLY MOUNTED SURFACE RACEWAY
	TRANSFORMER: XX - INDICATES TRANSFORMER TAG. REFER TO SCHEDULES AND/OR RISER DIAGRAM		MULTI-OUTLET ASSEMBLY WITH OUTLETS ON CENTER AS INDICATED ON THE DRAWING OR SPECIFICATIONS, MOUNTED 6" ABOVE COUNTER, UON.
	FUSIBLE DISCONNECT: XX - DENOTES MAX. AMPACITY OF DISCONNECT		CONCEALED FEED FOR SURFACE MOUNTED RACEWAY
	NON-FUSIBLE DISCONNECT: XX - DENOTES MAX. AMPACITY OF DISCONNECT		TEMPERATURE CONTROL PANEL: PROVIDED AND INSTALLED BY MECHANICAL CONTRACTOR, WIRED BY ELECTRICAL CONTRACTOR
	ENCLOSED CIRCUIT BREAKER. SIZE INDICATES BY "XXAF" DENOTES FRAME SIZE.		PHOTO CELL: AS NOTED ON DRAWINGS OR SPECIFICATIONS
	COMBINATION MOTOR STARTER AND FUSED DISCONNECT SWITCH: MS-XX DENOTES STARTER TAG. REFER TO MOTOR STARTER SCHEDULE.		TIME CLOCK: AS NOTED ON DRAWINGS OR SPECIFICATIONS.
	VARIABLE FREQUENCY DRIVE. PROVIDED BY MECHANICAL CONTRACTOR. INSTALLED BY ELECTRICAL CONTRACTOR.		CIRCUIT HOME RUN TO PANELBOARD
	COOPER INDUSTRIES MOTOR GUARD WITH 15A TOGGLE SWITCH AND EDISON BASE FUSE HOLDER. "XXAF" DENOTES THE OVERCURRENT PROTECTION FOR FUSEHOLDER		120-277 V. SINGLE POLE 20 AMP AC SWITCH
	RED MUSHROOM HEAD EMERGENCY POWER OFF BUTTON		120-277 V. DOUBLE POLE 20 AMP AC SWITCH
	LINE VOLTAGE THERMOSTAT: THERMOSTAT PROVIDED BY MECHANICAL CONTRACTOR, ROUGH-IN AND INSTALLATION BY ELECTRICAL CONTRACTOR.		120-277 V. THREE WAY 20 AMP AC SWITCH
	"ON/OFF" OR "UP/DOWN" PUSH BUTTON WITH PILOT LIGHT		120-277 V. FOUR WAY 20 AMP AC SWITCH
	CONTACTOR/ CONTACTOR CABINET. REFER TO SCHEDULES.		120 V. 60 HZ SINGLE POLE DIMMER SWITCH. 1500 WATT UON
	DIRECT CONNECTION TO EQUIPMENT		120-277 V. KEY OPERATED 20 AMP AC SWITCH
	MOTOR CONNECTION. "XX HP" INDICATES HORSEPOWER.		120-277 V. MOMENTARY CONTACT 20 AMP AC SWITCH
	JUNCTION BOX: "X" DENOTES LOCATION (CLNG = CEILING MOUNTED)		120-277 V. 20 AMP AC SWITCH WITH PILOT LIGHT
	CEILING FAN		SPECIAL PURPOSE SWITCH
	GROUNDING ROD. REFER TO SPECIFICATION FOR MIN. SIZE REQUIREMENTS		120 OR 277 MANUAL MOTOR STARTER SWITCH WITH PILOT LIGHT AND THERMAL OVERLOAD PROTECTION
	ELECTRIC HAND DRYER: MOUNTED AT 44" AFF. REFER TO SPECIFICATIONS		120-277 V. SINGLE POLE 20 AMP AC SWITCHES "Y" AND "Y" DENOTES OUTBOARD LAMPS TO BE ON SWITCH "Y" AND INBOARD LAMP(S) TO BE ON SWITCH "Y"
	120 V. 20 AMP SIMPLEX RECEPTACLE 16" A.F.F., UON		LIGHT FIXTURE. XX DENOTES FIXTURE TYPE. AB DENOTES SWITCHING
	120 V. 20 AMP DUPLEX RECEPTACLE 16" A.F.F., UON		EMERGENCY LIGHT FIXTURE. XX DENOTES FIXTURE TYPE. AB DENOTES SWITCHING.
	120V. 20 AMP DOUBLE DUPLEX RECEPTACLE. 16" A.A.F., UON		EMERGENCY NIGHT LIGHT FIXTURE. XX DENOTES FIXTURE TYPE. FIXTURE IS UNSWITCHED
	120 V. 20 AMP DUPLEX RECEPTACLE WITH GROUND FAULT CIRCUIT INTERRUPTER AT 16" A.F.F., UON		EXTERIOR WALL MOUNTED FIXTURE. XX DENOTES FIXTURE TYPE
	120 V. 20 AMP DUPLEX RECEPTACLE FOR ELECTRIC WATER COOLER. MOUNT PER EWC MFR'S REQUIREMENTS		EXTERIOR POLE MOUNTED FIXTURE. XX DENOTES FIXTURE TYPE
	120 V. 20 AMP DUPLEX WATER PROOF RECEPTACLE. 16" A.F.F., UON		WALL MOUNTED EMERGENCY LIGHT FIXTURE
	120 V. 20 AMP ISOLATED GROUND DUPLEX RECEPTACLE 16" A.F.F., UON. COLOR OF DUPLEX RECEPTACLE TO BE ORANGE WITH ISOLATED GROUND SYMBOL.		UNIVERSAL MOUNT EXIT LIGHT WITH DIRECTIONAL ARROW
	120 V. 20 AMP DUPLEX RECEPTACLE FOR MICROWAVE. 16" A.F.F., UON		UNIVERSAL MOUNT EXIT LIGHT WITH DIRECTIONAL ARROWS
	120 V. 20 AMP DUPLEX RECEPTACLE FOR REFRIGERATOR. 54" A.F.F., UON.		UNIVERSAL MOUNT EXIT LIGHT WITHOUT DIRECTIONAL ARROWS
	120 V. 20 AMP TAMPER PROOF DUPLEX RECEPTACLE. 16" A.F.F., UON		DOCK WITH EXTENSION ARM
	120 V. 20 AMP DUPLEX RECEPTACLE ON GENERATOR. 16" A.F.F., UON. COLOR OF DUPLEX TO BE RED.		CEILING MOUNTED OCCUPANCY SENSOR
	120 V. 20 AMP DUPLEX RECEPTACLE WITH SURGE PROTECTION. 16" A.F.F., UON. COLOR OF DUPLEX TO BE RED.		WALL MOUNTED OCCUPANCY SENSOR
	120 V. 20 AMP HORIZONTAL DUPLEX RECEPTACLE AT 6" ABOVE WORK SURFACE		NORMALLY CLOSED CONTACTOR
	SPECIAL PURPOSE RECEPTACLE: "XXAF" DENOTES AMPACITY OF RECEPTACLE		NORMALLY OPEN CONTACTOR
	120 V. 20 AMP SPLIT WIRE DUPLEX RECEPTACLE. 16" A.F.F., UON		WALL SLEEVE. "X" DENOTES DIAMETER
	TWIST LOCK RECEPTACLE		CENTER HUNG CABLE TRAY
	ELECTRIC CORD AND CABLE REEL WITH 25 FT CORD AND DOUBLE DUPLEX PORTABLE OUTLET BOX WITH STRAIN RELIEF		CEILING MOUNTED CLOCK
	FLOOR BOX: "X" DENOTES FLOOR BOX ID TAG. REFER TO SCHEDULES.		WALL MOUNTED CLOCK
	POKE THRU: "X" DENOTES FLOOR BOX ID TAG. REFER TO SCHEDULES.		DOUBLE FACE WALL MOUNTED CLOCK
	SECURITY CONTACT		
	MOTION DETECTOR		
	CCTV CAMERA		
	INTERCOM UNIT		
	SECURITY MAGNETIC LOCK		
	SECURITY CARD READER		
	SECURITY SYSTEM CONTROL PANEL		
	SECURITY KEYPAD		
	CEILING MOUNTED SPEAKER		
	CEILING MOUNTED PRO AUDIO SPEAKER		
	WALL MOUNTED SPEAKER		
	WALL MOUNTED PRO AUDIO SPEAKER		
	MASTER CONTROL CENTER		
	STRUCTURAL MOUNTED SPEAKER		
	VOLUME CONTROL		
	AUXILIARY JACK MOUNTED AT 16" A.F.F., UON		
	MICROPHONE JACK MOUNTED AT 16" A.F.F., UON		
	INTERCOM CALL SWITCH MOUNTED AT 48" A.F.F., UON		
	FIRE ALARM CEILING MOUNTED SMOKE DETECTOR		
	FIRE ALARM DUCT MOUNTED SMOKE DETECTOR. VERIFY QUANTITY WITH DUCT CONFIGURATION		
	FIRE ALARM MAGNETIC OR SENTRONIC DOOR HOLD OPEN		
	FIRE ALARM BELL		
	FIRE ALARM VISUAL, 80" A.F.F., UON. "WG" DENOTES WIRE GUARD		
	FIRE ALARM HORN, 80" A.F.F., UON		
	FIRE ALARM HORN/VISUAL, 80" A.F.F., UON		
	FIRE ALARM MANUAL PULL STATION, 44" A.F.F., UON		
	FIRE ALARM MANUAL PULL STATION AT 44" A.F.F. AND HORN/VISUAL AT 80" A.F.F., UON.		
	FIRE ALARM SMOKE DAMPER MOUNTED DETECTOR NEAR DAMPER. WITH SET OF NORMALLY OPEN CONTACTS		
	FIRE SUPPRESSION TAMPER FLOW MONITOR MODULE		
	FIRE ALARM CONTROL PANEL		
	FIRE ALARM ANNUNCIATOR PANEL		
	FIRE ALARM REMOTE TEST STATION		
	FIRE SUPPRESSION POST INDICATOR VALVE		
	FIRE ALARM CONTROL RELAY		
	DATA/VOICE OUTLET: MOUNTED AT 16" AFF. UON. X DENOTES NUMBER OF DATA DROPS AND Y DENOTED NUMBER OF VOICE DROPS.		
	VOICE OUTLET: MOUNTED AT 16" AFF. UON. X DENOTES NUMBER OF DROPS		
	ANALOG VOICE OUTLET: MOUNTED AT 48" AFF. UON. X DENOTES NUMBER OF DROPS		
	VOICE OUTLET: MOUNTED AT 48" AFF. UON. X DENOTES NUMBER OF DROPS		
	INPUT/OUTPUT JACK		
	AUDIO/VIDEO INPUT PLATE		
	TELEVISION INPUT PLATE		
	PROJECTOR MOUNTING PLATE		
	TEACHERS WORK STATION PLATE		

LINE TYPE SCHEDULE	
	UNDERGROUND COMMUNICATION FEED LINE TYPE AND WEIGHT
	UNDERGROUND FEED LINE TYPE AND WEIGHT
	NEW LINE WEIGHT
	EXISTING TO REMAIN LINE WEIGHT
	EXISTING TO BE DEMOLISHED LINE TYPE AND WEIGHT

CONSULTANTS:		ARCHITECT/ENGINEERS:		Drawing Title	Project Title	Project Number	Office of Construction and Facilities Management			
				ELECTRICAL INFORMATION PLAN	VA MORGUE VENTILATION	610A4-01-104				
				Approved Project Director	Location	Building Number	Department of Veterans Affairs			
					FORT WAYNE INDIANA	1				
					Date	Checked	E001			
					02/08/2012	CUB				
						Drawn	Dwg SHT8 of 10			
						CUB				
Revisions:				PRIMARY JOB # 09252						
Date										