



1. REINSTALL ALL CEILING MOUNT ITEMS CLOSE TO THE ORIGINAL LOCATION AND CENTER THEM ON THE CEILING TILE. U.N.O. PROVIDE REQUIRED SUPPORT FOR INSTALLATION.
2. RELOCATE SPRINKLER HEADS IN THE CENTER OF THE CEILING TILE. PROVIDE AND INSTALL NEW, VIKING - QUICK RESPONSE SPRINKLER HEAD AS BASIS OF DESIGN, WITHIN THE SOW AREA.
3. CEILING HEIGHT TO BE 8'-0" A.F.F. U.N.O.
4. CENTER CEILING TILE IN CORRIDOR & WAITING AREAS PER NEW LAYOUT ON SHEET A-20B-AC AND A-20B-B. COORDINATE WITH C.O.R. FOR STARTING POINT AT EACH PHASE.

- ① INSTALL NEW SUSPENDED CEILING SYSTEM. SEE 090600 SCHEDULE FOR FINISHES AND 095100 ACOUSTICAL CEILINGS.
- ② PROVIDE AND INSTALL NEW CEILING EJ COVER. SEE SPEC. SECTION 079513 EXPANSION JOINT COVERS.
- ③ EXISTING TO REMAIN CEILIN GRID.
- ④ ALIGN WITH EXISTING CEILIN GRID.
- ⑤ INSTALL NEW BULKHEAD.

	2'x2' ACOUSTICAL CEILING TILE
	GYPSUM BOARD
	2'x2' LIGHT FIXTURE
	SUPPLY DIFFUSER
	RETURN/EXHAUST DIFFUSER
	RECESSED DOWN LIGHT
	CEILING HEIGHT
	CEILING CAMERAS
	SPEAKER
	SMOKE DETECTOR
	EXIT LIGHT
	FIRE ALARM SPEAKER
	PENDANT LIGHT
	SPRINKLER HEAD
	DEPARTMENT/FIRE FINDING SIGNAGE
	WIRELESS ROUTER

VA FORM 08-6231