U.S. GOVERNMENT PRINTING OFFICE : 1973 O - 491-443

VA FORM 08-6231, FEB 1973

RETURN TO PLAN LIBRARY

FILE FOLDER NO. 2A

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19

THREE INCHES EQUALS ONE FOOT
ONE AND ONE HALF INCHES EQUALS ONE FOOT
ONE INCH EQUALS ONE FOOT
THREE QUARTER INCH EQUALS ONE FOOT
ONE HALF INCH EQUALS ONE FOOT
THREE EIGHTH INCH EQUALS ONE FOOT
ONE QUARTER INCH EQUALS ONE FOOT
ONE EIGHTH INCH EQUALS ONE FOOT

LOCATION: VAH, GAINESVILLE, FLORIDA

VETERANS ADMINISTRATION

APPROVED, SERVICE DIRECTOR

573-008

DRAWING NUMBER: 1-P6
SHEET NUMBER: 70 OF 148
PROJECT NUMBER

STEVENS & WALTON ARCHITECTS, INC.
ORLANDO, FLORIDA 32805
AND
SHERLOCK, SMITH & ADAMS, INC.
ARCHITECTS & ENGINEERS
MONTGOMERY, ALABAMA 36111

DRAWN | CHECKED | DATE: SEPT. 8, 1975

BLDG. NO. | PROJECT TITLE: CLINICAL IMPROVEMENTS PHASE I

SHEET TITLE: PLUMBING- FIRST FLOOR PLAN- BLOCK 'B'

NO.	DATE	REVISIONS DESCRIPTION
1	6-30-76	"AS BUILT" DRAWINGS
2	1-31-77	ADD DOORS OPERATING SUITE
3	9-28-78	MODIFICATION OF X-RAY AREA PLUMBING

ARCH. 426

ALABAMA — SHERLOCK, SMITH & ADAMS, INC. — MONTGOMERY, ALA. — REGISTERED ARCHITECTS & ENGINEERS

REGISTERED PROFESSIONAL ENGINEER — No. 5167 — STATE OF FLORIDA

2-8-2-0468

NOTE: FOR NOTES & SYMBOLS, SEE DRAWING NO. 1P1

FIRST FLOOR PLAN - BLOCK 'B' - PLUMBING

SCALE: 1/8" = 1'-0"

DETAIL OF X-RD PROCESSOR DELETED

ADD A P-9TE & HELESSARY PLUMG IN SCRUB ROOM E.145 b

F.C.O. 43 FURNISH AND INSTALL A P-19 PLASTER SINK IN ROOM E-161 AS SHOWN ON SKETCH "PARTIAL FIRST FLOOR PLAN - BLOCK B" DATED 3 FEBRUARY 1977, LESS THE DRAINBOARD, ALL IN ACCORDANCE WITH YOUR PROPOSAL DATED MARCH 25, 1977.

PARTIAL FLOOR PLAN SCALE 1/8"=1'-0"

Sketch No. 3

BELOW FLOOR

B4.4" PIPE BSMT
91.4" BSMT
105'-0" 1st FL.
117'-10" 2nd FL.
7'-0"
13'-8"
12'-10"

CEILING MEDICAL GAS DISPENSING UNIT

NOT TO SCALE

SECTION "B-B"

MALE DISS CONNECTION
DISS CONNECTION FOR AIR, OXYGEN, VACUUM, NITROUS OXIDE
FEMALE
COVER PLATE
FINISHED CEILING LINE
6'-6" ABOVE FINISHED FLOOR
SECTION "A-A"
COLOR CODED HOSE
OUTLET BODY
VALVE BODY

FRONT

RUNNER CHANNEL
1/8" PLATE

5-OUTLET BOXES SHALL HAVE 1 OXYGEN 1 NITROUS OXIDE 1 AIR AND 2 VACUUM

ALARM PANEL - OX., A., VAC. 4 R20 W/ PUSH BUTTONS & LIGHTS

P.B.P.U. TYPE I (TYPICAL FOR 8, THIS ROOM). EACH P.B.P.U. REQUIRES 34' VAC., 12' A. & 12' OX.

CANOPY OVER LOADING DOCK

RUN EXPOSED BELOW CANOPY AS HIGH AS POSSIBLE

SEE ARCH FOR METAL GUTTER UNCLG SPRING IN TRANSFORMER ROOM

NOTE: SIZING TYP GAS PIPE FOR FOUR OPERATING ROOMS

NOTE 6

@ CLG. OF EQUIP ROOM

CONSULTATION

MATCH LINE

SLEEVE FOR SILVER RECOVERY TYPICAL FOR 3 PROCESSORS

ADD A P-9TE & HELESSARY PLUMG IN SCRUB ROOM E.145 b