



### ELECTRICAL SYMBOLS

- 120V/240V GFI/RCB, WALL MOUNTED 18" AFF.
- DUPLEX RECEPTACLE, MOUNTED 18" AFF. - NEMA 5-20R UNLESS OTHERWISE INDICATED.
- WIRING SYSTEM CONCEALED IN OR ABOVE CEILING OR IN WALL.
- SINGLE POLE SWITCH, MOUNTED 44" AFF.
- TWO SINGLE POLE SWITCHES IN A 2-GANG BOX, MOUNTED 44" AFF. TO COMPLY WITH ENERGY CODE. OTHER SWITCH INBOARD AND OUTBOARD LAMPS SEPARATELY OR STEP-DOWN BOTH LAMPS TO 30W.

7 ELECTRICAL RENOVATION PLAN  
SCALE: 3/16"=1'-0"



KEY PLAN BUILDING 5  
OFFICE SPACE RENOVATION

Revision	Date	RECOMMEND APPROVAL				Drawing Title ELEVATION RENOVATION PLAN	Project Title RENOVATE B5 OFFICES			Date 18 JULY 2012	Project No. 659-12-241		Department of Veterans Affairs
		REQUESTER	Date	CHIEF OF SERVICE	Date		CHIEF OF STAFF	Date	Building Number 5				
		ASSOC. DIR. PATIENT CARE SVC.	Date	ASSOC. DIR. for OPERATIONS	Date	Approved: Safety Manager/M&O Supervisor	Location W.G.(Bill) Hefner Medical Center 1601 Brenner Ave. Salisbury NC 28144						
		APPROVAL BY: MEDICAL CENTER DIRECTOR				Date	Approved: Chief of Facilities Management Svr.						