


- DRAWING NOTES:**
- 1 POST INDICATOR VALVE WITH SUPERVISORY SWITCH. SEE CIVIL DRAWINGS.
 - 2 LOADING DOCK AREA TO BE PROTECTED BY HORIZONTAL DRY SIDEWALL SPRINKLERS. INSTALL IN ACCORDANCE WITH MANUFACTURERS SPECIFICATIONS. SEE DETAIL 5 ON SHEET FX501 FOR MORE INFORMATION.
 - 3 LOCATION OF INSPECTOR'S TEST CONNECTION.
 - 4 WAREHOUSE WILL REPORTEDLY BE USED TO STORE COMPUTERS, MEDICAL SUPPLIES, AND LINENS ON NON-ENCAPSULATED PALLETS UP TO AND INCLUDING 12 FEET IN HEIGHT. THIS IS CONSISTENT WITH CLASS III COMMODITIES, AS DEFINED BY NFPA 13. DESIGN CRITERIA IS IN ACCORDANCE WITH NFPA 13 - TABLE 13.2.1 FOR MISCELLANEOUS STORAGE 12 FEET OR LESS.
 - 5 PHARMACY CACHE WILL REPORTEDLY BE USED TO STORE PHARMACEUTICALS INCLUDING BUT NOT LIMITED TO PLASTIC BOTTLES, GLASS BOTTLES, ETC. THESE COMMODITIES WILL BE STORED ON OPEN SHELVES UP TO AND INCLUDING 12 FEET IN HEIGHT. THIS IS CONSISTENT WITH CLASS IV COMMODITIES, AS DEFINED BY NFPA 13. DESIGN CRITERIA IN ACCORDANCE WITH NFPA 13 - TABLE 13.2.1 FOR MISCELLANEOUS STORAGE 12 FEET OR LESS.
 - 6 PROVIDE ADDITIONAL BRANCH LINE ALONG WAREHOUSE WALL TO SUPPLY DRY SIDEWALL SPRINKLERS IN LOADING DOCK. REFER TO DETAIL 5/FX501.
 - 7 REFER TO FX502.
 - 8 DOWN TO ROOMS BELOW.
 - 9 BOILER ROOM TO BE PROTECTED WITH HIGH TEMPERATURE SPRINKLERS.



WAREHOUSE MEZZANINE- SPRINKLER SYSTEM PLAN
SCALE: 3/32" = 1'-0"

WAREHOUSE - SPRINKLER SYSTEM PLAN
SCALE: 3/32" = 1'-0"

Revision Schedule	
Revision Number	Revision Date

CONSULTANTS:			
CIVIL / STRUCTURAL Simpkins & Costelli, Inc. 401 32 1/2 Street Gulfport, MS 39506 t: 228.864.6289 f: 228.864.2897	MECH / PLUMBING Atherton Consulting Engineers 1907 Pass Road, Suite G Biloxi, MS 39531 t: 601.362.8478 f: 601.981.0575	ELECTRICAL Watkins & O'Gwynn 4523 Office Park Drive Jackson, MS 39206 t: 601.982.3313 f: 601.982.7685	FIRE PROTECTION Koffel Associates, Inc. 6522 Meadow Ridge Road, Suite 101 Elkridge, MD 21075 t: 410.750.2246 f: 410.750.2588

CONSTRUCTION DOCUMENT SUBMISSION-

ARCHITECT:
ELLERBE BECKET
2380 McGee Street, Suite 200
Kansas City, MO 64108
816 561 4443
Ellerbe Becket, Inc.
Ellerbe Becket Architects and Engineers, Inc.
Ellerbe Becket Architects and Engineers
2008

Drawing Title: SPRINKLER SYSTEM - FLOOR 1
Approved: Project Director

Project Title: Construct New Warehouse
Location: BILOXI, MS
Date: 3/10/08
Checked: SSG
Drawn: PHZ

Project Number: 520-320
Building Number: 26
Drawing Number: FX101
Dwg. 103 of 105

FULLY SPRINKLERED

Office of Facilities Management
Department of Veterans Affairs