

one eighth inch = one foot
one quarter inch = one foot
three eighths inch = one foot
one half inch = one foot
three quarters inch = one foot
one inch = one foot
one and one half inches = one foot
two inches = one foot
three inches = one foot
four inches = one foot
six inches = one foot
eight inches = one foot
ten inches = one foot
twelve inches = one foot
one foot = one foot


| AHU SYSTEM I/O POINTS LIST | | SYSTEM OUTPUTS | | | | | | | | SYSTEM INPUTS | | | | | | | | GENERAL INSTRUCTIONS | | | | | | | | |
|-------------------------------|-----|----------------|--------------|----------|-----------------------|---------------|------------------|-----------------------|-----------------------|---------------|--------|-------|----------------------|--------|-------------------|-----------------|----------------------|----------------------|----------------------|---------------------|-------------------------|---------------------|---------------------------|----------------------------|----------------------|-----------------------------------|
| | | BINARY | | | | ANALOG | | | | BINARY | | | | ANALOG | | | | SOFTWARE RESPONSES | | | | | | | | |
| | | START / STOP | OPEN / CLOSE | ON / OFF | GENERAL BINARY OUTPUT | SPEED CONTROL | POSITION CONTROL | GENERAL ANALOG OUTPUT | GENERAL ANALOG OUTPUT | SWITCH | STATUS | ALARM | GENERAL BINARY INPUT | SENSOR | POSITION FEEDBACK | PERCENT LOADING | GENERAL ANALOG INPUT | UPPER LIMIT RESPONSE | LOWER LIMIT RESPONSE | SCHEDULED OPERATION | OPERATOR ACKNOWLEDGMENT | COLLECT TRENDS DATA | CALL TO FIRE ALARM SYSTEM | EMERGENCY POWER ACTIVATION | DEVICE COMMUNICATION | |
| SYSTEM COMPONENTS: | ID# | | | | | | | | | | | | | | | | | | | | | | | | | NOTES: |
| ZONE TEMPERATURE SENSOR | 01 | | | | | | | | | | | ● | | ● | | | | | | | | ● | | | | HIGH/LOW ALARM = S.P. +/- 5 DEG F |
| ZONE MOISTURE SENSOR | 02 | | | | | | | | | | | ● | | ● | | | | | | | | ● | | | | HIGH ALARM = 60% RH |
| SUPPLY AIR TEMPERATURE SENSOR | 03 | | | | | | | | | | | ● | | ● | | | | | | | | ● | | | | HIGH/LOW ALARM = S.P. +/- 3 DEG F |
| ZONE HHW CONTROL VALVE | 04 | | | | | | ● | | | | | | | | | | | | | | | ● | | | | - |
| ZONE AIRFLOW CONTROL DAMPER | 05 | | | | | | ● | | | | | | | | | | | | | | | ● | | | | - |
| ZONE AIRFLOW SENSOR | 06 | | | | | | | | | | | ● | | ● | | | | | | | | ● | | | | HIGH/LOW ALARM = S.P. +/- 20% |

ALL SETPOINTS SHALL BE ADJUSTABLE

1 CONSTANT VOLUME AIR TERMINAL UNIT CONTROLS

NTS

- General: The air terminal unit (ATU) shall be managed for automatic operations through its independent terminal level controller (TLC) which is integrated into the energy control center (ECC).
- System Airflow Control: The ATU system modulates its control damper to maintain the supply air (SA) flow rate setpoint. For constant volume zones, the max flow rate = min flow rate regardless of its occupancy or thermal loading conditions.
 - Increased Loading: If the SA flow rate has decreased to below its setpoint, the integral control damper shall increase its position accordingly to increase the SA flow rate to maintain the SA flow rate setpoint.
 - Decreased Loading: If the SA flow rate has increased to above its setpoint, the integral control damper shall decrease its position accordingly to decrease the SA flow rate to maintain the SA flow rate setpoint.
- Zone Temperature Control: The system's hydronic control valve modulates the heating hot water (HHW) flow through the reheat coil to maintain the zone temperature (ZT) setpoint.
 - Increased Loading: If the ZT has decreased to below its setpoint, the hydronic control valve shall increase its position accordingly to increase the temperature of the SA being provided to the zone to maintain the ZT setpoint.
 - Decreased Loading: If the ZT has increased to above its setpoint, the hydronic control valve shall decrease its position accordingly to decrease the temperature of the SA being provided to the zone to maintain the ZT setpoint.



| AHU SYSTEM I/O POINTS LIST | | SYSTEM OUTPUTS | | | | | | | | SYSTEM INPUTS | | | | | | | | GENERAL INSTRUCTIONS | | | | | | | | | | | | |
|--------------------------------|-----|----------------|--------------|----------|-----------------------|--------|---------------|------------------|-----------------------|-----------------------|--|--------|--------|--------|----------------------|--|--------|----------------------|-----------------|----------------------|--|----------------------|----------------------|---------------------|--------------------------|---------------------|---------------------------|----------------------------|----------------------|-----------------------------------|
| | | BINARY | | | | ANALOG | | | | BINARY | | | | ANALOG | | | | SOFTWARE RESPONSES | | | | | | | | | | | | |
| | | START / STOP | OPEN / CLOSE | ON / OFF | GENERAL BINARY OUTPUT | | SPEED CONTROL | POSITION CONTROL | GENERAL ANALOG OUTPUT | GENERAL ANALOG OUTPUT | | SWITCH | STATUS | ALARM | GENERAL BINARY INPUT | | SENSOR | POSITION FEEDBACK | PERCENT LOADING | GENERAL ANALOG INPUT | | UPPER LIMIT RESPONSE | LOWER LIMIT RESPONSE | SCHEDULED OPERATION | OPERATOR ACKNOWLEDGEMENT | COLLECT TRENDS DATA | CALL TO FIRE ALARM SYSTEM | EMERGENCY POWER ACTIVATION | DEVICE COMMUNICATION | |
| SYSTEM COMPONENTS: | ID# | | | | | | | | | | | | | | | | | | | | | | | | | | | | | NOTES: |
| STEAM CONTROL VALVE 1 | 01 | | | | | | | ● | | | | | | | | | | | | | | | | | | ● | | | | 1/3 STEAM FLOW CONTROL VALVE |
| STEAM CONTROL VALVE 2 | 02 | | | | | | | ● | | | | | | | | | | | | | | | | | | ● | | | | 2/3 STEAM FLOW CONTROL VALVE |
| STEAM CONTROL VALVE 1 | 03 | | | | | | | ● | | | | | | | | | | | | | | | | | | ● | | | | 1/3 STEAM FLOW CONTROL VALVE |
| STEAM CONTROL VALVE 2 | 04 | | | | | | | ● | | | | | | | | | | | | | | | | | | ● | | | | 2/3 STEAM FLOW CONTROL VALVE |
| HHW SUPPLY TEMPERATURE SENSOR | 05 | | | | | | | | | | | | ● | | | | ● | | | | | | | | | ● | | | | HIGH/LOW ALARM = S.P. +/- 5 DEG F |
| HHW RETURN TEMPERATURE SENSOR | 06 | | | | | | | | | | | | ● | | | | ● | | | | | | | | | ● | | | | MONITORING PURPOSES ONLY |
| PUMP 1 CONTROLLER (START/STOP) | 07 | ● | | | | | | | | | | | | | | | | | | | | | | | | ● | | | | - |
| PUMP 1 CONTROLLER (STATUS) | 08 | | | | | | | | | | | | ● | | | | | | | | | | | | | ● | | | | - |
| PUMP 2 CONTROLLER (START/STOP) | 09 | ● | | | | | | | | | | | | | | | | | | | | | | | | ● | | | | - |
| PUMP 2 CONTROLLER (STATUS) | 10 | | | | | | | | | | | | | ● | | | | | | | | | | | | ● | | | | - |
| DIFFERENTIAL PRESSURE SENSOR | 11 | | | | | | | | | | | | ● | | | | ● | | | | | | | | | ● | | | | HIGH/LOW ALARM = S.P. +/- 20% |
| LOOP BYPASS CONTROL VALVE | 12 | | | | | | | ● | | | | | | | | | | | | | | | | | | ● | | | | - |

ALL SETPOINTS SHALL BE ADJUSTABLE


2 HEATING HOT WATER DISTRIBUTION SYSTEM CONTROLS

NTS

- General: The heating hot water (HHW) system shall be managed for automatic operations through its independent terminal level controller (TLC) which is integrated into the energy control center (ECC).
- Loop Pressure Control: The HHW system is always enabled and operating to maintain a constant HHW flow distribution throughout the loop.
 - Increased Loading: If the differential pressure (DP) sensor has decreased to below its setpoint, the bypass control valve shall decrease its position accordingly to increase the HHW loop DP to maintain the DP setpoint.
 - Decreased Loading: If the DP sensor has increased to above its setpoint, the bypass control valve shall increase its position accordingly to decrease the HHW loop DP to maintain the DP setpoint.
- Loop Temperature Control: The system's steam control valves shall in sequence modulate steam into the heat exchanger to maintain the HHW supply temperature (HHWST) setpoint.

Each of the shell and tube heat exchangers include two control valves and a manual bypass valve to manage the steam flow for each HX independently. The 1/3 valve shall be sized for 1/3 of the total steam flow and the 2/3 valve shall be sized for 2/3 of the total steam flow.

 - Increased Loading: If the HHWST has decreased to below its setpoint, the 1/3 steam control valve increases its position accordingly to maintain the HHWST setpoint. If the HHWST setpoint cannot be achieved by the 1/3 valve alone, the 2/3 control valve shall increase its position accordingly to provide additional steam flow to maintain the HHWST setpoint.
- Decreased Loading: If the HHWST has increased to above its setpoint, the two steam control valve positions shall decrease in sequence to maintain the HHWST setpoint. The 2/3 valve shall be fully closed before the 1/3 valve modulates.
- Pump Failure Condition: If the command for a pump's operation is in conflict with its operational status for at least 5-minutes, the pump has failed. Deactivate the duty pump and activate the standby pump.



FINAL DESIGN
APPROVED FOR CONSTRUCTION

| | | | | | | | | | |
|------------|-------|--------------|--|--|--|---|-------------------------------|----------------------|---|
| Revisions: | Date: | CONSULTANTS: | ENGINEER-OF-RECORD MARK G. HERTZ FL P.E. NO. 53279 | ARCHITECT/ENGINEERS: AKEA INC. 3603 NW 98th Street, Suite B Gainesville, FL 32606 Phone: (352) 474-6124 Fax: (352) 553-4437 COA: FL #26693 AKEA Project No. 094-14 | Drawing Title MECHANICAL SYSTEMS CONTROLS | Project Title RENOVATE WARD 3C FOR CARDIOLOGY EQUIPMENT INSTALLATION | Project Number 573-CSI-102 | Building Number 1 | Office of Construction and Facilities Management |
| | | | | | Approved: Project Director | Location GAINESVILLE, FLORIDA | Drawing Number MI901 | 26 OF 62 | Department of Veterans Affairs |
| | | | | | | Date MARCH 9, 2018 | Checked MGH | Drawn MGH | |