

1 HVAC PIPING DEMOLITION

1/4" = 1'-0"

N

SHEET NOTES

1. EXISTING CONDITIONS INFORMATION HAS BEEN TAKEN FROM AS-BUILT DOCUMENTS AND LIMITED SURVEYS AND IS IN-PART UNVERIFIED. CONTRACTOR SHALL VERIFY EXISTING CONDITIONS PRIOR TO BEGINNING CONSTRUCTION DEMOLITION AND NEW WORK.

SHEET KEYNOTES

1 PROVIDE DEMOLITION TO APPROPRIATE ISOLATION VALVES SO AS TO MAINTAIN THE FUNCTIONALITY OF THE PIPING MAINS. PROVIDE END CAPS ON EACH CONNECTION.

2 REMOVE THREE-PIPE SYSTEM BRANCH PIPES BACK TO MAINS. CAP AT POINT OF CONNECTION TO MAINS.

3 EXISTING THREE-PIPE SYSTEM MAIN PIPING TO REMAIN.



FINAL DESIGN
APPROVED FOR CONSTRUCTION

Revisions:	Date

CONSULTANTS:

Mark G. Hertz

Digitally signed by Mark G. Hertz
Date: 2018.03.12 17:05:08 -04'00'

ENGINEER - OF - RECORD MARK G. HERTZ FL. P.E. NO. 53279

MARK G. HERTZ LICENSE No. 53279 STATE OF FLORIDA PROFESSIONAL ENGINEER

ARCHITECT/ENGINEERS:

AKEA INC.
3603 NW 98th Street, Suite B
Gainesville, FL 32606
Phone: (352) 474-6124
Fax: (352) 474-6324
COA: FL #26693
AKEA Project No. 094-14

Drawing Title: HVAC PIPING - DEMOLITION - BASE BID

Approved: Project Director

Project Title: RENOVATE WARD 3C FOR CARDIOLOGY EQUIPMENT INSTALLATION

Location: GAINESVILLE, FLORIDA

Date: MARCH 9, 2018 | Checked: MGH | Drawn: TJM

Project Number: 573-CSI-102

Building Number: 1

Drawing Number: MP100

28 OF 62

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231