



SBBL Architecture + Planning
1001 North Alvernon Way #105, Tucson, Arizona 85711-1019
t: 520.620.0255 f: 520.620.0535 e: sbbl@sbbl.biz

ADDENDUM No. ONE

PROJECT: Replace Various Roofs

PROJECT NO.: 678-12-103

DATE: August 1, 2012

The following Addendum shall be incorporated in the Contract Documents of the above project, and all requirements herein are fully a part of the Contract Documents. All Bidders are reminded to acknowledge receipt of all Addenda in the space provided on the Proposal Form.

A. GENERAL NOTES-

DRAWINGS

Sheet 2-AS001, Keynote 1, Revise to read:

“REMOVE BRICK PAVERS, SAND, B.U.R. & RIGID INSULATION AND MASTIC DOWN TO BARE CONCRETE AS REQUIRED BY MANUF. FOR NEW ROOF INSTALL. ALL BRICK PAVERS SHALL BE SALVAGED, PALLETIZED, WRAPPED IN PLASTIC AND DELIVERED ON SITE TO A LOCATION NEAR THE WATER TOWER AS DIRECTED BY THE VA.”

SEE ATTACHED SHEET 2-AS001.

Sheet 30-AS001, Keynote 1, Revise to read:

“REMOVE BRICK PAVERS, SAND, B.U.R. & RIGID INSULATION AND MASTIC DOWN TO BARE CONCRETE AS REQUIRED BY MANUF. FOR NEW ROOF INSTALL. ALL BRICK PAVERS SHALL BE SALVAGED, PALLETIZED, WRAPPED IN PLASTIC AND DELIVERED ON SITE TO A LOCATION NEAR THE WATER TOWER AS DIRECTED BY THE VA.”

SEE ATTACHED SHEET 30-AS001.

Sheet 30-AS001, Keynote 2, Revise to read:

“REMOVE EXISTING CONCRETE SIDEWALK, AND ROOF SYSTEM BELOW,
DOWN TO ORIGINAL CONCRETE ROOF DECK. (CONCRETE SIDEWALK IS
APPROXIMATELY 4” THICK.)
SEE ATTACHED SEHET AS001.

Sheet 57-AS001, Keynotes:

DELETE KEYNOTE #9.

SPECIFICATIONS

**SECTION 02 41 00, 3.1, B. REPLACE PAGE 3 OF SPECS WITH ATTACHED PAGE
3R1.**

cc: Douglas Trinder

Enclosures

END OF ADDENDUM NO. ONE