

NOTES:

1. WIRE FENCE SHALL BE A MINIMUM OF 32 INCHES IN HEIGHT AND SHALL HAVE A MINIMUM OF 6 WIRES WITH 12" STAY SPACING.
2. FILTER FABRIC SHALL BE A MINIMUM OF 36" IN WIDTH AND SHALL BE FASTENED ADEQUATELY TO THE WIRE WITH #9 WIRE STAPLES 1-1/2" LONG. FABRIC THAT DETERIORATES TO SUCH EXTENT THAT IT'S EFFECTIVENESS IS REDUCED SHALL BE REPLACED BY CONTRACTOR AT CONTRACTOR'S EXPENSE.
3. STEEL POSTS SHALL BE A MIN. OF 5' HEIGHT AND SHALL BE THE SELF FASTENER ANGLE STEEL TYPE.
4. WOOD POST'S SHALL BE A MIN. OF 6' IN HEIGHT AND 3" OR MORE IN DIAMETER. WIRE FABRIC SHALL BE FASTENED TO WOODEN POST WITH NOT LESS THAN #9 WIRE STAPLES 1-1/2 INCHES LONG.
5. CONTRACTOR SHALL REVIEW SILT FENCE WEEKLY AND AFTER EACH RAINFALL OCCURRENCE. ANY NECESSARY REPAIRS OR CLEAN-UP TO MAINTAIN THE EFFECTIVENESS OF THE DEVICE SHALL BE MADE IMMEDIATELY.
6. TEMPORARY MEASURE SHALL BE REMOVED BY THE CONTRACTOR ONCE STABILIZATION OR SUFFICIENT GROUND COVER IS ACHIEVED AS DIRECTED BY THE COTR.



SECTION A-A

SILT FENCE

SCALE — 1 / C-101



NOTES:

1. PROVIDE FULL DEPTH 3/8" PREMOLDED EXPANSION JOINT FILLER ALL AROUND AT ALL UTILITY POLES, METER BOXES, ETC.
2. PLACE FULL DEPTH THRU JOINTS W/1/2"x6" PREMOLDED EJF AT POINT OF TANGENCY AND AT MIN 25' INTERVALS.

CONCRETE SIDEWALK

NOT TO SCALE — 8 / C-101



ELEVATION



SECTION A / C-101

WHEELCHAIR RAMP

NTS — 9 / C-101



AGGREGATE FILTER IS TO BE PLACED AT EXISTING INLETS PRIOR TO BEGINNING SITE DEMOLITION.



CURB AND GUTTER

NOT TO SCALE — 5 / C-101



GRAVEL INLET PROTECTION

N.T.S. — 2 / C-101



CONCRETE CURB

NOT TO SCALE — 6 / C-101



NOTES:

1. PAVEMENT REPLACEMENT PER NORTH CAROLINA DOT STD. SPECS.
2. EXISTING ASPHALT SHALL BE REMOVED FOR A DISTANCE OF 1 FOOT TO BOTH SIDES OF THE TRENCH OPENING.

PAVEMENT REPLACEMENT DETAIL

NTS — 3 / C-101



LEGEND

B_C – OUTSIDE DIAMETER
H – BACKFILL COVER ABOVE TOP OF PIPE (3'-0" MINIMUM)
D – INSIDE DIAMETER

CLASS-D

PIPE BEDDING DETAIL

NTS — 7 / C-101

Revision	Date
REV-1 GENERAL NOTES ADDITION	1 AUG 12

REV-1 GENERAL NOTES ADDITION

RECOMMEND APPROVAL

REQUESTER	Date		
CHIEF OF SERVICE	Date	CHIEF OF STAFF	Date
ASSOC. DIR. PATIENT CARE SVC.	Date	ASSOC. DIR. for OPERATIONS	Date
APPROVAL BY: MEDICAL CENTER DIRECTOR			Date

Drawing Title: STANDARD DETAILS

Project Title: REPLACE DOMESTIC WATER PIPING-NORTH LOOP

Date: 29 JUNE 2012

Project No. 659-12-253

Approved: Safety Manager/M&O Supervisor

Building Number: CAMPUS | Checked | Drawn: BLF

Approved: Chief of Facilities Management Svr.

Location: W.G.(Bill) Hefner Medical Center, 1601 Brenner Ave., Salisbury NC 28144

DRAWING NO. C-101

DWG. 6 OF 8

Department of Veterans Affairs