

LIGHTING/CEILING NOTES:

1. PROVIDE ALL OCCUPANCY SENSORS AND ASSOCIATED WIRING AS INDICATED ON THE DRAWINGS.
2. ELECTRICAL CONTRACTOR IS RESPOSIBLE FOR INSTALLING AND REMOVING ALL TEMPORARY LIGHTING REQUIRED FOR CONSTRUCTION.
3. ALL FLUORESCENT FIXTURES SHALL HAVE ELECTRONIC BALLASTS UNLESS OTHERWISE NOTED. ALL COMPACT FLUORESCENT FIXTURES TO HAVE HIGH POWER FACTOR BALLASTS.
4. CONTRACTOR SHALL VERIFY ALL MOUNTING CONDITIONS AND COORDINATE LIGHTING INSTALLATION WITH THE OTHER TRADES.
5. ALL RECESSED FIXTURES SHALL SUPPORTED INDEPENDENTLY OF THE CEILING GRID, AND SHALL BE EQUIPPED WITH EARTHQUAKE CLIPS WHERE APPLICABLE.
6. ALL BARE LAMP FIXTURES IN MAINTENANCE AREAS SHALL BE EQUIPPED WITH SHATTER-PROOF LAMP SHIELDS BY ARM-A-LITE.
7. E.C. SHALL PROVIDE AND INSTALL PLENUM RATED 16 AWG (VERIFY SPECIFIC WIRING REQUIREMENTS WITH VA) FROM PA SPEAKER.



KEY PLAN - BUILDING 1 - 3RD FLOOR - EAST

NORTH

Revisions:	Date
100% SET ISSUE	07-14-2011
100% SET ISSUE	06-13-2011
100% SET ISSUED FOR REVIEW	05-27-2011
REVISED 30% SUBMISSION	03-04-2011
REVISED SIGN OFF	02-24-2011
30% REVIEW SET	11-11-2010
SCHEME 1, 2 AND 3	09-11-2010
EXISTING CONDITIONS	09-01-2010

CONSULTANTS:

LJM ENGINEERING GROUP
439 Route 46 East
Rockaway, New Jersey 07866
Phone: (973) 586-3004 Fax: (973) 586-3009
E-Mail: office@ljmengineering.com Job No. 10092

STATE OF NEW YORK · LAWRENCE J. MUNN · 061098-1 · LICENSED PROFESSIONAL ENGINEER

ARCHITECT:

Lothrop associates LLP architects
200 SUMMIT LAKE DRIVE, VALHALLA, NEW YORK 914-741-1115

Drawing Title: THIRD FLOOR - EAST LIGHTING NEW WORK PLAN

Approved: Project Director

Project Title: RADIOLOGY - CT AT BROOKLYN CAMPUS
NEW YORK HARBOR HEALTH CARE SYSTEM

Location: BROOKLYN, NY

L/A PROJECT # 1284-00
Date 11-11-2010
Checked LJM
Drawn RM

Project Number 630A4-CSI-103
Building Number 1
Drawing Number 10-25-BK EL 101
Dwg. 27 of 45

Facilities Management Services

Department of Veterans Affairs

VA FORM 08-6231, OCT 1978