

#### GENERAL NOTES

- REFER TO ARCHITECTURAL ELEVATIONS FOR EXTERIOR LIGHT FIXTURE MOUNTING HEIGHT.
- REFER TO LIGHTING CONTROL SCHEDULES FOR EXTERIOR LIGHTING CONTROL REQUIREMENTS.
- ALL BRANCH CIRCUITS SHALL HAVE DEDICATED NEUTRALS.
- STREET LIGHTING BRANCH CIRCUITING SHALL BE INSTALLED A MINIMUM DISTANCE OF 24 INCHES FROM INNER CURB LINES. SITE LIGHTING BRANCH CIRCUITING SHALL BE INSTALLED A MINIMUM DISTANCE 6 INCHES FROM WALKWAYS.
- REFER TO ELECTRICAL AND COMMUNICATION RISER DIAGRAMS FOR CABLING AND CONDUIT REQUIREMENTS.
- REFER TO EXTERIOR POLE BASE DETAIL.
- REFER TO LIGHTING ASSEMBLY BASE DETAIL.

#### NOTES FOR THIS DRAWING

- DISCONNECT AND REMOVE EXISTING UNDERGROUND SITE LIGHTING CIRCUITING.
- EXISTING HANDHOLE/PULLBOX FOR SITE LIGHTING CIRCUITS TO BE RELOCATED. REFER TO NEW SITE PLAN LAYOUT FOR NEW LOCATION AND CIRCUITING.
- RELOCATE EXISTING SITE LIGHTING POLE AND FIXTURE(S) TO NEW LOCATION SHOWN ON NEW SITE PLAN LAYOUT. REMOVE EXISTING BASE COMPLETELY AND PROVIDE NEW BASE AT NEW LOCATION.
- EXISTING SITE LIGHTING POLE AND FIXTURE TO REMAIN. REFER TO NEW SITE PLAN LAYOUT FOR ANY RE-CIRCUITING WORK TO BE DONE.
- EXISTING SITE LIGHTING CIRCUITING TO REMAIN. REFER TO NEW SITE PLAN LAYOUT FOR REVISIONS OR ADDITIONS TO THIS CIRCUIT.
- DISCONNECT AND REMOVE EXISTING POLE, FIXTURE(S) AND POLE BASE. TURN POLE AND FIXTURE(S) OVER TO OWNER.
- EXISTING MEDIUM VOLTAGE DUCT BANK TO REMAIN.
- DISCONNECT AND EXTEND EXISTING ELECTRICAL CONNECTIONS TO SMOKING HUT THAT IS BEING RELOCATED. REFER TO NEW SITE PLAN LAYOUT FOR NEW LOCATION.
- EXISTING HANDHOLE TO REMAIN.
- EXISTING MEDIUM VOLTAGE DUCTBANK SECTION TO BE REMOVED. REFER TO NOTE #4 ON SHEET E009 FOR MORE INFORMATION REGARDING THE CONDUCTORS LOCATED IN THIS DUCTBANK.
- REMOVE MEDIUM VOLTAGE DUCTBANK FROM THIS POINT WEST. REFER TO CIVIL PLANS FOR EXACT LOCATION.

1 ELECTRICAL SITE DEMOITON PLAN  
1/16" = 1'-0"


100% OWNER REVIEW  
NOT FOR CONSTRUCTION  
12/16/2011



**RSP Architects**  
1220 Marshall Street NE  
Minneapolis  
Minnesota 55413-1036  
612.877.7100  
612.877.7499 fax  
www.rsparch.com

NOTICE: The designs shown and described herein including all technical drawings, graphics, and models thereof, are proprietary and cannot be copied, duplicated or commercially exploited, in whole or in part, without express written permission of RSP Architects. These are available for limited review and evaluation by clients, consultants, contractors, government agencies, vendors and other personnel only in accordance with the Notes.

© Copyright RSP Architects 2011. All rights reserved.



**ARRAY**

healthcare facilities solutions

#### CONSULTANTS:

**Structural**  
Van Sickle, Allen & Assoc.  
2955 Xenium Lane N  
Suite 10  
Plymouth, MN 55441

**Civil**  
EVS  
10250 Valley View Road  
Suite 113  
Eden Prairie, MN 55344

**Landscape**  
Dunham Foster Assoc.  
923 Nicollet Mall  
Minneapolis, MN 55402

**Fire Protection**  
Gary Trowbridge Associates  
Engineering  
84 Boston Hill  
Larksville, PA 19631-3298

**MEP**  
**DUNHAM**  
600 West Lake Street, Suite 1100  
Minneapolis, Minnesota 55402-1840  
Phone: 612.445.7500  
Fax: 612.445.7501  
www.dunhaminc.com

**MECHANICAL & ELECTRICAL**  
Engineering  
10000 Hennepin Avenue  
Eden Prairie, MN 55344

I hereby certify that this plan, specification or report was prepared by me or under my direct supervision and that I am a duly licensed Engineer under the laws of the State of Minnesota.

Signature

Registration No.

Date 12/16/2011

PROPOSED SERVICE LINE LOCATION	DATE	PROPOSED LIGHTING CONTROL NUMBER	DATE
PROPOSED POLE LOCATION	DATE	PROPOSED EXTERIOR LIGHTING	DATE
PROPOSED EXTERIOR LIGHTING	DATE	PROPOSED EXTERIOR LIGHTING	DATE
PROPOSED EXTERIOR LIGHTING	DATE	PROPOSED EXTERIOR LIGHTING	DATE
PROPOSED EXTERIOR LIGHTING	DATE	PROPOSED EXTERIOR LIGHTING	DATE

PROJECT FILE ELECTRICAL SITE DEMOLITION PLAN	DATE 12/16/2011
PROJECT FILE LONG TERM / INTERMEDIATE PSYCHIATRIC UNIT	DATE AS NOTED
PROJECT FILE 4001 VETERANS DR. SAINT CLOUD, MN	DATE 2002.001.00
PROJECT FILE 4001 VETERANS DR. SAINT CLOUD, MN	DATE E008

