



SAW Contracting, Inc.

2625 Production Rd, Ste A
Virginia Beach, VA 23454

www.sawcontracting.com

REQUEST FOR INFORMATION

Subject: Prebid RFIs

No.

PROJECT: Replacement of Energy Plant Boilers Building 100

DATE: 5/17/18

TO: Department of Veterans Affairs

Contract #: 36C24818R0121

ATTN: Thomas Lucas

STARTED:

REQUIRED:

REQUEST:

Please provide a ductile iron pile specification and geotechnical report. The pile manufacturer requests this information for them to evaluate driving conditions.

Request By: SAW Contracting, Inc.

Signed: _____

Date: 05/17/2018

RESPONSE:

Attached please find the geotechnical investigation report that was used as the basis for design. Ductile iron pipe shall be strong enough to be driven without warp or deflection. Pile driving contractor shall determine ductile iron pipe properties.

Answered By:

Signed: _____

Date: 5-24-2018

Richard Wheeler, PE