


Office of
Construction
and Facilities
Management

 Department of
Veterans Affairs

- 1 EXISTING CORRIDOR CEILING SPACE IS DENSELY POPULATED WITH EXISTING UTILITIES. CONTRACTOR SHALL PROVIDE OFFSETS, PULLBOXES, AND CONDUIT ROUTING REVISIONS AS NECESSARY TO ACCOMPLISH FEEDER INSTALLATION.
- 2 PROVIDE J-HOOKS OVER EXISTING CEILING TO SUPPORT NEW CABLES. PROVIDE HOOKS WITH SUFFICIENT CABLE CAPACITY AT 24" MAX. INTERVALS.
- 3 PROVIDE 9' LONG LADDER TRAY ABOVE EXISTING TO SUPPORT NEW CABLES. TRAY SHALL MATCH EXISTING.

FINAL DESIGN
APPROVED FOR CONSTRUCTION

FINAL DESIGN

Office of
Construction
and Facilities
Management



Department of
Veterans Affairs