



- SHEET KEYNOTES**
- 1 ROUTE POWER CIRCUIT FOR HWP STARTER TO NOTED PANEL. CONTRACTOR SHALL FIELD COORDINATE CONDUIT ROUTING. PROVIDE NEW 15A/3P BREAKER IN EXISTING PANEL. PROVIDE DUCT SEAL AT PENETRATIONS.
  - 2 MOTOR STARTERS MAY BE MOUNTED IN ANY NEC-COMPLIANT LOCATION WITHIN SIGHT OF THE CONNECTED PUMPS. COORDINATE WITH MECHANICAL PIPING PLANS AND EXISTING UTILITIES TO MAINTAIN ACCESSIBILITY AND CLEARANCES.
  - 3 APPROXIMATE LOCATION OF PUMPS. COORDINATE WITH MECHANICAL PIPING.
  - 4 CONTRACTOR SHALL FIELD VERIFY EXISTING PANEL CHARACTERISTICS (BRAND, AIC RATING, TYPE, ETC.). WORK SHALL BE CLOSELY COORDINATED WITH APPLICABLE USER GROUP AND COR. WORK SHALL BE CONDUCTED QUIETLY.

three inches = one foot  
one and one half inches = one foot  
one inch = one foot  
three quarters inch = one foot  
one half inch = one foot  
three eighths inch = one foot  
one quarter inch = one foot  
one eighth inch = one foot

1 SECOND FLOOR - POWER AND RACEWAY ROUTING  
1/8" = 1'-0"

|  |  |           |              |  |   |  |   |  |  |  |   |  |   |   |  |  |
|--|--|-----------|--------------|--|---|--|---|--|--|--|---|--|---|---|--|--|
| <div><div></div><div>ADDENDUM #1 - EQUIP. POWER REVISION</div></div> |  | 5/29/2018 | CONSULTANTS: |  | <div>ENGINEER - OF - RECORD<br/>CHAD J. FRALICK</div> <div>FL. P.E. NO.<br/>73811</div> |  | ARCHITECT/ENGINEERS:  |  | <div>Drawing Title</div> <div>SECOND FLOOR - POWER AND RACEWAY ROUTING</div> <div>Approved: Project Director</div> |  | <div>Project Title</div> <div>RENOVATE WARD 3C FOR<br/>CARDIOLOGY EQUIPMENT<br/>INSTALLATION</div> <div>Location</div> <div>GAINESVILLE, FLORIDA</div> <div><div>Date</div><div>MARCH 9, 2018</div><div>Checked</div><div>CJF</div><div>Drawn</div><div>CJF</div></div> |  | <div>Project Number</div> <div>573-CSI-102</div> <div>Building Number</div> <div>1</div> <div>Drawing Number</div> <div>EP103</div> <div>52 OF 62</div> | <div>Office of<br/>Construction<br/>and Facilities<br/>Management</div> <div><div></div><div>Department of<br/>Veterans Affairs</div></div> |  |  |
|  |  |           |              |  |   |  | <div><div>AKEA</div><div>INC.</div><div>3603 NW 98th Street, Suite B</div><div>Gainesville, FL 32606</div><div>Phone: (352) 474-6124</div><div>Fax: (352) 474-6324</div><div>COA: FL #26693</div><div>AKEA Project No. 094-14</div></div> |  |  |  |   |  |   |   |  |  |
| Revisions:   |  | Date      |              |  |   |  |   |  |  |  |   |  |   |   |  |  |

FINAL DESIGN  
APPROVED FOR CONSTRUCTION