

61B, (4-SK2-02)


60A, (4-SK-01)

LEGEND

- 1,2 APPROXIMATE SAMPLE LOCATION
- 25+ SAMPLE GREATER THAN 0% ASBESTOS
- 25 STOP POSITIVE SAMPLE FOR ASBESTOS
- 25 NO ASBESTOS DETECTED (NAD)
- FIRE WALL 1 HR
- FIRE WALL 2 HR
- SMOKE WALL
- OCCUPANCY SEPARATION 2 HR
- HATCHED AREAS INDICATE POSITIVE DETECTION OF ASBESTOS CONTAINING BUILDING COMPONENTS
- 12"x12" FLOOR TILE
- ACM TILE UNDER CARPET
- ACM BLACK MASTIC - BENEATH OTHER NON-ACM FLOOR MATERIALS
- ACM BLACK FLOOR TILE MASTIC (NO TILE) UNDER CARPET
- ACM COUNTER TOPS
- 12"x12" FLOOR TILE (ABATED ASBESTOS MATERIALS)
- ACM TRANSITE FUME HOOD
- ACM TRANSITE WINDOW PANELS
- ACM PIPE WRAP ON VALVES

NOTE:

UNHATCHED AREAS INDICATE NO ACM BUILDING COMPONENTS WERE IDENTIFIED DURING THE BUILDING SURVEY. REFER TO THE BUILDING ASBESTOS & LEAD SURVEY REPORT FOR LIMITATIONS.



KEY PLAN

Mabbett®
Scientists | Engineers | Program Managers
Mabbett & Associates, Inc.
5 Alfred Circle Bedford, MA 01730-2318
T. 781-275-6050
www.mabbett.com

Drawing Title
FOURTH FLOOR PLAN
ARCHITECTURAL

Site:
VA LOMA LINDA

Building:
1

Location: JERRY L. PETTIS MEMORIAL VA HOSPITAL
LOMA LINDA, CALIFORNIA

Project Title
ASBESTOS SURVEY

Drawn:
BLC

Checked:
DAN


Approved:
?

Scale:
NOT TO SCALE

Date
MARCH 2017

Project No.
2016016.001

Drawing No.
A1-4G



Department of
Veterans Affairs