

REQUEST FOR INFORMATION (RFI)
36C25018B0461

PROJECT NUMBER:	610-16-105	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Upgrade Primary Loop	
PROJECT LOCATION:	Department of Veterans Affairs VA Northern Indiana HCS 1700 E. 38 th St. Marion, IN 46953	

SUBMITTED BY:	Proven Techniques Applied, LLC	CITY/STATE:	Cantonment, FI
PHONE:	850-791-1853		

TO:

Felecia Beamen, Contracting Officer
Department of Veterans Affairs
NCO10 West Contracting Office
8888 Keystone Crossing, Suite 1100
Indianapolis, IN 46240
Felecia.beamen@va.gov

RFI NO.: 1 RFI 12	DATE: 07 June 2018	SPEC/DWG. REFERENCE(s): Sheet ED001, demo notes 9,10 and 11
REPLY NEEDED BY:		

INFORMATION NEEDED:

- On Sheet ED001, demo notes 9, 10 & 11, call out to remove existing breakers, & to replace with new Electronic Trip Breaker. Are we to assume only one breaker is to be replaced in each panel? Please advise.
Each panel indicated has 1 breaker to replaced as noted.

REPLY:

RFIs will be answered by amendment(s).

REPLY FROM:	DATE:
ATTACHMENTS:	COPY TO: