



Building 1, Floor 12.5 - Specific Survey Findings
Project No. VAMC:10013.00-IN

1511 Route 22, Suite C24, Brewster, NY 10509
Phone: 845.278.7710 Fax: 845.278.7750

Project: **Main Building, 12.5th Floor**
 VA Medical Center
 Wilkes-Barre, PA

Inspector(s): James Reber
 Thomas Ferro
Date(s): 2/2010-3/2010

LOCATION	MATERIAL	QUANTITY	CONDITION	SAMPLE #	HOMOGENEOUS WITH SAMPLE #	ASBESTOS CONTENT
12.5th Floor, machine room / elevator 7 & 8						
Floor	Concrete	N/A	N/A	N/A	N/A	Non-suspect
Walls	Brick / metal panels	N/A	N/A	N/A	N/A	Non-suspect
Ceilings	Metal Deck	N/A	N/A	N/A	N/A	Non-suspect
	Spray-on fireproofing (beams, columns and deck)	750 – 900 ft ²	Damaged	12.5-03	N/A	None detected

NOTE:

A brownish spray-on fireproofing was applied in the 1980's, which encompasses a greater than 90% of the spray-on material. A grayish spray-on fireproofing located in some of the ceiling areas was applied about two years ago and encompasses less than 10% of the spray-on material. None of the spray-on materials in this area contain asbestos.