



1 STEP DOWN TRANSFORMER SHALL BE HUNG FROM STRUCTURAL CEILING ABOVE USING 3"x3" GALVANIZED ANGLE AND 1/2" Ø THREADED ROD, NUTS AND FENDER WASHERS. BOTTOM OF TRANSFORMER SHALL BE 8'-0" MIN.

EP102

PANAMA CITY JOINT OUTPATIENT CLINIC	
NAVAL GULF COAST HEALTH CARE	

SIZE F	CODE IDENT. NO.	N A Y F A C DRAWING NO. N/A
HOME		

HQC PROJ. NO.		CONSTR. CONTR. NO.	
SCALE 1/4"=1'-0"	MACC.	T.O.# _____	SHEET 7 OF 13

 <p>766 MIDDLE ST., FARMHURST, AL 36532 251-990-5778</p> <p>ARCH. & ENGR. SEAL</p>	<p>NATURAL RESOURCES & ENVIRONMENTAL AFFAIRS</p> <p>SATISFACTORY TO DATE</p>
	<p>SAFETY DEPARTMENT</p> <p>SATISFACTORY TO DATE</p>
	<p>FIRE DEPARTMENT</p> <p>SATISFACTORY TO DATE</p>
	<p>PUBLIC WORKS SUPERVISOR</p> <p>SATISFACTORY TO DATE</p>

5	P.W. DWG. NO.
	DRAWN BY GWS
	CHECKED BY GWS
	SUPERVISOR WWB
	APPROVED _____ DATE _____
	PUBLIC WORKS OFFICER

DEPARTMENT OF THE NAVY		NAVAL FACILITIES ENGINEERING COMMAND	
NAVAL		SUPPORT ACTIVITY	
PANAMA CITY, FLORIDA			
PANAMA CITY JOINT OUTPATIENT CLINIC			
NAVAL GULF COAST HEALTH CARE			
HVAC POWER			
SIZE		NAVFAC DRAWING NO.	
F		N/A	
CODE IDENT. NO.		CONSTR. CONTR. NO.	
HOMC PROJ. NO.		T.O.# _____	
SCALE 1/4"=1'-0"		SHEET 7 OF 13	
MACC.			

0 2' 4' 8'

SCALE: 1/4" = 1'-0"