

**ST PETERSBURG VA REGIONAL OFFICE  
9500 BAY PINES BLVD  
ST PETERSBURG, FL**



## Performance Work Statement (PWS)

### ***Water Treatment and Cooling Tower Service Contract***

27 June 2018

# Table of contents

## Table of contents

1 Introduction	4
1.1 Scope	4
2 General Requirements	5
2.1 Non-Personal Services	6
2.2 Business Relations	6
2.3 Contract Administration and Management	6
2.4 Subcontract Management	6
2.5 Location and Hours of Work	6
3 Performance Requirements	6
3.1 Establish (open and closed) water treatment system / program. .	7
3.2 Perform Monthly site visits and inspections .	7
3.3 Perform maintenance on cooling towers .	10
4 Special Requirements	12
4.1 Security	13
4.2 Safety	13
4.2.1 Mishaps	14
4.3 Government Furnished Materials	14
4.4 Environmental Requirements	14
4.5 Applicable Directives	14
4.6 Quality	15
4.6.1 Quality Control	15
4.6.2 Quality Assurance Surveillance Plan (QASP)	15
5 Deliverables	16

# Table of contents

6 Related Documents

17

# Performance Requirement Summary (PWS)

## Cooling Tower Service Contract

### 1 Introduction

The St Petersburg VA Regional Office (VARO) has a requirement for maintenance and repair service for its Cooling Towers System. This SERVICE CONTRACT is to provide all materials, labor, supervision, tools, supplies, transportation, and equipment necessary to perform inspection, full preventive maintenance service and required repairs to the existing equipment listed in the schedule. Included are all inspections, adjustments, tests, and repairs to keep the equipment covered under this contract in continuous and reliable use at its established capacity and efficiency. Equipment shall be maintained in accordance with terms and conditions stated herein.

Contractor shall provide 24/7 emergency contact name(s) and telephone number(s).

The Contractor shall provide all labor, associated materials, personnel protective equipment, and any and all necessary equipment required for the maintenance and repairs of the Cooling Towers at the VARO facilities.

Contractor shall be required to provide evidence of training and certifications to perform duties as delineated in this contract. All technicians working on the cooling tower system(s) must be a Refrigeration Technician, Tower Tech Cooling Towers Service training, as well as possess at a minimum the 10 hour Occupational Safety and Health Training Course in Construction Safety & Health. Proof of training requirements shall be submitted to the COR within 10 days of contract award. Contractor must be fully familiar with the installation, operation, functions and capabilities of the Lakewood Instruments Model 1575e Water Treatment System Conductivity Controller.

### 1.1 Scope

#### 1.1.1 – Water Treatment.

This contract encompasses the development and implementation of a water treatment program for the HVAC cooling system at the St Petersburg VA Regional Office (VARO), St Petersburg, FL as well as the development and execution of a complete service and maintenance program for the two cooling towers located at the VARO. The contractor will provide all tools, labor, certified technicians, transportation, parts and materials, chemicals, and associated equipment and supplies necessary to execute the requirements of this contract. The contractor must be able to deliver and apply all necessary chemistry; provide all of the necessary laboratory services for: Legionella testing, corrosion test strip evaluations, atomic analysis, metallographic analysis, X-Ray Powder Diffraction and X- Ray Fluorescence Spectroscopy, perform Taylor Technologies Titration Reagents (Calcium, Chloride, Hardness- High and Low Range, Nitrite, P, M and OH Alkalinity, Sulfite, Organophosphate) and check conductivity for TDS. Contractor must be able to test water for:

- Azole (UV) – BZT & TT

# Performance Requirement Summary (PWS)

- Bromine, Total
- Chlorine, Total and Free
- Copper
- Hardness - High and Low Range
- Iron
- Molybdenum – High and Low Range
- Nitrite
- Organophosphonate (UV)
- Silica

It is the contractors responsibility to ensure both cooling towers are maintained IAW manufacturers O&M manual and this PWS as well as ensuring the contractor developed water treatment protocol is administered ensuring corrosion of the cooling towers is managed optimally to include the management and prevention of the Legionella bacteria. See section 3 below for specific requirements.

## 1.1.2 Cooling Tower Maintenance

The objective of the cooling tower maintenance program is to ensure the cooling towers are maintained IAW manufactures (EVAPCO) standards to include:

- Enhancing the overall plant reliability, availability and performance of the system.
- Reducing or eliminating functional-failures of production-related equipment (fans, motors, belts, etc.).
- Achieve optimal Operating and Maintenance costs.
- Provide a safe working environment for both plant and personnel.
- Reduce negative effects on the environment as a result of component failure.

See section 3.3 Perform Maintenance on Cooling Towers for specifics.

## 2 General Requirements

This section describes the general requirements for this effort. The following sub-sections provide details of various considerations on this effort.

# **Performance Requirement Summary (PWS)**

## ***2.1 Non-Personal Services***

The Government shall neither supervise contractor employees nor control the method by which the contractor performs the required tasks. Under no circumstances shall the Government assign tasks to, or prepare work schedules for, individual contractor employees. It shall be the responsibility of the contractor to manage its employees and to guard against any actions that are of the nature of personal services, or give the perception of personal services. If the contractor believes that any actions constitute, or are perceived to constitute personal services, it shall be the contractor's responsibility to notify the Contracting Officer (CO) immediately.

## ***2.2 Business Relations***

The contractor shall successfully integrate and coordinate all activity needed to execute the requirement. The contractor shall manage the timeliness, completeness, and quality of problem identification. The contractor shall provide corrective action plans, proposal submittals, timely identification of issues, and effective management of subcontractors. The contractor shall seek to ensure customer satisfaction and professional and ethical behavior of all contractor personnel.

## ***2.3 Contract Administration and Management***

The following subsections specify requirements for contract, management, and personnel administration.

## ***2.4 Subcontract Management***

The contractor shall be responsible for any subcontract management necessary to integrate work performed on this requirement and shall be responsible and accountable for subcontractor performance on this requirement. The prime contractor will manage work distribution to ensure there are no Organizational Conflict of Interest (OCI) considerations. Contractors may add subcontractors to their team after notification to the Contracting Officer (CO) or Contracting Officer Representative (COR).

## ***2.5 Location and Hours of Work***

Accomplishment of the results contained in this PWS requires work at the St Petersburg VA Regional Office, 9500 Bay Pines Blvd., St Petersburg, FL 33708. Normal workdays will be Monday through Friday except US Federal Holidays from 7:30am until 5:00 pm. The contractor may work on Saturday and/or Sunday's with prior coordination with the Contracting Officer Representative (COR). The Period Of Performance (POP) for this contract is a base year plus 4 option years.

## **3 Performance Requirements**

The following section specifies the Performance Objectives and Performance Elements for the contract.

# Performance Requirement Summary (PWS)

## ***3.1 Establish (open and closed) water treatment system / program.***

Contractor shall provide all labor, materials, necessary equipment, transportation, and supervision, to develop, implement and maintain an efficient and precise Industrial Water Treatment Program for all hydronic systems located at the St Petersburg VARO. Level of work shall be performed on a full-service basis. The treatment program shall maintain the hydronic systems in accordance with the manufactures specified parameters. Contractor will provide the government a monthly Field Water Analysis Report whereby the COR can review all water analysis data of the water treatment program for both open and closed systems.

### Performance Standards

a) Standard: Compliant with federal, state, and local laws and regulations to include OSHA Technical Manual, Section III, Chapter 7 with regards to Legionella and Cooling towers.

AQL: See OSHA Technical Manual, Section III, Chapter 7, Appendix III: 7-3 Water Sampling Guidelines

b) Standard: Comprehensive - provide scale and corrosion control for cooling systems and lines using efficient and correctly formulated corrosion inhibitors, micro biocides, etc.

AQL: Contractor will prevent the buildup of adherent mineral deposits and/or microbiological growth on heat transfer surfaces of equipment being treated.

### Deliverables

A001 On Site Water Test Results

## ***3.2 Perform Monthly site visits and inspections.***

Contractor will conduct monthly site visits to inspect, test, treat, report, and monitor water treatment services for both open and closed systems. During specified visits the contractor will inspect all equipment and perform all analysis required at the site necessary to determine that the water treatment program is being administered properly and that each system is operating at optimum performance. The technician shall provide on-site verbal and written instructions to the COR in the form of a service report, which shall include recommended control ranges and results of analysis by the technician at the time of each visit. A mass balance and Ryznar calculation will be performed to ensure system is being maintained properly.

### Performance Standards

a) Standard: Identifies and corrects deficiencies

AQL: Cooling towers show minimal signs of corrosion buildup and monthly performance report shows no delta drop greater than 5% than previous monthly performance report

# Performance Requirement Summary (PWS)

## 3.2.1 Water Treatment General Requirements.

- Contractor to provide complete tower/chiller water treatment to prevent fouling on metal services, inhibit corrosion, sanitize, clean, disinfect and control biological growths.
- Contractor shall provide all necessary supervision, personal protective equipment, labor, materials, equipment, and tools to perform the service.
- Vendor shall check chemical levels and fill as needed, and inspect on a regular basis to insure the integrity of the system.
- Vendor must be able to respond within 2 hours of emergency call.
- Chemicals other than chemicals in the day tanks located in tower yard shall not be stored on site.

Monthly the service visit shall include:

- Conduct water analysis on the cooling towers
- Inspect cooling towers for biological growth, foam, sludge, and proper system operation
- Control equipment is to be checked for calibration and proper operation, probes cleaned and adjustments made as test results dictate
- Clean and inspect blow down / conductivity solenoid valve
- Clean electrode end of conductivity sensor.
- Inspect and repair as required chemical pumps, injection points and check valves on all treated equipment
- Ensure water flow is sufficient through all lines
- Maintain polyethylene tubing, valves, and chemical pumps, provide loaner equipment in the event equipment malfunction until onsite units are repaired or replaced
- Furnish and apply all products to retard scale and corrosion in condensing water circuits.
- Check chemical storage tanks (biocide and inhibitor) and fill as necessary
- Ensure cycles of concentration are adjusted to minimize water that is discharged to the drain.
- Visually inspect operation of equipment and make note of any conditions that interfere with proper equipment operations and report to COR.
- Furnish all test regents, test equipment, and log sheets necessary to properly maintain the treatment program.



# Performance Requirement Summary (PWS)

- Supply copies of computerized and/or manually produced reports listing findings and recommendations to the COR.

Quarterly the service visit shall include:

- Water analysis on closed water circuits.
- Furnish and apply all products to retard scale and corrosion in closed loop water circuits
- Inspect pot feeders for proper operation.
- Visually inspect operation of equipment and keep the treatment area neat, clean and orderly to include keeping the cooling tower facility free of foreign objects and debris that can be sucked into the cooling system.

Semi-annually the following service will include:

- Legionella prevention and control is a multidisciplinary; effective prevention of HCA LD requires timely communication amongst the lab, water technician, contractor, and COR. This is especially important regarding interpretation and follow-up for positive validation results. If the results of the environmental validation are positive for *L. pneumophila*, the COR as well as Division Chief, SSD, St Petersburg VARO must be promptly notified.

Contractor will reference VHA Directive 1061, PREVENTION OF HEALTHCARE-ASSOCIATED LEGIONELLA DISEASE AND SCALD INJURY FROM POTABLE WATER DISTRIBUTION SYSTEMS in the management and treatment of Legionella.

- Performance Standards

a) Standard: Compliant with applicable standards

AQL: Refer to PREVENTION OF HEALTHCARE-ASSOCIATED LEGIONELLA DISEASE AND SCALD INJURY FROM POTABLE WATER DISTRIBUTION SYSTEMS , VHA Directive 1061

Deliverables

- A003 Water testing Deliver water samples to a certified Legionella testing lab for analysis and report findings to the COR and Chief, SSD room 205. Samples for both the cooling tower water as well as the fountain water adjacent the cooling tower complex will be delivered to a certified Legionella testing lab.

Annually, the following service will include

- Present water analysis on both open and closed water circuits

# Performance Requirement Summary (PWS)

- Present yearly review of the treatment program, topics to include recommendations, effectiveness of existing program, results of equipment inspections and future considerations.
- Perform annual cooling tower cleanout to maintain tower fill, tower nozzles, and distribution decks from scale and debris accumulation.
- Flush sumps and basins to remove debris

## Performance Standards

a) Standard: Identifies and corrects deficiencies.

AQL: Faults are addressed and remediated within 48hrs

b) Standard: Compliant with federal, state, and local laws and regulations

AQL: Compliant with all local, state, and federal law/codes to include environmental law regarding safe operation of cooling towers.

## Deliverables

A002 Monthly performance report

### ***3.3 Perform maintenance on cooling towers.***

The contractor shall furnish certified technician(s) on the job site while in performance of Maintenance and Service of Cooling Towers. Technicians shall have NLT 5 years of experience. Contractor shall be responsible for regular, systematic execution of the work items as referenced in the manufactures O&M manual. The contractor agrees to regularly and systematically perform required maintenance of the equipment and provide callback service as conditions warrant, repair or replace all portions of the equipment included under this contract.

Equipment shall be maintained in first-class condition to meet the initial performance ability. The equipment manufacturer's recommended maintenance requirements shall be accomplished under the scope of this contract. Both Cooling Towers are less than one year old and presently working and neither have presented any difficulties before this contract. The equipment manufacturer's maintenance requirements are considered the minimum for all equipment. If specific equipment covered by this contract requires additional maintenance for safe and reliable operation the contractor shall perform the required maintenance. Any Electrical work or maintenance shall be done by a licensed electrician.

Scheduled Maintenance Program:

A scheduled maintenance program will be provided, kept and used by the Contractor to keep the cooling towers operating at optimum efficiency. The scheduled maintenance program shall be

# Performance Requirement Summary (PWS)

previously approved by the Contracting Officer Representative (COR). Service technician assures state-of-the-art performance with minimum failure rate. Contractor will provide in writing the preventive maintenance protocol (policies and procedures), including the methods and frequency of testing and verifications of performance for the equipment.

Each preventive maintenance service will be scheduled and completed in a computer-prepared service report, detailing exactly what was performed and to which equipment was done, what special tools, instrumentation, and diagnostic programs was used to maintain the system at optimum efficiency levels. At the completion of each period, a Summary Report will be provided to the COR. Template of the report needs to be approved by COR prior to start of this contract. Maintenance intervals are scheduled twice a year, on intervals of approximately six (6) months apart.

## Preventive Maintenance & Repair Service:

The contractor shall perform all Inspections and Preventive Maintenance (PM) and repair service to ensure that equipment listed in the schedule performs in accordance with the "Equipment manufacturer's maintenance program". The contractor shall utilize and provide procedures and checklists with worksheet originals indicating work performance and actual values obtained at the completion of the PM. Contractor shall submit their checklist of PM for government approval before preceding any type of work. The scheduled work to be performed for PM shall include, but is not limited to the following items:

### Cooling Towers:

- Clean pan strainer (monthly or as needed)
- Clean and flush pan (quarterly or as needed)
- Check bleed-off valve to make sure it is operative – monthly
- Check operating level in pan and adjust float valve if necessary - monthly
- Check water distribution system and spray pattern – monthly
- Check drift eliminators – quarterly
- Check fan blades for cracks, missing balancing weights, and vibrations – quarterly
- Check sheaves and bushings for corrosion. Scrape and coat with ZRC – annually
- Inspect and clean protective finish – annually
  - Clean and polish with a stainless steel cleaner
- Washing/cleaning of collection system damper

# Performance Requirement Summary (PWS)

- Removal of inspection port cover and inspection of interior of perimeter basin wall, and replacing cover as needed.
- Power washing fan plenum exterior walls as required to prevent corrosive buildup.
- Power washing fan assemblies and fan shrouds as required to prevent corrosive buildup.
- Inspect and reseal interior wall seams and joints, as needed
- Readjusting make-up water valves to recommended operating level
- Inspect fan motor-drive assembly; check belt tension and adjust – monthly
- Inspect fan shaft bearings (pillow blocks) and lubricate as required, every 1000hours of operation or every three months
- Sliding motor base – Inspect and grease annually or as needed

## Repair Services:

Repair services will be conducted, as required to the Cooling Tower motor, and motor-drive assembly, bearings, pillow blocks, reducing gear, belts, pulleys, fan assembly, shrouds, nozzles, make-up valves, level sensors, catch basin seals, drift eliminators, filters, and motorized valves. The successful offeror will be expected while in the performance of the contract to procure and replace unrepairable items less than \$500 as mentioned above. For those items that exceed \$500 the contractor will provide the government with a cost estimate to include manufacture, make, model, part #, and labor to install the replacement part(s).

## Performance Standards

a) Standard: Identifies and corrects deficiencies

AQL: **Both** cooling tower(s) will not be out of service at the **same time** for more than 4hrs for any service or maintenance fault.

AQL: Drift eliminators, and side air filters will be pressure washed and free of scale and buildup.

## Deliverables

A004 Cooling Tower Maintenance Protocol

## 4 Special Requirements

This section describes the special requirements for this effort. The following sub-sections provide details of various considerations on this effort.

# Performance Requirement Summary (PWS)

## ***4.1 Security***

During normal business hours (6am - 6pm) the Contractor is required to enter and exit the St Petersburg VARO through the front entrance. Entering or exiting the building through any other door will require VARO approval and an escort will be required. Upon entering the building the contractor and/or contractor employees will be required to show proof of identity (must have a valid photo ID) as well as pass through a security screening. Once the contractor has passed through security he/she will report to room 205, Support Services Division (SSD) to sign in/out and meet with the COR. Contractor is responsible for notifying the COR via e-mail or phone at least 24hrs in advance of arrive to ensure someone will be available to meet with the contractor as well as deconflict any parking issues.

## ***4.2 Safety***

Equipment - The Contractor shall provide all safety equipment/devices, MSDS, personal protective equipment and clothing as required for its employees. Copies of all MSDS shall be provided to the COR.

OSHA - Prior to commencing work the Contractor shall provide proof that an OSHA designated "competent person (CP)(29 CFR 1926.20(b)(2) will maintain a presence at the work site whenever the general or subcontractors are not present. The Contractor as well as the on-site supervisor will have completed no less than 30 hours of OSHA approved safety training. All other Contractor employees will have no less than 10 hours of OSHA approved safety training.

Safety Plan Contractor will provide a site specific safety plan as well as an Activity Hazards Analysis. An example of a VA approved AHA can be found at <http://www.usace.army.mil/Safety-and-Occupational-Health/Activity-Hazard-Analysis>

Compliance - The Contractor shall comply with all applicable Federal, State and local legal requirements regarding workers health and safety. The requirements include but are not limited to, those found in Federal and State Occupational Safety and Health Act (OSHA) statutes and regulations, such as applicable provisions of Title 29, Code of Federal Regulations (CFR) Parts 1910 and 1926. Contractor is solely responsible for determining the legal requirements that apply to activities, and shall ensure safe and healthful working conditions for its employees.

Contractor is responsible for providing all personal protective equipment (PPE) required to be utilized by the contractor's personnel in the performance of their duties.

Contractor will provide the COR all Material Safety Data Sheet (MSDS'S) for any chemical(s) utilized by the contractor in the performance of this contract.

As defined by OSHA, EPA, NFPA Life Safety Codes, and all other regulatory requirements any incident of a major malfunction, accident or injury, a written report shall be submitted by the Contractor to the COR within five (5) working days following the incident. The report shall state the cause, what, where and when and why the incident happened and the repairs and tests that were or are to be made to correct the cause of the incident.

# Performance Requirement Summary (PWS)

## 4.2.1 Mishaps

Mishap Notification and Investigation: The contractor and its subcontractors (if applicable) shall promptly report pertinent facts regarding mishaps involving Government property damage or injury to Government personnel and to cooperate in any resulting safety investigation. The contractor shall notify (via telephone) the contracting officer's representative, and/or other applicable members within four (4) hours of all mishaps or incidents. The Government person notified by the contractor will in-turn notify the Safety office. Contractor notifications made after duty hours shall be reported to the appropriate installation Command Post. If requested by the cognizant contracting officer, the contracting officer's representative, and/or the cognizant program manager, the contractor shall immediately secure the mishap scene/damaged property and impound pertinent maintenance and training records until released by the investigating safety office. If the Government investigates the mishap, the contractor and the subcontractors shall cooperate fully and assist the Government personnel until the investigation is completed.

## 4.3 Government Furnished Materials

The government shall provide at no cost parking space and access to the VARO loading docks, chiller plant, and cooling towers as necessary.

## 4.4 Environmental Requirements

Contractor must show evidence of promoting technologies and best business practices in achieving GREEN goals and incorporating established best practices in developing a systematic Water Management Process that ensures the government can obtain a 'Green Globe' certification.

Mandatory compliance

Corps of Engineers Manual EM 385-1-1, "General Safety Requirements as well as the specific requirements stated elsewhere in the Contract Documents. EM 385-1-1 can be found at [http://www.publications.usace.army.mil/Portals/76/Publications/EngineerManuals/EM\\_385-1-1.pdf](http://www.publications.usace.army.mil/Portals/76/Publications/EngineerManuals/EM_385-1-1.pdf)

29 CFR 1926.20 -Application of the multi-employer policy to particular construction standards.

Found at

[https://www.osha.gov/pls/oshaweb/owasrch.search\\_form?p\\_doc\\_type=INTERPRETATIONS&p\\_to\\_c\\_level=3&p\\_keyvalue=1926.20&p\\_status=CURRENT](https://www.osha.gov/pls/oshaweb/owasrch.search_form?p_doc_type=INTERPRETATIONS&p_to_c_level=3&p_keyvalue=1926.20&p_status=CURRENT)

Non Mandatory document

## 4.5 Applicable Directives

The contractor shall comply with all documents listed below as mandatory and referenced under paragraph 3.0, Performance Requirements. Compliance with documents listed as non-mandatory is the contractors' option.

Mandatory compliance (list)

# Performance Requirement Summary (PWS)

Corps of Engineers Manual EM 385-1-1, "General Safety Requirements as well as the specific requirements stated elsewhere in the Contract Documents. EM 385-1-1 can be found at [http://www.publications.usace.army.mil/Portals/76/Publications/EngineerManuals/EM\\_385-1-1.pdf](http://www.publications.usace.army.mil/Portals/76/Publications/EngineerManuals/EM_385-1-1.pdf)

29 CFR 1926.20

Activity Hazards Analysis - AHA example found at <http://www.usace.army.mil/Safety-and-Occupational-Health/Activity-Hazard-Analysis>

Non-Mandatory document (list)

VHA Directive 1061 Prevention of Healthcare-Associated Legionella disease and scald injury from Potable Water Distribution Systems [https://www.1061\\_D\\_2014\\_08\\_15\(2\).pdf-Adobe Reader](https://www.1061_D_2014_08_15(2).pdf-Adobe Reader)

OSHA Technical Manual (OTM) Section III: Chapter 7  
[https://www.osha.gov/dts/osta/otm/otm\\_iii/otm\\_iii\\_3.html](https://www.osha.gov/dts/osta/otm/otm_iii/otm_iii_3.html)

ASHRAE Guideline 12-2000, Standard Minimizing the Risk of Legionellosis Associated with Building Water Systems for Legionella (reference CDC website)

## 4.6 Quality

This section describes the Quality Control components for this effort. The following sub-sections provide details of various considerations on this effort.

### 4.6.1 Quality Control

The Contractor shall develop a Quality Control Plan (QCP) and maintain an effective quality control program to ensure services are performed in accordance with this PWS. The Contractor shall develop and implement procedures to identify, prevent, and ensure non-recurrence of defective services. The Contractors QCP is the means by which he assures himself that his work complies with the requirement of the contract.

The finalized QCP will be accepted by the Government within 10 days from the time of the award of the Task/Delivery Order. The Contracting Officer may notify the Contractor of required modifications to the plan during the period of performance. The Contractor then shall coordinate suggested modifications and obtain acceptance of the plan by the Contracting Officer. Any modifications to the program during the period of performance shall be provided to the Contracting Officer for review no later than 10 working days prior to effective date of the change. The QCP shall be subject to the Governments review and approval. The Government may find the QCP "unacceptable" whenever the Contractors procedures do not accomplish quality control objective(s). The Contractor shall revise the QCP within 10 working days from receipt of notice that QCP is found "unacceptable."

### 4.6.2 Quality Assurance Surveillance Plan (QASP)

The Government shall monitor the Contractors performance under this Task/Delivery Order in accordance with the Governments QASP.

# Performance Requirement Summary (PWS)

## 5 Deliverables

The contractor shall provide deliverables as described in subsequent task orders. Deliverables shall be specified by the government. Format and delivery schedule for deliverables shall be outlined in CDRLs and/or other means TBD.

Number	Name	Frequency	Quantity
A001	On Site Water Test Results  Contractor will conduct mass balance and Ryznar calculation in order to ensure system is being maintained properly.	Monthly	12
A002	Monthly performance report  Performance report will address areas relevant to:  * the cooling tower and associated equipment for the presence of organic material, biofilm, algae, and other visible contaminants  * the general condition of the cooling tower, basin, packing material, and drift eliminator;  * water make-up connections and control;  * proper functioning of the conductivity control;  * proper functioning of all dosing equipment (pumps, strain gauges)	Monthly	12
A003	Water testing  In accordance with VHA Directive 1061, the laboratory processing the water samples for Legionella must be certified by the Centers for Disease Control and Prevention (CDC) Environmental Legionella Isolation Techniques Evaluation (ELITE) program as proficient at performing the culture of Legionella species from environmental samples.	Semi-annually	2



# Performance Requirement Summary (PWS)

## 6 Related Documents

- Florida Building Codes - [http://floridabuilding.org/bc/bc\\_default.aspx](http://floridabuilding.org/bc/bc_default.aspx)

VHA Directive 2011-036, Safety and Health during Construction -

[http://www.va.gov/vhapublications/ViewPublication.asp?pub\\_ID=2448](http://www.va.gov/vhapublications/ViewPublication.asp?pub_ID=2448)

- VA Handbook 6500.6, Appendix D, Contractor Rules of Behavior - [http://www.va.gov/vapubs/viewPublication.asp?Pub\\_ID=471&FType=2](http://www.va.gov/vapubs/viewPublication.asp?Pub_ID=471&FType=2)
- OSHA Technical Manual, Section III, Chapter 7, Appendix III: 7-3 Water Sampling Guidelines Found at: [https://www.osha.gov/dts/osta/otm/otm\\_iii/otm\\_iii\\_7.html](https://www.osha.gov/dts/osta/otm/otm_iii/otm_iii_7.html)
- COOLING TOWER MAINTENANCE PROGRAM AND PLAN TEMPLATE

Found at:

[https://www.google.com/url?sa=t&rct=j&q=&esrc=s&source=web&cd=3&ved=0ahUKEwih88jric7XAhXJ4SYKHQR4CAcQFgg7MAI&url=https%3A%2F%2Fwww.health.ny.gov%2Fenvironmental%2Fwater%2Fdrinking%2Flegionella%2Fdocs%2Fcooling\\_tower\\_maintenance\\_program\\_plan\\_template.docx&usq=AOvVaw3E7hMuBsZmybR9dUqjabRb](https://www.google.com/url?sa=t&rct=j&q=&esrc=s&source=web&cd=3&ved=0ahUKEwih88jric7XAhXJ4SYKHQR4CAcQFgg7MAI&url=https%3A%2F%2Fwww.health.ny.gov%2Fenvironmental%2Fwater%2Fdrinking%2Flegionella%2Fdocs%2Fcooling_tower_maintenance_program_plan_template.docx&usq=AOvVaw3E7hMuBsZmybR9dUqjabRb)