

General/RFI Clarifications
RENOVATE BLDG. 28 FOR SPECIALTY CARE
LEXINGTON VA MEDICAL CENTER – LEESTOWN DIVISION
VA PROJECT # 596-16-101

****GENERAL CLARIFICATION:** A-DEC will be supplying ALL equipment and materials related to dental; this includes all casework as well.

27. Spec Section: N/A

Paragraph: N/A

Page #: Drawing I501

QUESTION: Drawing sheet I501 note 3 calls for a sign type IN03.01 at each door. Floor plans I102 & I103 has signage location. Do we provide them per the floor plans or do all door openings get signage?

Answer: See response to questions 94 and 94.A. All interior door openings receive IN-04.04 unless otherwise noted.

156. Please clarify A501 C3 / C5 Spray Foam insulation as being “open” or “closed” cell application.

Answer: Please refer to new spec section 07 21 00 titled “Spray Polyurethane Thermal Insulation” part 2.1.A, which states closed-cell application. Also, see new spec section 07 21 13 “Thermal Insulation.”