

REMARKS:

- REMARKS:
1. PROVIDE WITH ELECTRICAL 110V ACTUATOR.
  2. TIE ELECTRICAL ACTUATOR TO TEMPERATURE SENSOR ON HWS PIPING FROM HX-1.
  3. TIE ELECTRICAL ACTUATOR TO TEMPERATURE SENSOR ON DHW PIPING FROM DHW-1.


---

REMARKS:

- REMARKS:
1. DUPLEX CONDENSATE PUMP WITH RECEIVER.
  2. PROVIDE EMERGENCY POWER.
  3. INSTALL PUMPS AND CONDENSATE RECEIVER IN PIT. LOCATE STARTER, DISCONNECT SWITCH, AND ALTERNATOR OUTSIDE OF PIT.
  4. CP-1 AND CP-2 ARE TO ALTERNATE USE WITH EACH OTHER. PROVIDE ALTERNATOR TO FACILITATE SWITCHING PUMP OPERATION.
  5. INTEGRATE INTO NEW BAS FOR BUILDING 25.

REMARKS:

- REMARKS:
1. VORTEX SHEDDING FLOW METER.
  2. PROVIDE TEMPERATURE AND PRESSURE DIGITAL READOUTS.
  3. POWER SUPPLY TO METER AND TRANSMITTER SHALL BE 120V/60HZ
  4. INTEGRATE INTO NEW BAS FOR BUILDING 25.

Project Title <b>BUILDING 25 RENOVATION</b>			Project No. VA Project No. 538-16-101		<b>Office of Construction and Facilities Management</b>
Location <b>CHILLICOTHE VAMC      CHILLICOTHE, OH</b>			Building Number <b>25</b>		
			Drawing Number <b>MP601</b>		
Date 11/22/2017	Checked CW	Drawn GP	Dwg. 94 of 133		 <b>Department of Veterans Affairs</b>