





1 FIRST FLOOR ELECTRICAL PLAN  
SCALE: 1/8"=1'-0"

KEYED NOTES:

1. LOCKED.

GENERAL NOTES:

1. DISCONNECT MECHANICAL EQUIPMENT AND MAKE SAFE FOR REMOVAL. PROTECT EXISTING WIRING AND CONDUIT DURING CONSTRUCTION FOR REUSE. RECONNECT TO NEW MECHANICAL EQUIPMENT IN SAME LOCATION. TOTAL OF 12 MOTORS BEING REPLACED THROUGHOUT BUILDING, LOCATION TO BE VERIFIED.



Revisions	Date	 www.bergmannpc.com 28 East Main Street 200 First Federal Plaza Rochester, New York 14614 585.232.5135 / 585.232.4652 fax Engineers / Architects / Planners / Surveyors	ALL WORK TO BE IN ACCORDANCE WITH N.F.P.A., NATIONAL, STATE AND CITY CODES & O.S.H.A.	Approved: A.P.G.E. _____ Date _____	Approved: Fire Chief _____ Date _____	Approved: Energy Engineer _____ Date _____	Drawing Title: WING A & B FIRST FLOOR ELECTRICAL PLAN	Project Title: ENERGY CONSERVATION MEASURES AT THE BATH VAMC	Date: 08/15/2012	
			Approved: Logistics Manager _____ Date _____	Approved: Interior Designer _____ Date _____	Approved: Safety Officer _____ Date _____	Approved: M&R Foreman _____ Date _____	Approved: Eng. Project Supervisor _____ Date _____	Building No. 104	Project No. 528A6-12-629	
Revisions	Date		Approved: Infection Control Mgr. _____ Date _____	Approved: Info. Sys. _____ Date _____	Approved: Industrial Hygienist _____ Date _____	_____ Date _____	Approved: Medical Center Director _____ Date _____	Location BATH, NEW YORK	DRAWING NO. VAMC-528A6-12-629 104-E-101	
			Approved: Chief Security _____ Date _____	Approved: Women's Health Rep _____ Date _____	Approved: Space Owner _____ Date _____	_____ Date _____	_____ Date _____	_____ Date _____	121 of 124	