



- KEYED NOTES:**
1. LOCKED.
 2. PROVIDE WIRED JUNCTION BOX FOR CONNECTION TO DDC CONTROL PANEL. CIRCUIT TO NEAREST 120V PANELBOARD. ASSUME DISTANCE TO PANELBOARD TO BE 150'.

1 FIRST FLOOR ELECTRICAL PLAN
SCALE: 1/8"=1'-0"



		<div> www.bergmannpc.com 28 East Main Street 200 First Federal Plaza Rochester, New York 14614 585.232.5135 / 585.232.4652 fax Engineers / Architects / Planners / Surveyors</div>	ALL WORK TO BE IN ACCORDANCE WITH N.F.P.A., NATIONAL, STATE AND CITY CODES & O.S.H.A.		Approved: A.P.G.E. _____ Date _____	Approved: Fire Chief _____ Date _____	Approved: Energy Engineer _____ Date _____	Drawing Title WING D & C FIRST FLOOR ELECTRICAL PLAN		Project Title ENERGY CONSERVATION MEASURES AT THE BATH VAMC		Date 08/15/2012	<div>V.A.M.C.</div>
			Approved: Logistics Manager _____ Date _____		Approved: Interior Designer _____ Date _____	Approved: Safety Officer _____ Date _____	Approved: M&R Foreman _____ Date _____	Project No. 528A6-12-629					
			Approved: Infection Control Mgr. _____ Date _____		Approved: Info. Sys. _____ Date _____	Approved: Industrial Hygienist _____ Date _____	_____ Date _____	Approved: Eng. Project Supervisor _____ Date _____	Building No. 104	Checked JJD	Drawn TLS	DRAWING NO. VAMC-528A6-12-629	
			Approved: Chief Security _____ Date _____		Approved: Women's Health Rep _____ Date _____	Approved: Space Owner _____ Date _____	_____ Date _____	Approved: Medical Center Director _____ Date _____	Location BATH, NEW YORK		104-E-102		
			Revisions _____ Date _____									122 of 124	