



NOTES:

1. REPLACE LAMPS AND BALLASTS AS INDICATED. PROVIDE SOCKETS, AND REWIRE AS REQUIRED FOR REPLACEMENT BALLASTS.
2. BASIS OF DESIGN BALLAST: PHILIPS ADVANCE OPTIMUM, PROGRAMMED START, MINIMUM 0.88 BALLAST FACTOR
3. BASIS OF DESIGN LAMP: PHILIPS ENERGY ADVANTAGE T8 25 WATT FLUORESCENT LAMPS.
4. BASIS OF DESIGN LAMP: PHILIPS ENERGY ADVANTAGE T8 HIGH LUMEN FLUORESCENT LAMPS.
5. BASIS OF DESIGN LAMP: PHILIPS ENERGY ADVANTAGE U-BENT 6' FLUORESCENT LAMPS.
6. BASIS OF DESIGN LAMP: PHILIPS EnduraLES A-LAMP SERIES.
7. REPLACE LAMPS AS INDICATED.
8. FIXTURE HAS DUAL LEVEL SWITCHING. COORDINATE BALLAST REPLACEMENT WITH EXISTING FIELD CONDITIONS.
9. REPLACE LAMP AND BALLAST WITH HOLOPHANE POST TOP LANTERN LED RETROFIT KIT. ORIENT ASSYMETRICAL REFRACTOR TO PROVIDE THE GREATEST AMOUNT OF LIGHT ALONG THE SIDEWALK.
10. REPLACE LIGHTING FIXTURE HEAD WITH HOLOPHANE LaneVue LED ROADWAY LIGHTING HEAD, LVU1-60-E70-MVOL-R3-KGR-QR-PC5.
11. REPLACE 1/4 WALLPACK. BASIS OF DESIGN: LPHONIA WST LED SERIES, WST LED 2 10A700/40-GR S3 MVOLT PE ELCW DBEXD.
12. REPLACE TWO BALLASTS (1 LAMP) IN PATIENT ROOM WALL MOUNTED FIXTURES IN BUILDING 78.

NOTE: ALL SYMBOLS MAY NOT BE USED

Source	Date	Building No.	Checked JJJ	Drawn TJS	DRAWING NO. VAMC-528A6-12-629 0-E-001 Dwg. 85 of 124
Source	Date	Location BATH, NEW YORK			