


**GENERAL NOTES:**

- A. ALL EXPOSED CONDUIT RUNS, ARE TO BE IMC, SURFACE MOUNTED ON GALVANIZED CHANNEL. SEE DETAIL ON DRAWING ES-090.
- B. (1) EACH BRANCH CIRCUIT HOMERUN SHALL HAVE NO MORE THAN THREE CIRCUITS. EACH BRANCH CIRCUIT HOMERUN SHALL HAVE A SEPERATE GREEN INSULATED EQUIPMENT GROUNDING CONDUCTOR.
- C. MULTI-GANG BACKBOXES FOR DIFFERENT VOLTAGES AND TYPES OF EMERGENCY AND NORMAL BRANCH WIRING DEVICES SHALL HAVE DEVIDERS BETWEEN DEVICES.
- D. MULTI-POLE BRANCH CIRCUITS, WILL NOT BE ALLOWED, PROVIDE SEPERATE NEUTRAL CONDUCTORS FOR EACH PHASE CONDUCTOR.

**KEY NOTES:**

- (1) DOOR OPERATORS, AND PUSH BUTTON STATIONS FURNISHED WITH DOORS. PROVIDE RACEWAY AND CONDUCTORS BETWEEN PUSH BUTTONS AND DOOR MOTOR, WIRE AND CONNECT PER MANUFACTURERS RECOMMENDATIONS.

1 POWER PLAN - LEVEL 2  
ES-102 1/16" = 1'-0"

		CONSULTANTS:  SIGNAGE SIGNIA DESIGN 2395 UNIVERSITY AVENUE W., SUITE 316 SAINT PAUL, MN 55114 PHONE: 651-209-6254 LANDSCAPE ANDERSON ENGINEERING 13605 1ST AVENUE NORTH, SUITE 100 PLYMOUTH, MN 55441 PHONE: 763-412-4000	ARCHITECTS/ENGINEERS:  LEO A DALY PLANNING ARCHITECTURE ENGINEERING INTERIORS EST. 1915  730 Second Avenue South, Suite 1100 Minneapolis, MN 55402-2455 USA Tel 612-338-8741 Fax 612-338-4840 Project #023-10131-000	Drawing Title: POWER PLAN - LEVEL 2	Project Title CONSTRUCT PARKING RAMP DESIGN	Project Number 618-820	Building Number 78	Office of Construction and Facilities Management
				I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am duly licensed Professional Engineer under the laws of the State of Minnesota Signature:  Printed Name: Randall A. Jacobs Date: 02-24-2012 License: 25414	Location 1 VETERANS DRIVE MINNEAPOLIS, MN 55417	Drawing Number ES-102	Department of Veterans Affairs	
Revisions:	Date		Project #023-10131-000					