

28 31 00  
**FIRE DETECTION AND ALARM**

PART 1 - GENERAL

1.1 DESCRIPTION

- A. This section of the specifications includes the furnishing, installation, and connection of the fire alarm equipment to form a complete coordinated system ready for operation. It shall include, but not be limited to, alarm initiating devices, alarm notification appliances, control units, fire safety control devices, annunciators, power supplies, and wiring as shown on the drawings and specified.
- B. Fire alarm systems shall comply with requirements of the NFPA 72 and the Department of Veterans Affairs Fire Protection Design Manual (4th Edition) unless variations are specifically identified within these contract documents by the following notation: [VARIATION]. The design, system layout, document submittal preparation, and supervision of installation and testing shall be provided by a technician that is certified NICET level III or a registered fire protection engineer. The NICET certified technician shall be on site for the supervision and testing of the system. Factory engineers from the equipment manufacturer, thoroughly familiar and knowledgeable with all equipment utilized, shall provide additional technical support at the site as required by the Contracting Officer or his authorized representative. Installers shall have a minimum of two years experience installing fire alarm systems.
- C. Fire Alarm Systems shall be noncoded addressable systems, with automatic sensitivity control of certain smoke detectors and multiplexed signal transmission, dedicated to fire-alarm service only.
- D. The existing building fire alarm system is less than a year old and is a Gamewell/FCI product that has an automatic digitized voice fire alarm signal with emergency manual voice override to notify occupants to evacuate. The digitized voice message shall identify the area of the building (smoke zone) from which the alarm was initiated.
- E. Alarm signals (by device), supervisory signals (by device) and system trouble signals (by device not reporting) shall be distinctly transmitted to the main fire alarm system control unit (located on plan drawings for each building).
- F. The main fire alarm control unit shall automatically transmit alarm signals to a listed central station using a digital alarm communicator transmitter in accordance with NFPA 72.

## 1.2 DEFINITIONS

- A. COTR: Contracting Officer's Technical Representative
- B. VA FPDM: Department of Veterans Affairs Fire Protection Design Manual
- C. LED: Light-emitting diode.
- D. NICET: National Institute for Certification in Engineering Technologies.
- E. PIV: Post Indicator Valve
- F. VCS: Voice Communications Systems

## 1.3 SCOPE

- A. The existing fire alarm devices, wiring, and conduits to be reused and/or modified for the new layout of the area. Any additional devices needed for this project shall be provided as part of this contract.
- B. All programming of the main fire alarm panel shall be provided by FireNet Systems Inc. Bidding contractors shall provide a separate line item cost for reprogramming of the space.
- C. A modified fire alarm system shall be designed and installed in accordance with the specifications and drawings. Device location and wiring runs shown on the drawings are for reference only unless specifically dimensioned. Actual locations shall be in accordance with NFPA 72, VA FPDM, and this specification.
- D. Basic Performance:
  - 1. Alarm and trouble signals from the building fire alarm control panel shall be digitally encoded by UL listed electronic devices onto a multiplexed communication system.
  - 2. Response time between alarm initiation (contact closure) and recording at the main fire alarm control unit (appearance on alphanumeric read out) shall not exceed five (5) seconds.
  - 3. The signaling line circuits (SLC) between building fire alarm control units shall be wired Style 7 in accordance with NFPA 72. Isolation shall be provided so that no more than one building can be lost due to a short circuit fault.
  - 4. Initiating device circuits (IDC) shall be wired Style C in accordance with NFPA 72.
  - 5. Signaling line circuits (SLC) within buildings shall be wired Style 4 in accordance with NFPA 72. Individual

signaling line circuits shall be limited to covering 22,500 square feet of floor space or 3 floors whichever is less.

6. Notification appliance circuits (NAC) shall be wired Style Y in accordance with NFPA 72.

#### 1.4 DEFEND IN PLACE SYSTEMS OPERATIONAL DESCRIPTION

- A. Fire-alarm signal initiation shall be by one or more of the following devices and systems:
  1. Smoke detectors.
- B. Fire-alarm signal shall initiate the following actions:
  1. Activate voice/alarm communication system.
  2. Identify alarm at fire-alarm control unit and remote annunciators.
  3. Transmit an alarm signal to the remote alarm receiving station.
  4. Unlock electric door locks in designated egress paths.
  5. Release fire and smoke doors held open by magnetic door holders.
  6. Switch heating, ventilating, and air-conditioning equipment controls to fire-alarm mode.
  7. Activate smoke-control system (smoke management) at firefighter smoke-control system panel.
  8. Close smoke dampers in air ducts of designated air-conditioning duct systems.
  9. Recall elevators to primary or alternate recall floors.
  10. Activate emergency lighting control.
  11. Activate emergency shutoffs for gas and fuel supplies.
  12. Record events in the system memory.
  13. Record events by the system printer.
- C. System trouble signal initiation shall be by one or more of the following devices and actions:
  1. Open circuits, shorts, and grounds in designated circuits.
  2. Opening, tampering with, or removing alarm-initiating and supervisory signal-initiating devices.
- D. Remote Smoke-Detector Sensitivity Adjustment: Controls shall select specific addressable smoke detectors for adjustment, display their current status and sensitivity settings, and change those settings. Allow controls to be used to program repetitive, time-scheduled, and automated changes in sensitivity of specific detector groups. Record sensitivity adjustments and sensitivity-adjustment schedule changes in system memory, and print out the final adjusted values on system printer.

1.5 RELATED DOCUMENTS AND WORK

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- B. Related Sections include the following:
  - 1. Section 01 33 23 - Submittals: Procedures for submittals
  - 2. Section 09 91 00 - Painting: Painting for equipment and existing surfaces
  - 3. Section 26 0511 - Requirements for Electrical Installations: General electrical requirements for items which are common to other Division 16 sections
  - 4. Section 26 0533 - Raceways and Boxes for Electrical Systems: Conduits and boxes for cables/wiring
  - 5. Section 26 0521 - Low Voltage Electrical Power Conductors and Cables (600V and Below): Cables/wiring
- C. Applicable Publications
  - 1. The publications listed below (including amendments, addenda, revisions, supplements and errata) form a part of this specification to the extent referenced. The publications are referenced in text by the basic designation only.
  - 2. National Fire Protection Association (NFPA):
    - a. 70-2005 National Electrical Code (NEC).
    - b. 72-2002 National Fire Alarm Code.
    - c. 90A-2002 Installation of Air Conditioning and Ventilating Systems.
    - d. 101-2003 Life Safety Code
  - 3. Department of Veterans Affairs Fire Protection Design Manual (4th Edition).
  - 4. Underwriters Laboratories, Inc. (UL):
    - a. 2000-2000 Fire Protection Equipment Directory
  - 5. Factory Mutual Research Corp (FM): Approval Guide, 2005 Edition
  - 6. American National Standards Institute (ANSI):
    - a. S3.41-1996 Audible Emergency Evacuation Signal
  - 7. International Code Council, International Building Code (IBC) 2003 Edition

1.6 SUBMITTALS

- A. General Submittal Requirements:

1. Submit 4 copies and 1 reproducible in accordance with Section 01 3323 Submittals and Section 26 0511 Requirements for Electrical Installations.
  2. Submittals shall be approved by authorities having jurisdiction prior to submitting them to Engineer.
  3. Shop Drawings shall be prepared by persons with the following qualifications:
    - a. NICET-certified fire-alarm technician, Level III minimum.
- B. Product Data: For each type of product indicated.
- C. Shop Drawings:
1. Comply with recommendations in the "Documentation" Section of the "Fundamentals of Fire Alarm Systems" Chapter in NFPA 72.
  2. Floor plans: Provide locations of all devices (with device number at each addressable device corresponding to control unit programming), Only those devices connected and incorporated into the final system shall be on these floor plans. Do not show any removed devices on the floor plans. Show all interfaces for all fire safety functions.
  3. Include performance parameters and installation details for each detector, verifying that each detector is listed for complete range of air velocity, temperature, and humidity possible when air-handling system is operating.
- D. Certifications:
1. Together with the shop drawing submittal, submit the technician's NICET level III fire alarm certification. Include in the certification the names and addresses of the proposed supervisor of installation and the proposed performer of contract maintenance. Also include the name and title of the manufacturer's representative who makes the certification.
  2. Together with the shop drawing submittal, submit a certification from the manufacturer of each component (e.g., smoke detector) that the components being furnished are compatible with the control unit.
  3. Together with the shop drawing submittal, submit a certification from the major equipment manufacturer that the wiring and connection diagrams meet this specification, UL and NFPA 72 requirements.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: Personnel shall be trained and certified by manufacturer for installation of units required for this Project.
- B. Installer Qualifications: Installation shall be by personnel certified by NICET as fire-alarm Level III technician.
- C. Source Limitations for Fire-Alarm System and Components: Obtain fire-alarm system from single source from single manufacturer. Existing fire alarm system is Gamewell/FCI
- D. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- E. NFPA Certification: Obtain certification according to NFPA 72 by a UL-listed alarm company.

1.8 WARRANTY

- A. All work performed and all material and equipment furnished under this contract shall be free from defects and shall remain so for a period of five (5) years from the date of acceptance of the entire installation by the Contracting Officer.

1.9 GUARANTY PERIOD SERVICES

- A. Complete inspection, testing, maintenance and repair service for the fire alarm system shall be provided by a factory trained authorized representative of the manufacturer of the major equipment for a period of one year from the date of acceptance of the entire installation by the Contracting Officer.
- B. Contractor shall provide all necessary test equipment, parts and labor to perform required inspection, testing, maintenance and repair.
- C. All inspection, testing, maintenance and permanent records required by NFPA 72, and recommended by the equipment manufacturer shall be provided by the contractor. Work shall include operation of sprinkler system alarm and supervisory devices as well as all reused existing equipment connected to the fire alarm system. It shall include all interfaced equipment including but not limited to elevators, HVAC shutdown, and extinguishing systems.
- D. Maintenance and testing shall be performed in accordance with NFPA 72. A computerized preventive maintenance schedule shall be provided and shall describe the protocol for preventive maintenance of equipment.

The schedule shall include a systematic examination, adjustment and cleaning of all equipment.

- E. Non-included Work: Repair service shall not include the performance of any work due to improper use, accidents, or negligence for which the contractor is not responsible.
- F. Service and emergency personnel shall report to the Engineering Office or their authorized representative upon arrival at the hospital and again upon the completion of the required work. A copy of the work ticket containing a complete description of the work performed and parts replaced shall be provided to the VA Contracting Officer or his authorized representative.
- G. Emergency Service:
  - 1. Warranty Period Service: Service other than the preventative maintenance, inspection, and testing required by NFPA 72 shall be considered emergency call-back service and covered under the warranty of the installation during the first year of the warranty period, unless the required service is a result of abuse or misuse by the Government. Written notification shall not be required for emergency warranty period service and the contractor shall respond as outlined in the following sections on Normal and Overtime Emergency Call-Back Service. Warranty period service can be required during normal or overtime emergency call-back service time periods at the discretion of the Contracting Officer or his authorized representative.
  - 2. Normal and overtime emergency call-back service shall consist of an on-site response within two hours of notification of a system trouble.
  - 3. Normal emergency call-back service times are between the hours of 7:30 a.m. and 4:00 p.m., Monday through Friday, exclusive of federal holidays. Service performed during all other times shall be considered to be overtime emergency call-back service. The cost of all normal emergency call-back service for years 2 through 5 shall be included in the cost of this contract.
  - 4. Overtime emergency call-back service shall be provided for the system when requested by the Government. The cost of the first 40 man-hours per year of overtime call-back service during years 2 through 5 of this contract shall be provided under this contract. Payment for overtime emergency call-back service in excess of the 40 man hours per year requirement will be handled through separate purchase orders. The method of calculating overtime emergency call-back hours are based on actual time spent on site and does not include travel time.

- H. The contractor shall maintain a log at each fire alarm control unit. The log shall list the date and time of all examinations and trouble calls, condition of the system, and name of the technician. Each trouble call shall be fully described, including the nature of the trouble, necessary correction performed, and parts replaced.
- I. In the event that VA modifies the fire alarm system post-Acceptance but during the five year Guaranty Period Service period, Contractor shall be required to verify that the system, as newly modified or added, is consistent with the manufacturer's requirements; any verification performed will be equitably adjusted under the Changes clause. The post-Acceptance modification or addition to the fire alarm system shall not void the continuing requirements under this contract set forth in the Guarantee Period Service provision for the fire alarm system as modified or added. The contract will be equitably adjusted under the Changes clause for such additional performance.

#### 1.10 PROJECT CONDITIONS

- A. Interruption of Existing Fire-Alarm Service: Do not interrupt fire-alarm service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary guard service according to requirements indicated:
  - 1. Notify Owner/Owner's Representative no fewer than 5 working days in advance of proposed interruption of fire-alarm service.
  - 2. Do not proceed with interruption of fire-alarm service without Owner/Owner's Representative written permission.}}

#### 1.11 SOFTWARE SERVICE AGREEMENT

- A. FireNet Systems Inc. to modify existing software agreement to include modifications based on this projects scope of work.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Gamewell/FCI (No Substitutions)



## 2.2 EQUIPMENT AND MATERIALS, GENERAL

- A. All added equipment and components shall be new and the manufacturer's current model. All equipment shall be tested and listed by Underwriters Laboratories, Inc. or Factory Mutual Research Corporation for use as part of a fire alarm system. The authorized representative of the manufacturer of the major equipment shall certify that the installation complies with all manufacturer's requirements and that satisfactory total system operation has been achieved

## 2.3 CONDUIT, BOXES, AND WIRE

- A. Conduit shall be in accordance with Section 16111, CONDUIT SYSTEMS and as follows:
  - 1. All new conduits shall be installed in accordance with NFPA 70.
  - 2. Conduit fill shall not exceed 40 percent of interior cross sectional area.
  - 3. All new conduits shall be ¾-inch minimum.
- B. Wire:
  - 1. All existing wiring that is not reused shall be removed after new wiring installed in conduit or raceway and the new system is fully functional.
  - 2. Wiring shall be in accordance with NEC article 760, Section 26 0521 and as recommended by the manufacturer of the fire alarm system. All wires shall be color coded. Number and size of conductors shall be as recommended by the fire alarm system manufacturer, but not less than 18 AWG for initiating device circuits and 14 AWG for notification device circuits.
  - 3. Addressable circuits and wiring used for the multiplex communication loop shall be twisted and shielded unless specifically exempted by the fire alarm equipment manufacturer in writing.
- C. Terminal Boxes, Junction Boxes, and Cabinets:
  - 1. Shall be galvanized steel in accordance with UL requirements.
  - 2. All new boxes shall be sized and installed in accordance with NFPA 70.
  - 3. New and existing covers shall be repainted red in accordance with Section 09 9100 Painting and shall be identified with white markings as "FA" for junction boxes and as "FIRE ALARM SYSTEM" for cabinets and terminal boxes. Lettering shall be a minimum of ¾-inch high.

4. Terminal boxes and cabinets shall have a volume 50 percent greater than required by the NFPA 70. Minimum sized wire shall be considered as 14 AWG for calculation purposes.
5. Terminal boxes and cabinets shall have identified pressure type terminal strips and shall be located at the base of each riser. Terminal strips shall be labeled as specified or as approved by the COTR.

#### 2.4 FIRE ALARM CONTROL UNIT (EXISTING)

#### 2.5 STANDBY POWER SUPPLY (EXISTING)

#### 2.6 ALARM INITIATING DEVICES

##### A. System Smoke Detectors

1. Duct Smoke Detectors: Photoelectric type complying with UL 268A.
  - a. Detector address shall be accessible from fire-alarm control unit and shall be able to identify the detector's location within the system and its sensitivity setting.
  - b. An operator at fire-alarm control unit, having the designated access level, shall be able to manually access the following for each detector:
    - 1) Primary status.
    - 2) Device type.
    - 3) Present average value.
    - 4) Present sensitivity selected.
    - 5) Sensor range (normal, dirty, etc.).
  - c. Weatherproof Duct Housing Enclosure: NEMA 250, Type 4X; NRTL listed for use with the supplied detector.
  - d. Each sensor shall have multiple levels of detection sensitivity.
  - e. Sampling Tubes: Design and dimensions as recommended by manufacturer for specific duct size, air velocity, and installation conditions where applied.
  - f. Relay Fan Shutdown: Provide quantity as required, rated to interrupt fan motor-control circuit. Provide all cabling/terminations for shutdown of unit(s).

## PART 3 - EXECUTION

### 3.1 EQUIPMENT INSTALLATION

- A. Installation shall be in accordance with NFPA 70, 72, 90A, and 101 and the VA FPDM as shown on the drawings, and as recommended by the major equipment manufacturer. Fire alarm wiring shall be installed in conduit. All conduit and wire shall be installed in accordance with Section 16111 "CONDUIT SYSTEMS," Section 16127 "CABLES, LOW VOLTAGE," and all penetrations of smoke and fire barriers shall be protected as required by Section 07270 "FIRESTOPPING SYSTEMS."
- B. All new conduits, junction boxes, conduit supports and hangers shall be concealed in finished areas and may be exposed in unfinished areas. All existing accessible fire alarm conduit not reused shall be abandoned in place and labeled "SPARE".
- C. All fire detection and alarm system devices may be surface mounted when located in unfinished areas.
- D. Duct Smoke Detectors: Comply with NFPA 72 and NFPA 90A. Install sampling tubes so they extend the full width of duct.

### 3.2 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Division 26 Section Requirements for Electrical Installations.
- B. Install framed instructions in a location visible from fire-alarm control unit.

### 3.3 GROUNDING

- A. Ground fire-alarm control unit and associated circuits; comply with IEEE 1100. Install a ground wire from main service ground to fire-alarm control unit.

### 3.4 TESTS

- A. Provide the service of a NICET level III, competent, factory-trained engineer or technician authorized by the manufacturer of the fire alarm equipment to technically supervise and participate during all of the adjustments and tests for the system. Make all adjustments and tests in the presence of the COTR.

B. When the systems have been completed and prior to the scheduling of the final inspection, furnish testing equipment and perform the following tests in the presence of the COTR. When any defects are detected, make repairs or install replacement components, and repeat the tests until such time that the complete fire alarm systems meet all contract requirements. After the system has passed the initial test and been approved by the COTR, the contractor may request a final inspection.

1. Visual Inspection: Conduct visual inspection prior to testing.
  - a. Inspection shall be based on completed Record Drawings and system documentation that is required by NFPA 72 in its "Completion Documents, Preparation" Table in the "Documentation" Section of the "Fundamentals of Fire Alarm Systems" Chapter.
  - b. Comply with "Visual Inspection Frequencies" Table in the "Inspection" Section of the "Inspection, Testing and Maintenance" Chapter in NFPA 72; retain the "Initial/Reacceptance" column and list only the installed components.
2. System Testing: Comply with "Test Methods" Table in the "Testing" Section of the "Inspection, Testing and Maintenance" Chapter in NFPA 72.
3. Before energizing the cables and wires, check for correct connections and test for short circuits, ground faults, continuity, and insulation.
4. Test the insulation on all installed cable and wiring by standard methods as recommended by the equipment manufacturer.
5. Open each new alarm initiating and notification circuit to see if trouble signal actuates.
6. Test new audible appliances for the public operating mode according to manufacturer's written instructions. Perform the test using a portable sound-level meter complying with Type 2 requirements in ANSI S1.4.
7. Test new audible appliances for the private operating mode according to manufacturer's written instructions.
8. Test new visible appliances for the public operating mode according to manufacturer's written instructions.
9. Factory-authorized service representative shall prepare the "Fire Alarm System Record of Completion" in the "Documentation" Section of the "Fundamentals of Fire Alarm Systems" Chapter in NFPA 72 and the "Inspection and Testing Form" in the "Records" Section of the "Inspection, Testing and Maintenance" Chapter in NFPA 72.

### 3.5 FINAL INSPECTION AND ACCEPTANCE

- A. At the final inspection a factory trained representative of the manufacturer of the major equipment shall repeat the tests in Article 3.5 TESTS and those required by NFPA 72. In addition the representative shall demonstrate that the systems function properly in every respect. The demonstration shall be made in the presence of a VA representative.

- - END OF SECTION - -