

## Scope of Work

**PROJECT NO. N/A, AHU #4 Exhaust Interlock.** This Project will interlock the exhaust fan serving Sterilized Processing Supply (SPS) with the Air Handling Unit (AHU #4) serving SPS at Bldg. No. 200 at the Northport VA Medical Center, 79 Middleville Road, Northport, NY 11768. The Contractor shall furnish labor and materials and perform work for this project as required. Work includes HVAC controls and electrical work and certain other items. Work is to be done during normal business hours with the exception of tie-in to existing BMS system which is to be done during off hours.

Work will include performing all parts and labor as necessary in order to have the exhaust fan serving SPS be interlocked with the air handling unit serving SPS. The work will include, but not necessarily be limited to; roughing in electrical control wiring in conduit, updating existing Siemens controls as necessary, programming, As-Built drawings and providing training (during multiple shifts if necessary) to VA AC shop / Climate Control staff. The exhaust fan motor starter is located in the Penthouse Mechanical Room, Bldg. No. 200. There is an existing control panel located in the Penthouse as well as the existing control panel serving AHU-4 located in the Sub-basement, MER #2. The existing control system serving AHU #4 is by Siemens. The Environmental Control Center (ECC) with display is located in the Climate Control Room in the Sub-basement. The display is to provide both a visual and audible notification of loss of power by either the air handler or the exhaust fan.

The contractor is responsible for removing all waste generated by this project from the property and dispensing it in an approved manner as required by State and Local Codes.

All workers shall have 10 hour OSHA Construction Safety Certification. The project supervisor shall be the competent person and have 30 hour OSHA Construction Safety Certification. Contractor to provide OSHA certifications to VA prior with ID badge request.

Infection Control permits may be issued for certain aspects of the work. The contractor is to comply with those requirements.

Contractor may be required to obtain Hot Work Permits and Smoke barrier penetration permits for certain aspects of the work as necessary.

### Security Requirements:

- a. Prior to start of work, the Contractor shall submit a request for photo ID badges to the Resident Engineer for all employees of the Contractor and subcontractors requiring access to the project site. Such request shall include the following information for each applicant: legal name, date of birth, social security number, home address, job title, work phone number, and name of firm or company.

## Scope of Work

- b. The issuance of photo ID badges will be arranged through VA Police. All requests must be submitted in advance to allow for processing before the start of work.

All work shall be covered by a warranty period of one (1) year from date of acceptance. The warranty shall include parts and labor.

The contract completion time is 15 calendar days from receipt of Notice to Proceed.

This contract does not involve VA Patient Identifiable or Health information and contractor personnel do not require access to VA systems. Information made available to the contractor or subcontractor by VA for the performance or administration of this contract or information developed by the contractor/subcontractor in performance or administration of the contract shall be used only for those purposes and shall not be used in any other way without the prior written agreement of VA. The contractor/subcontractor must store, transport, or transmit VA sensitive information in an encrypted form, using VA-approved encryption tools that are, at a minimum, FIPS 140-2 validated.