

**SECTION 00 11 21
REQUEST FOR PROPOSAL TO DESIGN-BUILD**

A. PART I - GENERAL

A1. Scope of Contract

Provide all labor, materials, tools equipment, design and construction services necessary to complete the design and subsequent construction of the project described herein and other specific tasks as further defined by this request for proposal (RFP).

A. Project Number: 509-CSI-501

B. Project Title: Cath Lab HVAC

C. Project Location: Alvin C. York DD 915 15th Street, Augusta GA 30904

D. Scope of Work:

This project provides a new HVAC system for the New Cath Lab Room 3C-143 and Cath lab suites renovation project at the Charlie Norwood VAMC. The new system will be in conformance with the Cardiovascular Laboratory Service Design Guide criteria dated November 29, 2011 and the Cardiovascular Laboratory Service Design Guide criteria with a revised date of April 15, 2016 or newest change. AHU will be medical grade.

E. Scope of work common to all tasks is to:

1. Where equipment, temporary installations, ingress/egress restrictions or any other consideration is necessary for infection control purposes such requirements and associated drawings and specifications shall be provided.
2. Provide shop drawings and demolition/installation and operating instructions as appropriate
3. Dispose of old removed parts and components after checking with VA staff if any should be retained by VA as replacement parts.
4. Clean up, return affected work areas to original condition.
5. Provide VA staff training, equipment manuals and warranty information for all equipment installed.
6. Provide ease of maintenance access (ladders, rail, or lifting device).

F. General Drawing Submission Requirements: Shop Drawing Submission Requirements are available on the internet at the following address: <http://www.cfm.va.gov/>. As-built drawings for the Medical Center are available. (note: these drawings are not completely accurate. A-E shall verify existing conditions.) All drawings will be prepared with the VA Standard Title Block and Border. All drawings shall be produced using AutoCAD 2005 or newer. Each individual file on a DVD shall be named by numbers corresponding to the construction documents (i.e. the specs

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

shall be named 00 11 22, 33 44 55, etc. and the drawings shall be E1, E2, etc.) and the final AutoCAD/specifications files shall be exactly as submitted in the final submission.

G. Incorporated References: The following Department of Veterans Affairs, Office of Construction and Facilities Management, information is incorporated within the Scope of Work by reference, and can be found on the VA web site at <http://www.cfm.va.gov/> Master Specifications; Design Guides; Design Manuals; Standard Details; Design Alerts; and Quality Alerts.

A2. Definitions

1. Design-Build (D-B) as defined by the Department of Veterans Affairs (VA) is the procurement by the Government, under one contract, with one firm or Joint Venture (J/V) for both design and construction services for a specific project.
2. Contracting Officer (CO): A person with the authority to enter into, administer, and/or terminate contracts and make related determinations and findings. The term includes certain authorized representatives of the contracting officer acting within the limits of their authority as delegated by the contracting officer. "Administrative contracting officer (ACO)" refers to a contracting officer who is administering contracts. "Termination contracting officer (TCO)" refers to a contracting officer who is settling terminated contracts. A single contracting officer may be responsible for duties in any or all of these areas.
3. Contracting Officer's Representative (COR): The Contracting Officer's written designation of a representative responsible for administering contracts and technical review under the immediate direction of the Contracting Officer. For the purposes of this contract the term "COR" will be used herein.
4. Technical Monitor (TM): This term, as used herein, refers to the person(s) assisting the COR in administering contracts under the immediate direction of the Contracting Officer.
5. Design-Build Contract: This term, as used herein, refers to the Contract(s) to perform the design and construction of the project.
6. Contractor: This term, as used herein, refers to the contractor under this contract or the D-B team. The contractor or D-B team is solely responsible for the management (planning, supervision, and contract coordination), design, and (professional) services and installation (including all labor, equipment, materials, tools, and inspections) to meet the requirements of this contract.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

7. Architect-Engineer (A-E): This term, as used herein, refers to the A-E firm(s) that is a part of the D-B team, also referred to as D-B A-E.
8. Project Management: The contractor shall provide an individual in the capacity of a contractor project manager. The contractor project manager shall have legal (on-site signature) authority to represent the Contractor. The Project Manager shall be the initial point of contact for coordinating with the VA.

A3. Pre-Proposal Site Visit (This section will be removed after award.)

The VA will schedule the pre-proposal site visit for Phase II of the Design-Build process.

Location: Charlie Norwood VAMC, Augusta GA, 30904

Date / Time: TBD

All Offerors, consultants, subcontractors, manufacturers and suppliers are invited to attend. The following agenda is furnished for this meeting:

1. Open meeting & Introductions;
2. Review of project and Design-Build method for construction contracting;
3. Specifications;
4. General requirements, Solicitation Documents and Offer Submission Procedure;
6. Questions and answers;
7. Close; and
8. Site walk through – attendance is optional.

*Please note that attendance for the pre-proposal conference and / or the site walkthrough is voluntary; however, an RSVP must be sent to Lauren Brauer, Lauren.Brauer@va.gov, no later than the date indicated on solicitation, if your company plans to attend. Please include the project title in the subject line of the email, as well as the names of the attendees (no more than three per Offeror).

A4. Permit Requirements

The D-B Contractor is responsible for obtaining all permits and approvals necessary to complete the project, prior to starting Construction.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

A5. Selection Criteria (This section will be removed after award.)

- A. In accordance with FAR part 15 The Government intends to award a contract resulting from this solicitation to the responsible Offeror whose proposal represents the best value after evaluation in accordance with the factors in the Two-Phase Design-Build solicitation. Responsibility determination will be made in accordance with **FAR 9.1, Responsible Prospective Contractors.**

- B. Evaluations: All Phase I and Phase II proposals shall be subject to evaluation by a team of Government personnel. In Phase I of the Two-Phase Design-Build process, Offerors will submit a Phase I proposal in accordance with the three (3) evaluation factors listed in C.3. Upon receipt of the Phase I proposals, the VA team will evaluate and determine the highest qualified Offerors based on their Phase I proposal submissions. The Phase I proposals will only be evaluated on the three (3) evaluation factors listed. A maximum of four (4) Offerors will be selected to provide a proposal for Phase II. The Phase II proposals will consist of both technical and price factors, which are listed in D.4. The Government reserves the right to award without discussions based on the initial evaluation of the Phase II proposals. Using the tradeoff process under best value, it may be in the Government's best interest to consider award to other than the lowest price Offeror or other than the highest Technically rated Offeror in Phase II. All Phase II Technical evaluation factors, when combined, are approximately equal to price.

B. PART II - RESPONSIBILITIES

B1. VA Team

- A. The VA team is comprised of the VHA-PCAC Contracting Officer, the COR who will be located at the construction site and VA Medical Center staff.

B2. Use of Advisors

- A. Contractors are advised that VA contractor personnel may assist the Government during the Government's evaluation of Proposals. The persons shall be authorized access to only those portions of the proposal and discussions that are necessary to enable them to provide specific technical advice on specialized matters or on particular problems. These individuals will be required to protect the confidentiality of any specifically identified trade secrets and/or privileged or confidential commercial or financial information obtained as a result of their participation in this evaluation. They shall be expressly prohibited from scoring, ranking or recommending the selection of a Vendor.

B3. Design-Build Team:

- A. The D-B team includes all J/V partners, consultants and sub contractors to the one firm. The D-B team shall provide Architectural and Engineering disciplines for the preparation of construction documents, and construction contractor capabilities for construction of the project.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

- B. If the D-B Team A-E and contractor are a J/V (not one and the same firm) engineering and other technical consultants shall be subcontractors of the J/V Architect - not the Design-Build construction contractor or sub contractors. If the D-B Team A-E and contractor are one and the same firm (not a J/V) those consultants shall be subcontractors of D-B firm not the construction subcontractors.
- C. The RFP documents are intended to define existing conditions, certain required items, and design parameters to be included in the project. It is the contractor's responsibility to visit the site or ascertain the conditions at each site. In addition, the Contractor acknowledges that it has taken steps reasonably necessary to ascertain the nature and location of the work, and that it has investigated and satisfied itself as to the general and local conditions which can affect the work or its cost, the existing conditions, certain required items, and design parameters to be included in the project. It is the D-B Team's responsibility to complete the documents and construction in a manner consistent with the intent of the RFP documents within the required period of performance.

C. PART III - PROPOSAL REQUIREMENTS (This section will be removed after award.)

C1. General

Phase I

- A. Phase I proposals shall be based on the solicitation documents issued for RFP Solicitation Number 36E77618R0097. Phase I proposals will be in the format stipulated elsewhere in Section "C2. Phase I Proposal Format".
- B. Phase I proposals shall be received on or before the date listed in Block 13a of the SF 1442. There will be no public opening of the proposals.
- C. Phase I proposal submission
 1. Submit via email to: Lauren.Brauer@va.gov
 2. Emails are limited to five (5) MB.
 3. Phase I proposals will only be accepted via email.

C2. Phase I Proposal Format

- A. The Offeror shall submit the Phase I proposal in one (1) PDF document. The proposal shall be labeled with the Offeror's organization, business address and VA solicitation number. The Offeror shall not include any price or price related material in the Phase I proposal.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

- B. The Offeror shall submit the Phase I proposal in electronic format only. Include page numbers and the company name in the header or footer of each page.
- C. The Offer, including title page, detailed table of contents, preface, for the Phase I proposal shall not exceed a total of 25 (twenty-five) pages in Microsoft Arial size 12 font. Use graphic presentations where such use will contribute to the compactness and clarity of the proposal.
- D. A page is defined as each face of an 8.5 X 11 inch sheet of paper containing information. All information (except for document numbers, page numbers, etc.) shall be provided in an image area of 7 X 9 inches. The background color of each page of the submission shall be white or ivory stock only. Excess pages will not be evaluated. Text lines will be single-spaced. A smaller font size for any graphics presented in a proposal is permitted as long as the information is legible to the human eye. Fonts other than Arial are permissible in the presentation of graphic material only.

C3. Phase I Proposal Evaluation Factors

- A. The Phase I proposal shall address the following evaluation factors. The factors are listed in descending priority of importance.

1. Factor 1, Experience

Provide a minimum of one (1) and a maximum of three (3) projects completed within the last five (5) years in which the Offeror's proposed design-build team has worked together on previous design-build contracts similar in size, complexity and scope to this project. projects must demonstrate an offeror's design build experience as a prime construction contractor directly responsible to the owner and managing multiple subcontractors. For purposes of this evaluation, a relevant project is further defined as "as design build completed in a clinical, hospital or other medical related use space similar in size and scope to this project." Project(s) shall have a minimum value of \$500,000 and be 90% completed.

Projects submitted for the Offeror shall be completed within the past five (5) years of the date of issuance of this RFP. A project is defined as a design build project performed under a single task order or contract. For multiple award and indefinite delivery/indefinite quantity type contracts, the contract as a whole shall not be submitted as a project; rather Offerors shall submit the work performed under a task order as a project. If the Offeror is a Joint Venture (JV), relevant project experience should be submitted for projects completed by the Joint Venture entity. If the Joint Venture does not have shared experience, projects shall be submitted for each Joint Venture partner. Offerors who fail to submit experience for all Joint

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

Venture partners may be rated lower. The Offeror's submission should include at a minimum:

- Provide the Project Title and Description, Project Location (Physical Address); Contract Type (Example: Design-Build, Design Bid Build).
- Provide the project owner name and telephone number of the owner's contact person.
- Provide a brief description of the scope of work.
- Provide project prime contractor and major subcontractors.
- Provide project statistics including start and completion dates (original vs actual) and project cost (original vs actual). If original vs actual completion dates and project cost differ, please explain as to why they differ.

2. Factor 2, Technical Approach

Provide a brief narrative (page limitation: three pages for brief narrative) describing the Offeror's method to manage the project to achieve design and construction design objectives as described in the solicitation. If the page limits are exceeded, the pages in excess of the limit will not be read or considered. Include at minimum all aspects covered in the scope of work. The following shall be included in the narrative:

1. Design Approach: Describe the techniques and methods for an efficient, effective design and;
2. Construction Approach: Describe the techniques and methods for this construction project to include coordination with the design packages, projected timelines and coordination of work.

3. Factor 3, Past Performance

Each proposal shall provide current and relevant information regarding an Offeror's actions under previously awarded contracts referenced under Factor 1, Experience. If a completed past performance evaluation is available in the Past Performance Information Retrieval System (PPIRS), it shall be submitted with the proposal for each project referenced in Factor 1, Experience. If there is not a completed past performance evaluation available in PPIRS, then the Offeror shall submit a Past Performance Questionnaire (PPQ) (reference Past Performance Questionnaire) for each project referenced in Factor 1, Experience. The Offeror shall notify their client that they PPQ shall be submitted via email to the Government's point of contact Lauren.Brauer@va.gov. If the Offeror is unable to obtain a completed PPQ from a client for a project(s) before proposal closing date, the Offeror shall complete and submit with the proposal the first page of the PPQ, which will provide contract and client information for the respective project(s). The Government may make reasonable attempts to contact the

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

client noted for that project(s) to obtain the PPQ information. However, Offerors should follow-up with clients/references to help ensure timely submittal of questionnaires.

C4. Evaluation of Offers (Phase I)

The Phase I evaluations will be conducted in accordance with the Two-Phase Design-Build Evaluation process and the methodologies provided below. The factors are listed in descending order of importance.

Factor 1, Experience

Will be evaluated on relevant and recent experience of design-build contracts and/ or contracts of comparable size, complexity and scope within the last five (5) years.

Factor, 2 Technical Approach

Will be evaluated based on the Offeror's proposed technical approach for this design-build project as defined in the solicitation submittal requirements. The assessment of the Offeror's method to manage the project shall be used as a means of evaluating the Offeror's ability to successfully meet the requirements of the solicitation.

Factor 3, Past Performance

Will be evaluated on the quality of the Offeror's past performance within the last five (5) years with respect to the construction projects listed in Evaluation Factor 1, Experience. This includes, timeliness of contract completion, adherence to contract schedules and timely submission of data deliverables; the contractor's ability to comply with the terms and conditions of the contract; the overall quality of the work performed on the contract; the Offeror's managerial performance' and whether or not the reference would enter into a contract with the contractor again. Contractors without relevant past performance or for whom past performance information is not available, will be rated neither favorably nor unfavorably on past performance. In the event that the prime contractor does not have relevant past performance, surveys submitted for key personnel will be evaluated. In accordance with VA Information Letter (IL) 049-03-9, past performance evaluations may also be conducted using information obtained from CPS or PPIRS and any other sources deemed appropriate by the CO. Other sources may include, but are not limited to, inquiries of owner representative(s), Federal Awardee Performance and Integrity Information System (FAPIIS), Electronic Subcontract Reporting System (eSRS), and any other known sources not provided by the Offeror.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

D. PART IV – PHASE II PROPOSAL REQUIREMENTS (This section will be removed after award.)

D1. PHASE II General (This section will be removed after award.)

- A. Phase II proposals shall be based on solicitation documents issued for RFP Solicitation Number 36E77618R0097 and the instructions provided by the Contracting Officer in the Phase II Notice of Offerors that they were selected as one of the most qualified Offerors in Phase I. Proposals will be in the format stipulated in Section D2. Phase II Proposal Format.
- B. Proposals shall be received on or before the date specified in the Phase II Notice of Offerors.
- C. Submit Phase II proposals via email to:
 - 1. Lauren.Brauer@va.gov
 - 2. Emails are limited to five (5) MB.
 - 3. Phase II proposals will only be accepted via email.
- D. Submit the original Bid Bond by mail to:
 - 1. US Postal Service Deliveries:

Lauren Brauer
Program Contracting Activity Central (VHA-PCAC)
6150 Oaktree Blvd, Suite 300
Independence, OH 44131

- 2. Commercial Delivery Services / Hand Carry (Monday- Friday, 8:00 AM to 4:30 PM (EDT))

Lauren Brauer
Program Contracting Activity Central (VHA-PCAC)
6150 Oaktree Blvd, Suite 300
Independence, OH 44131

Failure to furnish the required bid guarantee in the proper form and amount, by the time specified in Block 13 of the SF 1442, may result in rejection of the Phase II proposal. SEE FAR Provision 52.228-1, Bid Guarantee, of this solicitation.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

D2. PHASE II Proposal Format (This section will be removed after award.)

- A. Technical and Price sections of the Offerors Phase II proposals will be evaluated independently; therefore, the Offeror shall submit the Phase II proposal in two (2) Volumes (Volume I: Technical and Volume II: Price). In order that the Volume I Technical may be evaluated strictly on the merit of the material submitted, the contractor shall include **NO** price information in Volume I. Offeror shall separately bind Volumes I and II. Both Technical and Price volumes, therefore, must be labeled with the Offeror's organization, business address, and VA Solicitation Number.
- B. The Offeror shall submit Volumes I and II in electronic format only. No hard copies will be accepted. Include page numbers and the company name in the header or footer of each page.
- C. The Offer, including title page, detailed table of contents, preface, for Volume I Technical shall not exceed a total of 30 (Thirty) pages in Microsoft Arial size 12 font. Volume II Price Proposal shall not exceed a total of 20 (Twenty) pages in Arial size 12 font. Use graphic presentations where such use will contribute to the compactness and clarity of the proposal. The SF 1442, Representations and Certifications and acknowledged amendments shall all be part of Volume II and will not count against the page limitations. The J/V documentation, if applicable, will not be counted in the page limit.
- D. A page is defined as each face of an 8.5 X 11 inch sheet of paper containing information. All information (except for document numbers, page numbers, etc.) shall be provided in an image area of 7 X 9 inches. The background color of each page of the submission shall be white or ivory stock only. Excess pages will not be evaluated. Text lines will be single-spaced. A smaller font size for any graphics presented in a proposal is permitted as long as the information is legible to the human eye. Fonts other than Arial are permissible in the presentation of graphic material only.
- E. Offeror shall include all required Representations and Certifications; and acknowledge receiving amendments by filling out section 19 of the SF 1442 and returning a signed copy of the amendment(s) with the offer.
- F. Offeror shall include their Safety or Environmental Violations and Experience Modification Rating Information as part of Volume II, including filling out the Contractor Safety and Environmental Record Evaluation Form Attachment of the solicitation. It will not be evaluated as part of Volume II Price, but will be used as part of the Responsibility Determination. It will also not count against the page limitations for Volume II.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

1. All Offerors shall submit information pertaining to their past Safety and Environmental record. The information must contain a certification that the Offeror has no more than three (3) serious, or one (1) repeat or one (1) willful OSHA or any EPA violation(s) in the past three years. If such certification cannot be made, an Offeror shall explain why and submit as much information as possible regarding the circumstances of its past safety and environmental record, including the number of EPA violations and/or the number of serious, repeat, and/or willful OSHA violations, along with a detailed description of those violations.
2. All Offerors shall submit information regarding their current Experience Modification Rate (EMR). This information shall be obtained from the Offeror's insurance carrier and be furnished on the insurance carrier's letterhead. If an Offeror's EMR is above 1.0, Offeror must submit a written explanation of the EMR from its insurance carrier furnished on the insurance carrier's letterhead, describing the reasons for the elevated EMR and the anticipated date the EMR may be reduced to 1.0 or below.
3. Self-insured contractors or other contractors that cannot provide their EMR rating on insurance letterhead must obtain a rating from the National Council on Compensation Insurance, Inc. (NCCI) by completing/submitting form ERM-6 and providing the rating on letterhead from NCCI. Note: Self-insured contractors or other contractors that cannot provide EMR rating on insurance letterhead from the states or territories of CA, DE, MI, NJ, ND, OH, PA, WA, WY, and PR shall obtain their EMR rating from their state run worker's compensation insurance rating bureau.
4. If the NCCI cannot issue an EMR because the Offeror lacks insurance history, Offeror shall submit a letter indicating so from its insurance carrier furnished on the insurance carrier's letterhead, and include a letter from the NCCI indicating that it has assigned Offeror a Unity Rating of 1.0.
5. The above information, along with other information obtained from Government systems, such as the OSHA and EPA online inspection history databases, will be used to make an initial Determination of Responsibility. *The above information is not required for subcontractors.
6. Failure to provide the completed Contractor Safety and Environmental Record Evaluation Form Attachment of the solicitation containing the above information, may result in a determination that an Offeror is not responsible and therefore ineligible for award.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

D3. Final Proposal Revisions (FAR 52.215-1)

- A. If determined to be necessary, Phase II proposal revisions will be requested from the Phase II proposals received. The CO will identify those Offerors, whose Phase II proposals are within the competitive range, considering the selection criteria identified in this section. Negotiations may be conducted with those Offerors falling within the competitive range, after which Phase II proposal revisions will be requested. Sealed Phase II proposal revisions will be submitted as per Part III.D1.D, above, except as noted below and will be due at a time and place to be determined.
- B. Offerors submitting Phase II proposal revisions will not be requested to re-submit any documents which are unchanged from their initial Phase II proposals. They should provide necessary changes to individual paragraphs, as briefly as possible, together with a table of contents, which clarifies where within the initial Phase II proposal the additional information or changed documents would be placed. Phase II proposal revisions shall include a completed **SF 1442** that acknowledges receiving all amendments, by number. A new bid bond shall be submitted only if the final Phase II proposal revisions Offeror's price proposal is greater than its initial price proposal.

D4. PHASE II - Technical Proposal Requirements (Volume I)

1. The Phase II proposal shall address the following evaluation factors. All evaluation factors other than price, when combined, are approximately equal to price. The factors are listed in descending priority of importance.
 1. **Volume I, Factor 1, Technical Solution:** Based on the solicitation documents, site visit, and the Offeror's Phase I Technical Approach, provide a detailed narrative describing the Offeror's technical solution to the project to achieve design and construction design objectives as described in the solicitation. If the page limits are exceeded, the pages in excess of the limit will not be read or considered.

The Offeror's narratives shall include, at minimum, the following technical areas:

- Phasing
- Infection Control
- Interim Life Safety Measures
- Structural
- Mechanical
- Electrical
- Plumbing

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

The Offeror shall address areas of concern and describe how they will minimize risk in conjunction with the identified areas of concern. The narrative shall indicate that the Design-Build team understands the complexities of high tech equipment site preparation and address how their approach offers constructability advantages in an operational hospital setting.

2. **Volume I, Factor 2, Draft Project Schedule:** The firm shall demonstrate their understanding of Attachment 5 Project Schedule Specification by submitting a draft project schedule for design and construction of the Cath Lab HVAC that adheres to the requirements outlined in Attachment 5 Project Schedule Specification.
3. **Volume I, Factor 3, Key Personnel:** The Offeror shall provide a resume for each of the following key personnel members to include: Overall Project Manager, Design Project Manager, Construction Project Manager, Project Site Superintendent, A-E Field Representative and all of the identified Major Subcontractors. (It is recognized that not all subcontractors may be identified at the time of proposal submission.) For each resume, include name of company, name of individual, relevant listing of experience, qualifications for each person such as specialized training, education, experience. Please delineate approximate % of work the prime contractor will perform on this job and the approximate % of work the subcontractors (collectively) will perform on this job. Also, clearly describe the prime responsible firm (or firms if a J/V) and individuals as well as the roles and responsibilities of individuals proposed as consultants and sub-contractors.

D5. PHASE II Price Proposal Requirements (Volume II)

- A. Carefully follow "Instructions, Conditions, and Notices to Offerors". **Standard form (SF) 1442 Solicitation, Offer and Award (Construction, Alteration, or Repair) and the pricing schedule located on page 6** when submitting price offers. Submit a bid guarantee as stipulated in the Section "Instructions, Conditions, and Notices to Offerors"
- B. The prices shall be Firm Fixed Price. The Offeror shall take care not to include remarks that take exception to the Government's SOW/Specifications or pricing requirements or otherwise preclude the Government from evaluating the offer or render the offer as non-responsive or unacceptable.
- C. If the Offeror communicates in its proposal any qualifications, exceptions, exclusions, or conditions to the proposed prices not provided for in the Offerors proposal documents, the Contracting Officer may reject the proposal and exclude the Offeror from further discussions.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

D6. Evaluation of Offers

The Phase II evaluations will be conducted in accordance with Two-Phase Design-Build Evaluation process and the methodologies provided below. All evaluation factors other than price, when combined are approximately equal to price. The factors are listed in descending order of importance.

- 1. Volume I, Factor 1, Technical Solution:** The VA will evaluate and use as an aid to help determine that the Offeror understands the complexity and risks of performing high tech equipment site preparation and can perform all of the required elements safely and limit impacts on facility operations. The Technical Solution will be evaluated for inclusion of the technical areas listed in the criteria. The VA will evaluate Offeror's specific detail in each of the technical areas in regards to design and constructability of design. The Offeror's narrative should provide enough detail to demonstrate that the scope and complexity of the project requirements are understood and will be successfully completed.
- 2. Volume I, Factor 2, Draft Project Schedule:** The VA will evaluate and use as an aid to help determine that the Offeror understands and can perform all of the required elements to design and construct the Cath Lab HVAC in the time frame specified with limited impact, to the greatest extent possible, to the Medical Center. (The draft schedule submitted with the offer should not be construed as the agreed upon schedule as per FAR 52.236-15, the contractor shall, within 21 Calendar days after receiving the Notice to Proceed, submit an interim project schedule which will supersede the draft project schedule. The interim project schedule will be subject to VA approval and must show the project being accomplished within the time frame specified on the SF 1442.)
- 3. Volume I, Factor 3, Key Personnel:** The VA will evaluate the relevant management, technical personnel and subcontractor capabilities and qualifications of the team to provide the required planning, implementation and completion of the project. The VA will also evaluate how the Offeror organized personnel for this project, and the lines of authority between the construction firm, design firm, and key subcontractors.
- 4. Volume II, Price:** The Contracting Officer will evaluate Offers in accordance with the process identified in the Price Schedule. The total evaluated price will be determined by the Offeror's price for CLIN 0001. The VA reserves the right to award to a higher priced Offeror in accordance with the stated evaluation criteria. The VA also reserves the right to award to a lower priced, lower rated Offeror if it's in the interest of the VA.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

E. PART V - POST AWARD REQUIREMENTS

E1. Construction Document Preparation:

A. Design Review Submissions:

1. The Design-Build Team A-E (D-B A-E) shall prepare and submit complete construction documents for review and approval by the VA in accordance with standard professional practice, the Department of Veterans Affairs RFP (VA RFP), and prevailing codes.
2. The documents may be divided into multiple review submission packages. The VA will review as many as seven (7) package submissions (examples: demolition, civil, architectural, structural, mechanical, Electrical, plumbing etc.) to facilitate the start of construction.
3. All submission packages will be reviewed at (15%)(30%)(60%) and (95%) completion stages. The (95%) review submission packages will incorporate the final review comments from all previous reviews. If any package is not complete for the required stage a post review may be required the cost of which will be borne by the D-B Team.
4. Each review submission package shall include 3 hard copy sets and 2 set on CD-ROM. The package will include an index of drawings (by sheet number and title) and specifications (by section number and title) submitted. The packages will be distributed to the VA Medical Center, RFP A-E, VA COR and others as determined to be appropriate by the VA.

B. Design Review Meetings:

1. A review meeting to resolve design issues will be held for each design review package submitted. The meeting will include discussion of VA comments on functional relationships and technical peer review comments (by others).
2. Participants will include RFP A-E, VA Staff and D-B team members as appropriate for the specific package to be reviewed and others. The D-B team members will each allow for (1) full day for each discipline/package design review meeting. D-B team management will be present at each review meeting.
3. The D-B team shall allow a minimum of ten (10) working days for each review cycle. A cycle includes:
 - a. The VA's receipt of the design review submission package.
 - b. The review meeting.
 - c. D-B teams receipt of comments from the VA, either electronically, by fax, or by hard copy delivery.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

4. Coordination of the review meeting schedules will be the responsibility of the VA COR (for the VA and RFP AE) and the D-B Team Project Manager (for the D-B Team). See section I. Quality Assurance/Quality Control.

C. Electronic Media:

1. Design review submission drawings and final Construction Document submission drawings will be executed in electronic format AutoCAD version 2016.
2. The drawings included in the VA RFP will be available to the D-B team in electronic format in AutoCAD version 2016 for use in preparing the construction drawings. Since data stored on electronic media can deteriorate undetected or be modified without the RFP Architect/Engineer's knowledge, the CADD drawing files are provided without warranty or obligation on the part of the RFP Architect/Engineer as to accuracy or information contained in the files. The user shall independently verify all information in the files. Any user shall agree to indemnify and hold the RFP Architect Engineer harmless from any and all claims, damages, losses, and expenses including, but not limited to, attorney's fee arising out of the use of the CADD drawing files.
3. Design review submission specifications and other 8 ½ by 11 formatted material and final Construction Document submission specifications and other 8 ½ by 11 formatted material will be executed in electronic format Microsoft Office 2016, Word 2016
4. The specifications included in the VA RFP shall be available to the D-B team in electronic format in Microsoft Office 2016, Word 2016, for use in preparing the construction specifications. Since data stored on electronic media can deteriorate undetected or be modified without the RFP Architect/Engineer's knowledge, the CADD version 2016 drawing files are provided without warranty or obligation on the part of the RFP Architect/Engineer as to accuracy or information contained in the files. The design builder shall independently verify all information in the files and shall agree to indemnify and hold the RFP Architect Engineer harmless from any and all claims, damages, losses, and expenses including, but not limited to, attorney's fee arising out of the use of the electronic files.
5. The construction record drawings shall be completed in AutoCAD version 2016.
6. Construction shop drawings are not required to be completed in AutoCAD version 2016.

D. Professional Licensing:

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

1. The D-B A-E who prepares the construction documents shall be a professional architect or engineer licensed in the state in which the design work is completed.
2. The professional seal indicating such license by the state shall appear on the final construction documents. The architect whose seal is shown will be known as the Architect of Record. The D-B A-E shall certify compliance with the VA RFP and all applicable codes.

E. Approved Construction Documents:

1. The final construction document submission package will be submitted by the D-B team for approval by the VA after completion of the 95% review cycle for the final package to be submitted by the D-B team. The VA will have 5 days to take approval action.
2. The final construction documents submission package will include a full set of construction documents including all disciplines/packages.
3. The final construction documents submission package will incorporate all VA supplied comments from the earlier 15% 30% 60% and 95% submission package reviews and will comply with the VA RFP.
4. If the final construction documents submission package is not complete a post submittal may be required the cost of which will be borne by the D-B Team.
5. The approved final construction documents include such details that the project can be constructed and will be used for construction of the project.
6. See D2 CONSTRUCTION PERIOD SUBMITTALS for Approved Construction Document distribution.

F. Construction Drawing Preparation - Mandatory material and equipment schedules and details may be indicated either on the drawings or in the specifications, at the option of the D-B team. The construction drawings shall include a coordinated set of the following:

1. Civil engineering drawings including demolition plans, grading and drainage plans, paving plans, utility plans, schedules calculations and details.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

2. Landscape drawings including demolition plans, landscape plans, plant schedule and list, special landscape elements, proposed materials to be used for each special landscape element, calculations and details.
 3. Structural drawings including foundation plans, framing plans, schedules, and details, including general notes and all calculations.
 4. Architectural drawings including floor plans, building elevations, building sections, wall sections, reflected ceiling plans, stair details, toilet and bath details, door schedules and details, window schedules and details, room finish schedules, auto transport and other details.
 5. Fire protection drawings including floor and roof plans, riser diagrams, equipment schedules, and details, including general notes calculations and all related calculations.
 6. Plumbing drawings including floor and roof plans, riser diagrams equipment schedules, plumbing fixture schedules, and details, including general notes, and all related calculations.
 7. HVAC drawings including floor and roof plans, one-line flow diagrams, equipment schedules, and details, including general notes and all related calculations. Also provide sections for mechanical equipment rooms and sequence of operation for all HVAC equipment.
 8. Outside steam distribution drawings including demolition plans, system plans and profiles, manhole piping plans, calculations and sections, equipment schedules, and details.
 9. Electrical drawings including site demolition plans, site, floor and roof plans (power, lighting, and other systems), one-line diagrams, panel schedules, equipment schedules, light fixture schedules calculations and details.
 10. Asbestos abatement drawings including site demolition plans and floor plans indicating asbestos abatement method.
 11. Parking Control drawings including paving plans, schedules calculations and details for the parking fee collection/parking control system for the entire Medical Facility.
- G. Construction Specifications - Project specifications shall include specifications for all products, materials, equipment, methods, and systems shown on the construction drawings in accordance with standard professional practice and the VA RFP. The specification submitted for review shall include:

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

1. The name of the manufacturer, the product name, model number, or other identification as appropriate to clearly identify the product that will be used in the construction of the project;
2. Other data as appropriate to clearly identify the product that will be used in the construction of the project i.e. shop drawings, product data, and samples as required by the VA RFP documents; and
3. The required stamp of the licensed architect or engineer of record will be considered as certification of compliance with the RFP requirements.

H. Design Requirements - Compliance with codes and standards.

1. Project design shall be in compliance with applicable standards and codes described in VA Program Guides and design materials included or referenced in the solicitation materials.
2. See Section E. Approved Construction documents, above, for required inclusion of design review comments.
3. In the design of new building and alteration work under this contract, the D-B team shall consider all requirements (other than procedural requirements) of:
 1. Zoning laws;
 2. Environmental and erosion control regulations; and
 3. Laws relating to landscaping, open space, minimum distance of a building from the property line, maximum height of a building, historic preservation, and esthetic qualities of a building. Also similar laws, of the State and local political division, which would apply to the building if it were not to be constructed or altered by the U.S. Government.
4. The D-B team shall consult with appropriate officials of the Federal, state, and political subdivision, and submit plans under the rules prescribed by those reviewing authorities. The A-E and VA shall give due consideration to the recommendations of the referenced building officials. VA will also permit inspection by the officials described above during the construction period in accordance with the customary schedule of inspections in the locality of the building construction. Such officials shall provide VA with a copy of the schedule before construction begins or give reasonable notice of their intention to inspect before conducting an inspection.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

5. The D-B team shall provide prompt, written notification to the Contracting Officer concerning conflicts with, or recommended deviations from codes, laws, regulations, standards, and opinions of review officials as described above. No work altering the scope of this contract shall be undertaken prior to receipt of written approval from the Contracting Officer.
 6. No action may be brought against the D-B Team or VA and no fine or penalty may be imposed for failure to carry out any of the previously described recommendations of Federal, state, or local officials. VA and its contractors, including RFP A-E, shall not be required to pay any amount for any action taken by a state or political division of a state in carrying out functions described in this article, including reviewing plans, carrying out on-site inspections, issuing permits, and making recommendations.
 7. The D-B team shall advise the Contracting Officer of any variances with the applicable Department of Labor, Occupational Safety and Health Standards, for occupancy requirements.
- I. Quality Assurance/Quality Control:
1. To reduce design errors and omissions, the D-B team shall develop and execute a QA/QC plan that demonstrates the project plans and specifications have gone through a rigorous, thorough review and coordination effort.
 2. No later than 10 calendar days of receipt of Notice to Proceed, the D-B Team will submit a detailed QA/QC plan describing each QA/QC task that will be taken during the development of the various design submission packages and the name of the D-B Team member responsible for QA/QC.
 - a. Upon its completion each task shall be initialed and dated by the responsible D-B Team member.
 - b. A 100% completed QA/QC plan shall be submitted with the final construction document submission package.
- E2. Construction Period Submittals**
- A. The D-B contractor shall distribute a total of 8 sets of the approved construction documents prepared by the D-B Team to the VA and RFP AE, as directed by the VA COR.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

- B. Other submittals - The D-B team shall submit test results, certificates, manufacturer's instructions, manufacturers field reports, etc. as required by the VA RFP specifications, to the VA R/E.
- C. Project record drawings - The D-B team will maintain a set of construction documents (field as-built drawings) to record actual construction changes during the construction process as required by the RFP specifications. The project record drawings will be available for review by the VA COR at all times.
- D. Shop drawings and submittals - The D-B A-E shall check government furnished and/or the D-B construction contractor's shop drawings, detail drawings, schedules, descriptive literature and samples, testing labor-laboratory reports, field test data and review the color, texture and suitability of materials for conformity with the RFP Documents and construction documents. The D-B A-E shall recommend approval, disapproval, or other suitable disposition to the VA RE. The VA RE will have final approval authority. The D-B AE shall evaluate the submittals with reference to any companion submittals that constitute a system. When necessary, the D-B A-E will request the D-B Construction Contractor to submit related components of a system before acting on a single component. Should this procedure be inappropriate, the D-B A-E shall review all prior submittals for related components of the system before acting on a single component. The D-B A-E may be required to hold joint reviews with the VA technical staff and /or the RFP AE on complicated system submittals. The D-B A-E shall notify the VA COR in writing of any and all deviations from the requirements of the construction documents that are found in the submittals.

D3. Project Close-Out

The D-B team shall comply with the requirements in FAR 4.804 Closeout of Contract Files, for submission of final RFP as built drawings, manuals, and other documents as noted. Required as built drawings and specifications will be submitted in the same format required for the construction documents.

D4. Site Visits and Inspections

During the construction period the D-B A-E shall make weekly visits to the project site when requested by the COR. The COR may also request visits for special purposes. Only registered architects and engineers thoroughly familiar with the project may make these site visits. The COR has the prerogative to determine the professional discipline(s) required for any visit. The D-B A-E shall observe the construction, advise the COR of any deviations or deficiencies or solutions to issues discussed. A site inspection report which includes the purpose of the inspection, items reviewed, deficiencies observed, recommendations and additional actions required, shall be furnished to the COR within five work days following the site visit date.

Attachment 1 - Section 00 11 21 Request for Proposal to Design-Build

--- E N D ---