



- ## **DRAWING NOTES:**
1. REFER TO FLOOR PLAN SHEETS FOR CONTINUATION.
 2. CAP PIPING FOR CONNECTION IN PHASE 2 OF CONSTRUCTION
 3. CONNECT WATER DISCHARGE PIPING TO EXISTING AT DOWN DRAIN.
 4. STEAM TO WATER HEAT EXCHANGER. REFER TO HVAC DRAWINGS FOR STEAM CONNECTION. PROVIDE CONCRETE EQUIPMENT BASE. REFER TO DETAILS 7 AND 8 ON SHEET PL501. INTEGRATE CONTROLS AND GAUGES PROVIDED WITH DBXL. NEW LOW BUILDING BAS INTERFACE FOR REMOTE MONITORING AND CONTROL.
 5. CONNECT WATER PIPING TO EXISTING AT DOWN SINK.
 6. REFER TO DETAIL 9 ON SHEET PL501 FOR AC-1. PROVIDE CONCRETE EQUIPMENT BASE. REFER TO DETAIL 10 ON SHEET PL501.
 7. CONNECT SANITARY PIPING TO EXISTING AT DOWN SINK.
 8. PROVIDE SANITARY STUB FOR CONNECTION IN PHASE 3 OF CONSTRUCTION. CAP PIPING AT STUB.
 9. CONNECT COMPRESSED AIR PIPING TO EXISTING AT DOWN SINK.
 10. CORE DRILL THROUGH FLOOR SLAB FOR PIPING PENETRATION. REFER TO SPECIFICATIONS FOR FURTHER INFORMATION ON PENETRATION SEVEREITY.
 11. 12" DOW TO SERVE AS MAKE-UP WATER FOR CHILLED WATER SYSTEM. PROVIDE REDUCED PRESSURE BACKFLOW PREVENTER, AIR SEPARATOR, AND EXPANSION TANK. REFER TO DETAIL 10 ON SHEET MP501.
 12. 12" DOW TO SERVE AS MAKE-UP WATER FOR HEATING HOT WATER SYSTEM. PROVIDE REDUCED PRESSURE BACKFLOW PREVENTER, AIR SEPARATOR, AND EXPANSION TANK. REFER TO DETAIL 10 ON SHEET MP501.
 13. REFER TO DETAIL 10 ON SHEET PL501 FOR CONNECTIONS TO BOP-1.
 14. REFER TO DETAIL 12 ON SHEET PL501 FOR SP-1.

[illegible]