



1 THIRD FLOOR PLAN - PHASE 1 FIRE PROTECTION DEMOLITION  
SCALE: 1/8" = 1'-0"

2 THIRD FLOOR PLAN - PHASE 0 FIRE PROTECTION DEMOLITION  
SCALE: 1/8" = 1'-0"

NOTES ELSEWHERE ON THIS DRAWING:  
(1) REMOVE THE EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER BRANCH PIPING TO THE SPRINKLER MAIN PIPING. PROVIDE NEW SPRINKLER PIPING FROM THE POINT OF DISCONNECTION TO NEW SPRINKLERS SHOWN ON THE NEW WORK PLAN.

NOTES:  
1. EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER PIPING NOT WITHIN THE CURRENT PHASE OF WORK SHALL REMAIN OPERATIONAL THROUGH PERMANENT OR TEMPORARY MEANS THROUGHOUT CONSTRUCTION.

FULLY SPRINKLERED  
ISSUED FOR BID

	<b>CONSULTANTS:</b>		<b>KEY PLAN:</b>		<b>ARCHITECT:</b>		Project Number 3515	Scale As indicated	Drawing Title THIRD FLOOR PLAN - PHASES 0 AND 1 FIRE PROTECTION DEMOLITION	Project Title REPLACEMENT OF AC-19 AND LABORATORY RENOVATION	VA Project Number VA244-P-1786	Office of Facilities Management  Department of Veterans Affairs	
	Lab Consultant HERA		MEP Engineer H.F. Lenz				 2520 Renaissance Boulevard, Suite 110 King of Prussia, PA 19406  t: 610.270.0599 f: 610.270.0995 www.arrayhfs.com		Approved: Project Director	Location 3900 WOODLAND AVENUE PHILADELPHIA, PA 19104	Drawing Number FP-111		
	230 S. Broad Street, Suite 201 Philadelphia, PA 19102 Tel (215) 670-5333 Fax (215) 670-5334		1407 Scalp Avenue Johnstown, PA 15004 Tel (814) 269-9366 Fax (814) 269-9301						Date 04-12-2012	Checked TME	Drawn JAM		Dwg. of
Revisions										Date			