



NOTES ELSEWHERE ON THIS DRAWING:
① WORK SHOWN OUTSIDE OF THE PHASE LINE IS TO BE INCLUDED IN THIS PHASE.

NOTES:
EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER PIPING NOT WITHIN THE CURRENT PHASE OF WORK SHALL REMAIN OPERATIONAL THROUGH PERMANENT OR TEMPORARY MEANS THROUGHOUT CONSTRUCTION.

FULLY SPRINKLERED
ISSUED FOR BID

CONSULTANTS:		KEY PLAN:		ARCHITECT:		Project Number 3515		Scale As indicated		Drawing Title THIRD FLOOR PLAN - PHASE 3 FIRE PROTECTION NEW WORK		Project Title REPLACEMENT OF AC-19 AND LABORATORY RENOVATION		VA Project Number VA244-P-1786		<div>Office of Facilities Management</div> <div>Department of Veterans Affairs</div>	
Lab Consultant HERA		MEP Engineer H.F. Lenz				 <div>2520 Renaissance Boulevard, Suite 110 King of Prussia, PA 19406</div> <div>t: 610.270.0599 f: 610.270.0995 www.arrayhfs.com</div>		Approved: Project Director		THIRD FLOOR PLAN - PHASE 3 FIRE PROTECTION NEW WORK		Location 3900 WOODLAND AVENUE PHILADELPHIA, PA 19104		Building Number 2			
230 S. Broad Street, Suite 201 Philadelphia, PA 19102 Tel: (215) 674-5333 Fax: (215) 674-5334		1407 Scalp Avenue Johnstown, PA 15004 Tel: (814) 269-9366 Fax: (814) 269-9301										Drawing Number FP-231					
Revisions		Date										Date 04-12-2012		Checked TME			