



1 THIRD FLOOR PLAN - PHASE 4 FIRE PROTECTION DEMOLITION  
SCALE: 1/8" = 1'-0"

NOTES ELSEWHERE ON THIS DRAWING:  
① REMOVE THE EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER BRANCH PIPING TO THE SPRINKLER MAIN PIPING. PROVIDE NEW SPRINKLER PIPING FROM THE POINT OF DISCONNECTION TO NEW SPRINKLERS SHOWN ON THE NEW WORK PLAN.

NOTES:  
EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER PIPING NOT WITHIN THE CURRENT PHASE OF WORK SHALL REMAIN OPERATIONAL THROUGH PERMANENT OR TEMPORARY MEANS THROUGHOUT CONSTRUCTION.

FULLY SPRINKLERED  
ISSUED FOR BID

		CONSULTANTS:		KEY PLAN:		ARCHITECT:		Project Number 3515		Scale As indicated		Drawing Title THIRD FLOOR PLAN - PHASE 4 FIRE PROTECTION DEMOLITION		Project Title REPLACEMENT OF AC-19 AND LABORATORY RENOVATION		VA Project Number VA244-P-1786		Office of Facilities Management			
		Lab Consultant HERA		MEP Engineer H.F. Lenz						2520 Renaissance Boulevard, Suite 110 King of Prussia, PA 19406  t: 610.270.0599 f: 610.270.0995 www.arrayhfs.com		Approved: Project Director		Location 3900 WOODLAND AVENUE PHILADELPHIA, PA 19104		Building Number 2				Drawing Number FP-141	
Revisions		Date		230 S. Broad Street, Suite 201 Philadelphia, PA 19102 Tel: (215) 670-5333 Fax: (215) 670-5334		1407 Scalp Avenue Johnstown, PA 15004 Tel: (814) 269-9366 Fax: (814) 269-9301						Date 04-12-2012		Checked TME		Drawn JAM		Dwg. of FP-141			