



1 THIRD FLOOR PLAN - PHASE 5 FIRE PROTECTION DEMOLITION  
SCALE: 1/8" = 1'-0"

NOTES ELSEWHERE ON THIS DRAWING:  
1 REMOVE THE EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER BRANCH PIPING TO THE SPRINKLER MAIN PIPING. PROVIDE NEW SPRINKLER PIPING FROM THE POINT OF DISCONNECTION TO NEW SPRINKLERS SHOWN ON THE NEW WORK PLAN.

NOTES:  
EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER PIPING NOT WITHIN THE CURRENT PHASE OF WORK SHALL REMAIN OPERATIONAL THROUGH PERMANENT OR TEMPORARY MEANS THROUGHOUT CONSTRUCTION.

FULLY SPRINKLERED  
ISSUED FOR BID

<b>CONSULTANTS:</b> <div>Lab Consultant HERA</div> <div>MEP Engineer H.F. Lenz</div> <div>230 S. Broad Street, Suite 201 Philadelphia, PA 19102 Tel: (215) 675-3333 Fax: (215) 675-3334</div> <div>1407 Scalp Avenue Johnstown, PA 15004 Tel: (814) 269-9366 Fax: (814) 269-9301</div>		<b>KEY PLAN:</b> <div>AREA A</div> <div>BUILDING 2</div> <div>N</div>	<b>ARCHITECT:</b> <div>ARRAY</div> <div>2520 Renaissance Boulevard, Suite 110 King of Prussia, PA 19406 t: 610.270.0599 f: 610.270.0995 www.arrayhfs.com</div>	Project Number 3515	Scale As indicated	Drawing Title THIRD FLOOR PLAN - PHASE 5 FIRE PROTECTION DEMOLITION	Project Title REPLACEMENT OF AC-19 AND LABORATORY RENOVATION	VA Project Number VA244-P-1786	<div>Office of Facilities Management</div> <div>Department of Veterans Affairs</div>
Revisions		Approved: Project Director		Location 3900 WOODLAND AVENUE PHILADELPHIA, PA 19104	Date 04-12-2012	Checked TME	Drawn JAM	Building Number 2	
Date								Drawing Number FP-151	
								Dwg. of	