



NOTES:  
EXISTING SPRINKLERS AND ASSOCIATED SPRINKLER PIPING NOT WITHIN THE CURRENT PHASE OF WORK  
SHALL REMAIN OPERATIONAL THROUGH PERMANENT OR TEMPORARY MEANS THROUGHOUT CONSTRUCTION.

FULLY SPRINKLERED  
ISSUED FOR BID

<b>CONSULTANTS:</b>		<b>KEY PLAN:</b>		<b>ARCHITECT:</b>		Project Number 3515		Scale As indicated		Drawing Title THIRD FLOOR PLAN - PHASE 5 FIRE PROTECTION NEW WORK		Project Title REPLACEMENT OF AC-19 AND LABORATORY RENOVATION		VA Project Number VA244-P-1786		<div>Office of Facilities Management</div> <div>Department of Veterans Affairs</div>					
Lab Consultant HERA		MEP Engineer H.F. Lenz				 <div>2520 Renaissance Boulevard, Suite 110 King of Prussia, PA 19406</div> <div>t: 610.270.0599 f: 610.270.0995 www.arrayhfs.com</div>		Approved: Project Director		THIRD FLOOR PLAN - PHASE 5 FIRE PROTECTION NEW WORK		Location 3900 WOODLAND AVENUE PHILADELPHIA, PA 19104		Drawing Number FP-251							
230 S. Broad Street, Suite 201 Philadelphia, PA 19102 Tel: (215) 675-5333 Fax: (215) 675-5334		1407 Scalp Avenue Johnstown, PA 15004 Tel: (814) 269-9366 Fax: (814) 269-9301										Date 04-12-2012		Checked TME				Drawn JAM		Dwg. of	
Revisions		Date																			