

SHEET NOTES:

1. EXISTING PIPING IS NOT LABELED. VERIFY SYSTEMS SERVED PRIOR TO MAKING SYSTEM ALTERATIONS. NOTIFY A/E AND OWNER OF DRAWING DISCREPANCIES.

KEYED NOTES:

1. REMOVE EXISTING SINK. REMOVE WATER SUPPLY PIPING BACK TO ACTIVE MAIN AND CAP AT SHUT-OFF VALVES. REMOVE WASTE AND VENT PIPING BACK TO ACTIVE MAIN AND CAP.
2. REMOVE EXISTING LAUNDRY WASHER, STANDPIPE, AND HOSE BIBBS. REMOVE WATER SUPPLY PIPING BACK TO ACTIVE MAIN AND CAP AT SHUT-OFF VALVES. REMOVE WASTE AND VENT PIPING BACK TO ACTIVE MAIN AND CAP.
3. DISCONNECT EXISTING MEDICAL AIR PIPE AND PROVIDE TEMPORARY CAPS BELOW FLOOR AND ABOVE CEILING. PREPARE EXISTING PIPE FOR EXTENSION TO NEW LOCATION AS INDICATED ON NEW WORK DRAWINGS.
4. REMOVE EXISTING EMERGENCY EYEWASH. REMOVE WATER SUPPLY PIPING BACK TO ACTIVE MAIN AND CAP AT SHUT-OFF VALVES. REMOVE WASTE AND VENT PIPING BACK TO ACTIVE MAIN AND CAP.
5. REMOVE EXISTING WATER CLOSET. REMOVE WATER SUPPLY PIPING BACK TO ACTIVE MAIN AND CAP AT SHUT-OFF VALVES. REMOVE WASTE AND VENT PIPING BACK TO ACTIVE MAIN AND CAP.
6. REMOVE EXISTING URINAL. REMOVE WATER SUPPLY PIPING BACK TO ACTIVE MAIN AND CAP AT SHUT-OFF VALVES. REMOVE WASTE AND VENT PIPING BACK TO ACTIVE MAIN AND CAP.
7. REMOVE EXISTING FLOOR DRAIN. REMOVE WASTE AND VENT PIPING BACK TO ACTIVE MAIN AND CAP.
8. DISCONNECT EXISTING O2, V, MA, AND A PIPING AND PROVIDE TEMPORARY CAPS BELOW FLOOR AND ABOVE CEILING. PREPARE EXISTING PIPE FOR EXTENSION TO NEW LOCATION AS INDICATED ON NEW WORK DRAWINGS.
9. DISCONNECT EXISTING SANITARY SEWER AND PROVIDE TEMPORARY CAP ABOVE CEILING. PREPARE EXISTING PIPE FOR EXTENSION TO NEW LOCATION AS INDICATED ON NEW WORK DRAWINGS.

NOTE:

CONTRACTOR SHALL VERIFY THE PRESENCE OF EXISTING CONDUIT IN THE SLAB PRIOR TO BEGINNING ANY WORK.

NOTE:

CONTRACTOR SHALL MEET ALL INFECTION CONTROL REQUIREMENTS AS NECESSARY TO PERFORM WORK IN PHASES.

PLUMBING PIPING SYMBOLS

—CW——CW—	EXISTING DOMESTIC COLD WATER
—HW——HW—	EXISTING NEW DOMESTIC HOT WATER
—HWR——HWR—	EXISTING DOMESTIC HOT WATER RETURN
—SAN——SAN—	EXISTING SANITARY SEWER
—V——V—	EXISTING VENT PIPING
—SD——SD—	EXISTING STORM WATER DRAIN
	NEW DOMESTIC COLD WATER
	NEW DOMESTIC HOT WATER
	NEW DOMESTIC HOT WATER RETURN
—SAN——SAN—	NEW SANITARY SEWER
	NEW VENT PIPING
—SD——SD—	NEW STORM WATER DRAIN
	POINT OF CONNECTION BETWEEN NEW AND EXISTING WORK
	CHECK VALVE
	BALL VALVE
	SOLENOID VALVE

CRAWLSPACE DEMOLITION 1/8"=1'-0"

0 4' 8' 16'
GRAPHIC SCALE

FINAL BID SET
FULLY SPRINKLERED

Revisions	Date

Dept. of Veterans Affairs
Medical Center
5000 W. National Avenue
Milwaukee, WI

P:\110007-07\Production\Images\diva.sesi2.bmp

KEY PLAN:

ENGINEER:

ARCHITECT:

Drawing Title: Partial Crawlspace Floor Plan - Plumbing Demo

Approved Project Director

Project Title: 111 Upgrade Prosthetics Product Line Improvements

Location: VA Medical Center,Milwaukee, WI

Date: 18 AUG 2012 | Checked: - | Drawn: -

Project Number: 695-11-115

Building Number: Building 111

Drawing Number: PD097

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231