

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.		1. CONTRACT ID CODE		PAGE 1		OF PAGES 3	
2. AMENDMENT/MODIFICATION NUMBER 0001		3. EFFECTIVE DATE 07-27-2018		4. REQUISITION/PURCHASE REQ. NUMBER 652-18-3-165-0200		5. PROJECT NUMBER (if applicable) None			
6. ISSUED BY Department of Veterans Affairs Network Contracting Office 6 100 Emancipation Drive Hampton VA 23667		CODE		7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Office 6 100 Emancipation Drive Hampton VA 23667		CODE			
8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders				(X)		9A. AMENDMENT OF SOLICITATION NUMBER 36C24618Q9511			
				X		9B. DATED (SEE ITEM 11) 07-25-2018			
						10A. MODIFICATION OF CONTRACT/ORDER NUMBER			
						10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE							
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS									
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. 0800AM EDT 31 Jul 2018									
12. ACCOUNTING AND APPROPRIATION DATA (If required)									
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.									
CHECK ONE									
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.									
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).									
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:									
D. OTHER (Specify type of modification and authority)									
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.									
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)									
1. This amendment has been published to provide answers to questions posed by industry. 2. As a result of this Amendment: a. All questions have been answered b. No additional questions will be accepted nor will any additional answers be provided. c. The Solicitation has been extended by 24hrs and the offer due date and time moved to 0800AM EDT 31 Jul 2018. 3. Please refer to page 2 for the list of Questions and the Government's Response. 4. All other terms and conditions remain unchanged.									
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.									
15A. NAME AND TITLE OF SIGNER (Type or print)					16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)				
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED			
(Signature of person authorized to sign)				BY (Signature of Contracting Officer)					
PREVIOUS EDITION NOT USABLE									

CONTINUATION PAGE

Questions Submitted in response to Solicitation 36C24618Q9511 and Government Responses:

Question I am hoping to find out if there is an incumbent contractor currently performing these services or if this is a new requirement. If there is an incumbent, could you please provide the contract number?

Gov't Response This is a new requirement for a Vertical Filing System with installation in which there is no incumbent. Installation of goods is the only service tethered to this project and is incidental to the Governments actual defined needs.

Question Can you tell me the dimensions of their folders, the height and length and whether there is a top tab or side tab.

Gov't Response Folder dimensions are; Front side 9 1/2" by 11 3/4", Back side 9 1/2" by 12 1/2". Pressboard with side tab.

Question Is this for the Radiation Oncology Dept?

Gov't Response Yes, this is for the Radiation Oncology department.

Question From the 129" unit width x 15 carriers = 1,935 however this is overstated and should be based on the shelf width which would be approximately 112" wide. We are thinking than that, the LFI requirement should be 1,680 LFI, not 1935.

Gov't Response The current machine that will be removed is 115 inches wide with 17 shelves. The 129 inches is the space available where the machine is at. It has to fit within the confines of the curbing available (can be less than 129). Of the 17 shelves we currently have, 2 are not in use for records.

Question In addition, what is the ceiling height in the room and is it a drop ceiling?

Gov't Response The 102 inches described in section b. of the salient characteristics is the ceiling height with consideration given to the drop ceiling in place with an additional 5 inches of available space above the drop ceiling. All dimensions provided in the salient characteristics in regards to curbing are maximum dimensions.

Question We would like to request for Pre-bid Site Visit

Gov't Response The Government does not believe that a Pre-Offer Site Visit is merited for this project. All specifications that need to be adhered to are contained within the Salient Characteristics. Prospective offerors are advised to draft responses that meets the minimum need of the Government as defined in the solicitation.

(End of Questions and Responses)