

## **RFI FORM**

**Contractor Name:** NelsonHCS Inc.

**Address:** 3050 Pullman Street, Costa Mesa CA 92626

**Phone/Fax:** (310) 420-4200 (Phone)

**Send to:** timothy.saffles@va.gov

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	606-15-351	<b>RFI NO.:</b>	003
<b>PROJECT NAME:</b>	Steam Distribution Deficiencies Correction, VA Loma Linda	<b>DATE REQUESTED:</b>	July 31, 2018
<b>SOLICITATION NO.:</b>	3625818B0324	<b>REFERENCE:</b>	Schwab Drawings dated June 16, 2017
<b>DRAWING:</b>	M-002M101, M-102, M-103, M104	<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
<p>Please be specific as possible:</p> <p>1. M-002 Pump Schedule for all 8 locations notes "Spirax Sarco PTC Simplex Pump Package or Approved Equal". Q - Please advise Approved Equal Pump Package Manufacturer and their related Model Number(s)/Part Number(s)</p> <p>2. Drawings M101, M-102, M-103 and M-104 Steam Trap General Note #2 all state "All End of Main Steam Traps (Drip Traps Only) That Are To Be Replaced Shall Be Complete With Universal Steam Trap Station Similar To Spirax Sarco Model USTS II Or Approved Equal in Armstrong and Watson McDaniel". Q - Please advise End of Main Steam Trap Armstrong and McDaniel Approved Equal Model Numbers/Part Numbers.</p>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<p style="color: red;">Determination of approved equal will be accomplished by VA during product submittal stage, after contract award. It is the responsibility of the contractor to determine additional manufacturer's product that meets the minimum qualifications of applicable specifications.</p> <p style="color: red;">Spec 01 33 23 - 1: "Submit for approval, all of the items specifically mentioned under the separate sections of the specification, with information sufficient to evidence full compliance with contract requirements."</p>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>		<b>DATE:</b>	