










IF THIS SHEET IS NOT 30" x 42" FULL SIZE, USE GRAPHIC SCALES




**1 ELECTRICAL LIGHTING PART PLAN**  
Scale : 1/4" = 1'-0"




**3 ELECTRICAL LIGHTING PART PLAN**  
Scale : 1/4" = 1'-0"




**2 ELECTRICAL POWER PART PLAN**  
Scale : 1/4" = 1'-0"



**4 ELECTRICAL POWER PART PLAN**  
Scale : 1/4" = 1'-0"



**5 ELECTRICAL POWER PART PLAN**  
Scale : 1/4" = 1'-0"




- REFER TO DRAWING E-3 FOR SYMBOL LIST
- KEYED NOTES - LIGHTING AND POWER
- INSTALL (B) NEW 20A-1P BREAKERS IN EXISTING PANEL LPB IN SPACE 3738/436/450 & INSTALL (I) NEW 15A-2P BREAKER IN SPACE 40/42. REFER TO DRAWING E-3 FOR SCHEDULES
  - CONNECT LIGHT FIXTURE TO EXISTING LIGHT FIXTURES OUTLET BOX WITH 2#12-60-3/4" C
  - CHASE FLOOR FOR NEW CONDUITS FOR POWER TO RECEPTACLES 2#12-60-3/4" RSCG
  - ELECTRICAL CONTRACTOR SHALL REPLACE EXISTING 40 CIRCUIT 2 SECTION PANEL LPE WITH NEW 60 CIRCUIT 2 SECTION PANEL. RECONNECT EXISTING MAIN FEED TO NEW PANEL. REFER TO DRAWING E-3 FOR SCHEDULE 4 ADDITIONAL INFORMATION
  - CONNECT TO EXISTING EMERGENCY LIGHTING CIRCUIT ELFA/4 WITH 2#12-60-3/4" C
  - EXISTING FIRE ALARM HORN TO BE REINSTALLED IN NEW HMG CEILING. PROVIDE NEW OUTLET BOX AND WIRING AS REQUIRED.
  - EXISTING ANSUL R-102 KET CHEMICAL SYSTEM NEW LOCATION. ANY POWER AND ASSOCIATED WIRING SHALL BE PERFORMED BY FIRE COMMAND CREW BY CONTRACTOR

REFER TO ARCHITECTURAL DRAWINGS FOR LIGHTING FIXTURE SCHEDULE

**EMTG** CONSULTING ENGINEERS  
EMTGENGINEERS.COM  
TEL: 212-268-6465 FAX: 212-268-6467  
115 WEST 30TH STREET, SUITE 202, NEW YORK, NY 10001

**Kenneth Irving, Architect P.C.**  
42 MEMORIAL PLAZA SUITE 301, PLEASANTVILLE, NY 10570  
PHONE: (914) 747-0002 E-MAIL: mandrade@kiarch.com FAX: (914) 747-9211

NOTE AND READ CAREFULLY:  
The Contractor shall consult and study the requirements of each and every drawing and each specification section of this contract so that he/she may become acquainted with the project as a whole in order to determine how the work of his/hers subcontractor or vendor may affect the work required under this contract.  
Written Specifications are part of this contract



Drawing Title  
**ELECTRICAL POWER AND LIGHTING PART PLANS**

Approved: Division Chief

Approved: Service Director

Project Title  
**Implement Community Living Center Cultural Transformation**

Date  
**3/30/2012**

Project No.  
**632-08-123**

DRAWING NO.  
**E-4**

Dwg. 33Df 34

