









IF THIS SHEET IS NOT 30" x 42"
FULL SIZE, USE GRAPHIC SCALES




- SUPPLY BRANCH DUCT SPLITTER TYPE DAMPER
- SUPPLY OR RETURN SINGLE LEAF DAMPER
1. ALL BRANCH DUCTS SHALL BE PROVIDED WITH MANUALLY OPERATED VOLUME DAMPERS. DAMPERS AT DIFFUSERS ARE IN ADDITION TO BRANCH DAMPERS.
 2. DUCTS LARGER THAN 48 IN SHALL HAVE MULTIPLE SINGLE LEAF DAMPERS WITH LOCKING QUADRANTS EACH SIDE.

VOLUME DAMPER DETAILS
NTS




- NOTES:
1. WHEN DAMPER IS LOCATED WITHIN 10' OF A DIFFUSER OR WITHIN A LOBBY OR SPECIALTY SPACE (COORDINATE WITH ARCHITECT), VOLUME DAMPER ASSEMBLY SHALL BE OPERABLE THROUGH FACE OF NEAREST DIFFUSER BY MEANS OF FLEXIBLE CABLE BASED ON BOWDEN REMOTE CABLE CONTROL SYSTEM WITH YOUNG REGULATOR.
 2. ALL OTHER NON-ACCESSIBLE CEILING AREAS SHALL BE AS INDICATED.


VOLUME CONTROL DAMPER
FOR NON ACCESSIBLE CEILING ONLY



METHOD OF HANGING DUCT WORK
NTS




EXHAUST OR RETURN BRANCH DUCTWORK
NTS



- NOTE:
UNLESS OTHERWISE INDICATED ON PLANS, MAXIMUM ANGLES SHOWN SHALL APPLY.

DUCTWORK TRANSITIONS
(WITH EQUIPMENT MOUNTED IN DUCT)

NTS



NOTES:

1. ALL VANE ELBOWS SHALL BE CONSTRUCTED AND INSTALLED AS DETAILED BY SMACNA.
2. WHEN W1 DOES NOT EQUAL W2, VANE SHALL BE SINGLE THICKNESS VANE TYPE REGARDLESS OF W DIMENSION.
3. ALL SINGLE THICKNESS VANES SHALL HAVE A 2" (50mm) RADIUS, 1 1/2" (40mm) MAXIMUM SPACE BETWEEN VANES AND A 3/4" (20mm) TRAILING EDGE.
4. WHEN W1 EQUALS W2 AND W1 IS GREATER THAN 20" (500mm) VANES SHALL BE DOUBLE VANE TYPE.

DUCTWORK SQUARE VANE ELBOWS
NTS

EMTG
Consulting Engineers

EMTGENGINEERS.COM

TEL: 212-268-6465 FAX: 212-268-6467

115 WEST 30TH STREET, SUITE 202, NEW YORK, NY 10001

Revisions

Date

VA FORM 08-6231, DEC 1989

KIRK
KENNETH IRVING, ARCHITECT P.C.

42 MEMORIAL PLAZA SUITE 301, PLEASANTVILLE, NY 10570

PHONE (914) 747-0002 E-MAIL Lmandraco@kirch.com FAX (914) 747-9211

NOTE AND READ CAREFULLY:

The Contractor shall consult and study the requirements of each and every drawing and each specification section of this contract so that he /she may become acquainted with the project as a whole in order to determine how the work of his/hers subcontractor or vendor may affect the work required under this contract.

Written Specifications are part of this contract

KEY PLAN



BUILDING 92

Drawing Title
MECHANICAL DETAILS

Approved: Division Chief

Approved: Service Director

Project Title
Implement Community Living
Center Cultural Transformation

Building Number
92

Checked
MA

Drawn
MA/DC

Location
Northport, New York

Date
3/30/2012

Project No.
632-08-123

DRAWING NO.

M-3

Dwg. 2nd of 34



U.S. GOVERNMENT PRINTING OFFICE: 1983-400-250