











IF THIS SHEET IS NOT 30" x 42"
FULL SIZE, USE GRAPHIC SCALES





1 ELECTRICAL LIGHTING PART PLAN
Scale : 1/4" = 1'-0"



2 ELECTRICAL POWER PART PLAN
Scale : 1/4" = 1'-0"






3 ELECTRICAL LIGHTING PART PLAN
Scale : 1/4" = 1'-0"




4 ELECTRICAL POWER PART PLAN
Scale : 1/4" = 1'-0"

SYMBOL LIST - LIGHTING AND POWER	
▼	DATA TELEPHONE OUTLET WITH 1" STUB UP
▼	NURSES CALL DATA OUTLET WITH 1" STUB UP
①	KEYED NOTE
Ⓢ	SINGLE POLE LIGHTING SWITCH (LOWER CASE LETTER DENOTES FIXTURE CONTROL)
Ⓢ	SWITCH WITH DIMMER CONTROL
Ⓢ	JUNCTION BOX
Ⓢ	SIMPLEX RECEPTACLE 20A-2P-125V
Ⓢ	DUPLEX RECEPTACLE 20A-1P-125V WITH GROUND FAULT PROTECTION
Ⓢ	DOUBLE DUPLEX RECEPTACLE 20A-125V
Ⓢ	SIMPLEX RECEPTACLE 250V - REFER TO DRAWING FOR RECEPTACLE NEMA RATING
—	WIRING RUN CONCEALED
—	NEW HOMERUN TO PANELBOARD
Ⓢ	PANELBOARD (EXISTING)
Ⓢ	EXISTING FIRE ALARM HORN DEVICE
Ⓢ	AREA SMOKE DETECTOR
Ⓢ	CEILING MOUNTED OCCUPANCY SENSOR - NATSTOPPER DT-355
Ⓢ	NEW FIRE ALARM STROBE - MTD # 80" A.F.F.
Ⓢ	NEW FIRE ALARM HORN STROBE - MTD # 80" A.F.F.
"E"	NEXT TO SYMBOL INDICATES EXISTING TO REMAIN
"RL"	NEXT TO SYMBOL INDICATES NEW LOCATION OF EXISTING
"N"	NEXT TO SYMBOL INDICATES NEW
Ⓢ	NEW TAMPER SWITCH
Ⓢ	MAGNETIC DOOR HOLDER

KEYED NOTES - LIGHTING AND POWER	
①	INSTALL (4) NEW 20A-1P BREAKERS IN EXISTING PANEL LPA (SECTION B) IN SPACE 579535.662. REFER TO SCHEDULE ON DRAWING E-3
②	CONNECT NEW LIGHT FIXTURES TO EXISTING SWITCHES WITH 2#2-60-3/4" - REFER TO SWITCH DETAIL
③	CONNECT TO EXISTING EMERGENCY LIGHTING CIRCUIT EPA/II WITH 2#2-60-3/4"
④	INSTALL (4) NEW 20A-1P BREAKERS IN EXISTING PANEL LPD (SECTION B) IN SPACES 553532.284. REFER TO SCHEDULE ON DRAWING E-3
⑤	NEW DUPLEX RECEPTACLE AND DATA OUTLET FOR NURSES CALL SYSTEM DIGITAL DISPLAY. MOUNTING HEIGHT SHALL BE COORDINATED WITH VANG RESIDENT ENGINEER. DUPLEX RECEPTACLE SHALL BE CONNECTED TO EXISTING CRITICAL CIRCUIT PREVIOUSLY FEEDING DIGITAL DISPLAY WITH 2#2-60-3/4"
⑥	NEW DATA OUTLET WITH 1" STUB UP INTO HANG CEILING. DATA CABLE TO BE CONNECTED TO NURSES CALL SYSTEM WITH APPROVED MANUFACTURERS WIRING. COORDINATE EXACT LOCATION WITH VANG RESIDENT ENGINEER. REPROGRAM / RECONFIGURE NURSES CALL SYSTEM AS REQUIRED. WORK TO BE PERFORMED ONLY BY CERTIFIED/QUALIFIED TECHNICIANS/INSTALLERS EXPERIENCED IN SERVICING THIS EXISTING MAKE/MODEL SYSTEM.
⑦	EXISTING FIRE ALARM HORN TO BE REINSTALLED IN NEW HANG CEILING. PROVIDE NEW OUTLET BOX AND WIRING AS REQUIRED.
⑧	CONNECT TO EXISTING EMERGENCY LIGHTING CIRCUIT 2EP/3 WITH 2#2-60-3/4"
⑨	POWER STRIP FOR EQUIPMENT CHARGERS. COORDINATE EXACT LOCATION IN FIELD WITH VANG RESIDENT ENGINEER.




EMTG
Consulting Engineers
TEL: 212-268-6465 FAX: 212-268-6467
115 WEST 30TH STREET, SUITE 202, NEW YORK, NY 10001



Revisions
VA FORM 08-6231, DEC 1989

KIR
KENNETH IRVING, ARCHITECT P.C.
42 MEMORIAL PLAZA SUITE 301, PLEASANTVILLE, N.Y. 10570
PHONE: (914) 747-0002 E-MAIL: mandraoe@kirarch.com FAX: (914) 747-9211

NOTE AND READ CAREFULLY:
The Contractor shall consult and study the requirements of each and every drawing and each specification section of this contract so that he/she may become acquainted with the project as a whole in order to determine how the work of his/hers subcontractor or vendor may affect the work required under this contract.
Written Specifications are part of this contract



Drawing Title
ELECTRICAL POWER AND LIGHTING PART PLANS
Approved: Division Chief
Approved: Service Director

Project Title
Implement Community Living Center Cultural Transformation
Building Number
92
Checked
MA
Drawn
MA/DC
Location
Northport, New York

Date
3/30/2012
Project No.
632-08-123
DRAWING NO.
E-3
Dwg. 320f 34

