



UNITED ANALYTICAL SERVICES, INC.  
1429 CENTRE CIRCLE DR, DOWNERS GROVE, IL 60515  
OFFICE: (630) 691-8271 FAX: (630) 691-1819

Invoice No. 1619903

## INVOICE

### Customer

Name VA Medical Center  
Address 1900 East Main Street  
City Danville State IL ZIP 61832  
Project  
Location 58-5 Surgery Suite

Date 11/16/2016  
Proj. No. 1619903  
Proj. I.D. P70264  
ATTN Daniel Kraybill

E-Mail: [daniel.kraybill@va.gov](mailto:daniel.kraybill@va.gov)

Qty	Description	Unit Price	TOTAL
4	3 Day PLM	\$10.00	\$40.00
Payment Terms: Net 30 days from the date of Invoice Past Due Balances accrue interest at 1.5% per month.			

UAS is proud to announce over 25 years in business



Since 1988

Interest	
TOTAL	\$40.00

1429 Centre Circle Drive Downers Grove, IL. 60515

Phone - 630-691-8271 / Fax - 630-691-1819 / E-mail - [kbuehler@uas1.com](mailto:kbuehler@uas1.com)



UNITED ANALYTICAL SERVICES, INC.  
1429 CENTRE CIRCLE DR., DOWNERS GROVE, IL 60515  
OFFICE: (630) 691-8271 FAX: (630) 691-1819

Page 1 of 1

## PLM LABORATORY REPORT

<b>METHOD:</b> EPA/600/R-93/116 July 1993 PLM w/ Dispersion Staining				<b>REPORT DATE:</b> November 16, 2016					
<b>CLIENT:</b> VA Medical Center				<b>DATE RECEIVED:</b> November 15, 2016					
<b>ATTENTION:</b> Daniel Kraybill				<b>UAS SAM#:</b> 1619903					
<b>email:</b> daniel.kraybill@va.gov				<b>JOB LOCATION:</b> 58-5 Surgery Suite P70264					
LAB SAMPLE #	CLIENT SAMPLE #	COLOR	DESCRIPTION LOCATION	ASBESTOS TYPE	%	OTHER FIBERS	%	MATRIX	%
1619903 -01	1	Beige & Silver	Paper Wrapping Behind Sterilizer	ND	--	CELL	45	O	55
1619903 -02	1a	Yellow	Pipe Insulation Behind Sterilizer	ND	--	FBGL	95	O	5
1619903 -03	2	Beige & Silver	Paper Wrapping Behind Sterilizer	ND	--	CELL	40	O	60
1619903 -04	2a	Yellow	Pipe Insulation Behind Sterilizer	ND	--	FBGL	90	O	10
<b>Analysis Comments:</b>  Samples analyzed according to the EPA/600/r-93 116 July 1993 titled Method for the Determination of Asbestos in Bulk Building Materials Further testing by Gravimetric or TEM methods are recommended for samples that are non-friable such as floor tiles, mastics, etc. Report shall not be reproduced except in full, without the written approval of the laboratory. Laboratory results pertain to those delivered for analysis. Samples will be discarded if not notified by the client within 90 days.				<b>CODES ASBESTOS</b>		<b>CODES OTHER FIBERS</b>		<b>CODES MATRIX</b>	
				ND-None Detected CHRY-Chrysotile AMOS-Amosite CROC-Crocidolite TREM-Tremolite ACTN-Actinolite ANTH-Anthophyllite		FBGL-Fibrous Glass CELL-Cellulose SYN-Synthetic WOLL-Wollastonite H-Hair O-Other (Specify)		G-Gypsum C-Calcium Carbonate M-Mica O-Other Matrix	

ANALYZED BY -

Karen Buehler / Laboratory Manager

November 16, 2016

DATE ANALYZED



NVLAP Lab Code 101732-0

This report must not be used by the client to claim product endorsement by NVLAP or any agency of the United States Government.

PLM Master Report/01-02-14/KB

